

RE-CONDUCTORING OF TRANSMISSION LINES TO INCREASE CAPACITY

Ramjee Kuberalingam

(119135A)



University of Moratuwa, Sri Lanka.
Electrical Engineering & Sciences
Degree of Master of Sciences
www.lib.mrt.ac.lk

Department of Electrical Engineering

University of Moratuwa
Sri Lanka

July 2016

RE-CONDUCTORING OF TRANSMISSION LINES TO INCREASE CAPACITY

A thesis submitted to the
Department of Electrical Engineering, University of Moratuwa
in partial fulfillment of the requirements for the



Degree of Master of Science
University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

Ramjee Kuberalingam

Supervised by:

Prof. H. Y. Ranjith Perera

Department of Electrical Engineering
University of Moratuwa, Sri Lanka

DECLARATION

The work submitted in this thesis is the result of my own investigation, except where otherwise stated.

It has not already been accepted for any degree, and is also not being concurrently submitted for any other degree.

Ramjee K

(Candidate)

April 4, 2016



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

I endorse the declaration by the candidate.

Prof. H. Y. Ranjith Perera

(Supervisor)

Acknowledgement

Many thanks are due first to my supervisor, Prof. H. Y. Ranjith Perera, for his great insights, perspectives and guidance throughout the entire duration of the study.

Author extends his sincere gratitude Prof. N. Wickramarachchi, Head of the Department of Electrical Engineering, for providing him the Research Assistantship and excellent assistance during the study period.

Sincere thanks are also due to the officers in Post Graduate Office of the Faculty of Engineering, University of Moratuwa for helping in various ways to clarify the things related to academic works in time with excellent cooperation and guidance. Thanks are also due to the staff of the Department of Electrical Engineering for the support extended during the study period. Also, I wish to gratefully acknowledge the assistance extended by Mr. Anuruddha Tilakaratne, Project Manager, Ceylon Electricity Board. [University of Moratuwa, Sri Lanka](#).

I would also like to acknowledge with much appreciation to Mr R.C.V. Kumara, Civil Engineer, Ceylon Electricity Board, Mr. S.M.D Senerath., Senior Design Engineer, LTL Projects and Mr GR Kodikara, Electrical Engineer, Ceylon Electricity Board who gave assistance in PLS Tower software the valuable advices and friendly help for this research to end up with efficient result.

Many thanks are also due to many individuals, friends and colleagues who have not been mentioned here by name in making this educational process as success. Lastly, I would like to express my heartiest gratitude and love to my parents, my daughter and wife, who took a lot of burden and patience, helping me to complete this work in difficult circumstances.

Abstract

Electric power consumption, is increasing rapidly, showing growth faster growth in the last few decades. To meet the increase in demand of electricity the expansion of transmission networks is needed all over the country. In Sri Lanka most of the electric lines are saturated, they are reaching critical values of capacity and sag. Therefore, building new lines is necessary to provide the ever increasing consumption. The difficulty to find line route and environmental issues limited the construction of new overhead lines. Therefore, there is an urgent need to find out some alternatives that increases the power transfer capacity of the existing lines. This circumstance is forcing the use of the existing lines, which represents a cheaper solution compared underground transmission for countries like Sri Lanka.

This research study is focused on finding facts to replace the conductor by a high current capacity one. In this study, a suitable alternative method is proposed for existing transmission lines comprising zebra conductors. In order to evaluate the potential benefits of re conducting of a transmission network a holistic computational methodology is used. This allows sag, capacity and tension calculations to be carried out for each section of selected transmission line.

Further, PLS -Tower and PLS – CADD software is used to analyze usage of various high current rating conductors in the market with the new technologies. Tower loads due to wind, weight of the conductor etc.. are calculated and loaded to the existing towers to check the strength.

The proposed technique can be used to analyze the tower strength to replace high current capacity conductors. The same can also be used as a powerful method at planning stage at the new transmission line projects.

TABLE OF CONTENTS

Declaration	i
Acknowledgement	ii
Abstract	iii
Table of Contents	iv
List of Figures	vi
List of Tables	vii
List of Abbreviations	viii
List of Appendices	ix
1.0 INTRODUCTION	1
1.1 Background	1
1.2 Objectives	2
1.3 Case Study	2
University of Moratuwa, Sri Lanka.	2
1.4 Methodology	2
Electronic Theses & Dissertations	2
2.0 DESIGN ASPECTS OF A 132kV TRANSMISSION LINE	4
2.1 Applicable Standards	4
2.2 132kV Tower Design	4
2.2.1 Suspension Tower	5
2.1.2 Tension Tower	5
2.2.3 Transposition Tower	5
2.2.4 Tower Extensions (Leg or Body Extensions)	6
2.2.5 Tower structure	6
2.2.6 Insulator Swing Angle	7
2.2.7 Arching Horn Gap	7
2.2.8 Overhead Earth and Shielding Angle	7
2.2.9 Basic Span	8

2.2.10 Equivalent Span or Ruling span	9
2.2.11 Wind Span	9
2.2.12 Weight Span	9
2.3 Loading on Tower (Suspension Tower - TDL)	10
2.3.1 Transverse Load	10
2.3.2 Longitudinal Load	11
2.3.3 Vertical Load	11
2.4 Sag Tension Calculation	12
2.5 Tower Structure Design	14
2.6 Electrical Clearance Diagram of 132kV Transmission Tower	18
2.7 Wind Load on Tower	18
2.8 Load Showing on Tree Diagram for Each Case	20
3.0 SOFTWARE USED FOR STRUCTURAL ANALYSIS AND MODELING	25
3.1 Design Criteria	26
 University of Moratuwa, Sri Lanka. Electronic Theses & Dissertations www.lib.mrt.ac.lk	26
3.2 Modeling and Analysis in PLS-Tower (for TDL tower)	27
3.3 Wind Span Vs Angle of Deviation	28
3.4 Creep Calculation (Temperature Shift Calculation)	31
4.0 PROFILE DESIGN	35
4.1 Clearances to Ground, objects under the line and at crossings	35
4.2 PLS-CADD Software	36
5.0 COST and TIME IMPACTS OF A NEW TRANSMISSION LINE CONSTRUCTION	37
6.0 CONCLUSION	38
REFERENCE	39
APPENDIX	

List of Figures

Figure 2.2.3: Transposition Tower	5
Figure 2.2.6 : Insulator Swing Angle	7
Figure 2.2.8 : Overhead Earth and Shielding Angle	8
Figure 2.2.9 : Basic Span	8
Figure 2.2.10: Equivalent Span or Ruling span	9
Figure 2.2.12: Weight Span	9
Figure 2.3: Loading on Tower (Suspension Tower - TDL)	10
Figure 2.3.3: Vertical Load on a tower	11
Figure 2.4 Catenary Curve for level spans	12
Figure 2.7: Wind Load on Tower, Sri Lanka.	18
Figure: 3.0 shows typical transmission towers configurations which can be modeled with PLS-TOWER.	26
Figure 3.3: Wind Span Vs Angle of Deviation	28

List of Tables

Table 2.3.3: Weight Span of a 132kV Transmission tower according to CEB Specification	12
Table 2.4.1: Properties of the Conductors and Earthwire	13
Table 2.4.2: Properties of the Conductors	13
Table 2.7: Wind load on a TDL single peak tower	19
Table 3.3.1: Angle of Deviation of TDL tower	29
Table 3.3.2: Angle of Deviation of TD1 tower	30
Table 3.4.1: Creep Calculation	32
Table 3.4.2: Creep Calculation	33
Table 3.4.3 : Creep Calculation Result	34
Table 4.1: Line Clearances as per the CEB specification	35



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

List of Abbreviations

BS – British Standards for Design and Construction

CEB - Ceylon Electricity Board

ISO – International Organization for Standardization

OPGW – Optical Fibre Ground wire

PLS – Power Line System software

TDL - Tower Double circuit Line

TD1 - (Tower Double circuit –Deviation angle 0°- 10°)

TD3 - (Tower Double circuit –Deviation angle 10°- 30°)

TD6 - (Tower Double circuit –Deviation angle 30°- 60°)

TDT - (Tower Double circuit Terminal)

WS – Wind span

For Earth wire (OPGW)


University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations

- Ne –Numbers
- De (mm) - Diameter
- We (kN/m) - Weight
- Te (kN) – Tension
- Pe (kN/m²) – Wind pressure

List of Appendices

- Appendix A Existing 132kV Tower Details
- Appendix B Proposed New Low loss conductor technical specifications
- Appendix C sag tension calculation for the both existing Zebra conductor and proposed conductors
- Appendix D Electrical Clearance Diagram of 132kV Transmission Tower
- Appendix E Member Detail of TDL Tower
- Appendix F PLS –Tower Design
- Appendix G PLS Tower Analysis Results for a TDL+9 tower
- Appendix H Tower Analysis of Vavuniya Kilinochchi Transmission Line
- Appendix I Angle of Deviation for the other towers such as TD3, TD6 and TDT
- Appendix J Profile Design



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

1. INTRODUCTION

1.1 Background

Power Transmission from Generating Station to Substations (Grid) is the fundamental objects of the Power System. This function is accomplished by overhead transmission lines that connect the power plants into the distribution networks in Sri Lanka.

The growing demands on the dynamic capacity of transmission system and utilities in Sri Lanka are looking costly. The construction of new transmission line essential to cater reliable supply of electricity and meet the growing demand in each provinces in the country. The construction of new transmission line require additional land, environmental issues, project implementation period also relatively high. The cost of new transmission line construction includes cost of towers, conductor, insulators, hardware and the cost of land covered by the tower foundation. Also environmental clearance from the government, Stating that there are no objections on environmental issues in the particular transmission line project needs to be submitted to the funding agency when looking for funds.

Therefore we need to come across the solution how the existing lines can be utilized more efficiently. In this regard, several alternative way to increase the power transfer capacity of an existing Transmission line, such as , convert it from AC to DC transmission system, Consider the Voltage upgrading mechanism, replace the conductor by a high current capacity one without modifying the existing towers, line accessories etc... Hence, AC to DC conversion system need total modification in the Grid substation and suitable for long transmission line system and other hand the Voltage upgrading mechanism also require the modification in the Grid Substation as well as Transmission Line that imply more cost and time. Therefore, Re-conductoring of Transmission Line by substituting a high current carrying conductor is the relatively best option for countries like Sri Lanka while considering the electromechanical properties of the particular transmission line.

1.2 Objectives

The construction of new transmission lines to transfer more power from the Generating Station to Substations (Grid) need large extent of land, substance amount of steel and foundation cost, consume more time for construction works and etc., which cause to the high cost to the supply providers. In addition to the high cost a number of indirect impediments are encountered in implementing of the projects with the current design of towers such as objection by land owners and environmentalists where the transmission lines running through urban areas. Therefore, it becomes essential to increase current carrying capacity of the existing transmission line with the optimum cost in this study. In this case I used low loss conductor to substitute the existing one.

1.3 Case Study

This case studies have been carried out by modeling the existing 132kV transmission lines currently in operation in 132kV Vavuniya to Kilinochchi transmission line (Zebra conductor with the nominal current rating of 760 A @ 75° C) and 132kV Anuradhapura to Vavuniya transmission line (Lynx conductor with the nominal current rating of 450 A @ 75° C). This achieved by using computer software's PLS-Tower and PLS-CADD.

Five different spans form each transmission lines are selected for this study. The existing tower architecture and profile survey were used to configure the additional load of the larger current rating conductors for the safety of the towers and the electrical clearances. The details are given in the Appendix A and B.

1.4 Methodology

Earlier the design of transmission line was made as per design philosophy based on deterministic concept of Loadings and strengths with specified factors of safety for the different operating conditions. Now the design of transmission line is made as per design philosophy based on probabilistic concept of Loadings and strengths with specified factors of safety for the different operating conditions. Further the design

must consider the optimum utilization of the transmission towers because those are constituting about 30-40 percent of the cost of transmission line.

This case study is based on data obtained by reviewing the existing tower literature on different design of transmission towers and comparing the cost of manufacture and other social and practical implication of existing design with the proposed design. In this study the proposed large current rating conductors manufacturing data used to analyze the tower by using the computer software called PLS-Tower and profile design of selected spans has been achieved by the software called PLS-CADD.



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

2.0 DESIGN ASPECTS OF A 132kV TRANSMISSION LINE

2.1 Applicable Standards

Following standards are used in this study.

- ANSI/ASCE 10-97 –Design of Latticed steel transmission structures
- ISO 898–1 –Mechanical properties of fasteners. Part 1-Bolts, screws and studs.
- ISO 630 – Structural Steels – plates, wide flats, bars, sections and profiles
- ISO 1459 – Metallic coatings – Protection against corrosion by Hot Dip Galvanizing.
- ISO 7411 – Hexagon Bolts for high strength structural bolting with large width across flats.
- ISO 657– 5 – Hot rolled structural steel sections equal and unequal leg angles.

 University of Moratuwa, Sri Lanka.
Basically Transmission Line Design comprise the followings.
www.lib.mrt.ac.lk

1. Sag-Tension calculation
2. Tower Design
3. Wind Span Vs Angle of Deviation
4. Creep Calculation
5. Profile Design

2.2 132kV Tower Design

Tower design is one of the most important factors for reliable operation and lifetime of a transmission line. The tower of various shapes is being used with increasing environmental concern and the public becoming more and more conscious of the detrimental effects of transmission line towers on the environment and land use. In Ceylon Electricity Board (CEB) transmission system there are three types of towers.

- a) Suspension Tower
- b) Tension Tower
- c) Transposition Tower

2.2.1 Suspension Tower

These towers are used on the lines for straight run or for small angle of deviation up to 2° or 5° . Conductor on suspension towers may be supported by means of I-string in CEB transmission System. In double circuit transmission lines this types of towers are called TDL towers.

2.2.2 Tension Tower

Tension towers also known as angle towers are used at locations where the angle of deviation exceeds that permissible on suspension towers and/or where the towers are subject to uplift loads. These towers are further classified as

Up to 10° angle deviation TD1

$10^\circ - 30^\circ$ angle deviation TD3

 University of Moratuwa, Sri Lanka.
30°- 60° angle deviation TD6
www.lib.mrt.ac.lk

Terminal tower (more than 60° of angle of deviation) TDT

Those towers are used according to the angle of deviation of line. One of the classes of angle towers depending on the site conditions is also designated as Section Tower. The section tower is introduced in the line after certain distance to avoid cascade failure or series failure of towers.

2.2.3 Transposition Tower

Transposition towers are used to transpose the phase conductors in three sections in such a way that each phase by rotation occupies each of the three phase positions in a circuit.




Figure 2.2.3: Transposition

2.2.4 Tower Extensions (Leg or Body Extensions)

Body extension is used to increase the height of tower (3m, 6m, 9m, and 12m) with a view to obtaining the required minimum ground clearance over road crossing, river crossings, power line crossings, ground obstacles etc. For body extensions having greater heights more than 25m, the suitability of the standard tower is checked by reducing the span length and angle of deviation. Leg extensions are used either with anyone leg or any pair of legs at locations where footings of the towers are at different levels. Leg extensions are generally used in hilly regions to reduce benching or cutting. Leg extensions of -2m, -1m, +1m, +2m, and +3m also used where necessary.

2.2.5 Tower structure

Tower structure is fixed from the requirement of minimum ground clearance, terrain type, right of way limitation, electrical clearances etc. Tower structure is defined in terms of the following parameters.

Tower Height



- Minimum ground clearance
- **University of Moratuwa, Sri Lanka.**
- **Electronic Theses & Dissertations**
- Maximum sag of conductor
- www.lib.mrt.ac.lk
- Length of suspension insulator string assembly
- Vertical spacing between power conductors
- Location of ground wire
- Angle of shield
- Minimum mid span clearance

Cross Arm Spread

- Length of insulator string assembly
- Length of the insulator
- Tension string
- Jumper Suspension string
- Swing angle
- Conductor jumper

- Phase to phase horizontal spacing
- Bundle Conductor configuration

2.2.6 Insulator Swing Angle

At the heavy wind condition suspension insulators swing with certain angle. If we consider a double circuit line one circuit swings away from the tower and one is towards the tower. Then the line clearance gets reduced. Therefore, it is important to consider swing angle during the design. The factors effects to swing angle is length of the insulator set, Wind force, weight span, wind span, conductor type, Insulator type, etc.




Figure 2.2.6 : Insulator Swing Angle

2.2.7 Arching Horn Gap



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations

This is very important in connection with lightning protection. This mainly depends on air breaking voltage and the pollution level of the area. Normal air breaking voltage is 21kV/cm at the clear air. For 132kV transmission line the Arching Horn Gap is calculated for the impulse voltage of 800kV.

2.2.8 Overhead Earth and Shielding Angle

Double earth wire configuration towers are erected in areas of high lightning activity, or with supporting structures with wide horizontal spacing configurations, two earth wires were provided to permit a lower shielding angle and superior protection. The tower height reduce by the use of double earth configurations. Shielding angle of the double earth configuration is almost 0 degree. In this case more critical in the mid span clearance of the conductors.




Figure 2.2.8 : Overhead Earth and Shielding Angle

The design of a transmission line tower is distinctly classified into Mechanical design and Electrical design. Electrical clearance between live parts to metal parts is to be considered while designing the tower. For checking the clearance, swing angle of insulator (for suspension towers) and swing angle of jumper (for tension towers) is required, Sample electrical clearance diagram for suspension tower, tension tower and swing angle calculation as per the CEB Technical Specifications are attached as

Appendix-C

2.2.9 Basic Span

[University of Moratuwa, Sri Lanka.](#)
[Electronic Theses & Dissertations](#)
www.lib.mrt.ac.lk




Figure 2.2.9 : Basic Span

Basic span for a 132kV Transmission line is 300m.

2.2.10 Equivalent Span or Ruling span

Equivalent span calculates for a particular section. It considers all the spans in a section. This varies from section to section.





Figure 2.2.10: Equivalent Span or Ruling span

2.2.11 Wind Span

Wind span for a particular tower is half of a sum of adjacent spans. The wind force act on the tower due to conductor section represents by multiplying wind span by wind force act on the unit length of the conductor.



2.2.12 Weight Span

The weight span is the equivalent length of the weight of conductor supported at any one tower at minimum temperature in still air. At suspension positions the minimum weight of conductor, inclusive of weights where used.




Figure 2.2.12: Weight Span

$$Weight Span = \frac{s_1}{2} + \left(\frac{T_1}{w}\right) \left(\frac{h}{s_1}\right)$$

Where T_1 Tension of conductor at required temperature

w unit weight of the conductor

s_1 Span

h_1 Level deference between towers

2.3 Loading on Tower (Suspension Tower - TDL)

The following parameters were used to calculate the force acting on a transmission tower as per the CEB technical specifications and the conductor, Earthwire and insulator manufacturers specifications are attached as Appendix-D. Transmission Conductor and Tower are usually subject to the following external forces. Forces due to ice will not be considered for the lines in Sri Lanka.




Figure 2.3: Loading on Tower (Suspension Tower - TDL)

2.3.1 Transverse Load

The following factors produce the Transverse Load on a Tower.

- Component of mechanical tension of conductor , ground wire OPGW and insulator string
- Wind load on tower structure, conductor, ground wire / OPGW

2.3.2 Longitudinal Load

Unbalanced Horizontal loads in longitudinal direction due to mechanical tension of conductor and/or ground wire during Broken wire condition.

In the case of supports with suspension strings may be reduced value of maximum working tension of the conductor in broken wire condition as specified in CEB specification and this value is taken as a 30% reduction in maximum conductor tension.

For the ground wire broken condition, maximum working tension shall be considered for the purpose of design of a tower.

When there is a possibility of the tower being used with a longer span by reducing the angle of line deviation, the tower member needs to be checked for maximum longitudinal and transverse components arising out of the reduced angle of deviation.

2.3.3 Vertical Load

Loads due to weight of each conductor, ground wires based on appropriate weight span weight of insulator strings and hardware fittings.

A provision of 150 kg is made for the weight of a lineman with tools in addition to the vertical loads due to insulators and fittings and dead weight of the structure.

- Dead load of conductor = Unit weight of Conductor (kN/m) \times Weight Span (W1+W2)
- Dead load of Tower (Self Weight of Tower)




Figure 2.3.3: Vertical Load on a tower

Table 2.3.3: Weight Span of a 132kV Transmission tower according to CEB Specification

Basic Span (m)		300	
Wind Span (m)			
All Towers	Normal Working Condition	360	
	Broken wire condition	270	
Weight Span (m)		Maximum	Minimum
Suspension towers	Normal Working Condition	600	150
	Broken wire condition	450	112.5

2.4 Sag Tension Calculation

$$y(x) = \frac{H}{w} \cosh\left(\left(\frac{w}{H}x\right) - 1\right) = \frac{w(x^2)}{2H}$$




Figure 2.4 Catenary Curve for level spans

Sag Tension Calculation is carried out for both existing conductor (ACSR Zebra - 54/7/3.18) and the proposed conductor Low loss conductors.

Table 2.4.1: Properties of the Conductors and Earthwire

Properties of the Earthwire

Earthwire	GSW
Earthwire Size	7/3.25
Overall Diameter of the earthwire (D)	9.8 mm
Area of earthwire (for all strands) (A)	58.07 mm ²
Weight of the earthwire (w)	0.46 kg/m
Ultimate breaking strength	58.1 kN
Coefficient of linear expansion	0.0000115 per ° C
Modulus of elasticity (E)	193 kN/mm ²

Table 2.4.2 : Properties of the Conductors

Conductor	Existing (ACSR-ZEBRA)	Low Loss ACSR
Conductor Size	54/7/3.18	-
Overall Diameter of conductor	28.62 mm	28.62 mm
Area of conductor (for all strands) (A)	484.00 mm ²	590.5 mm ²
Weight of the conductor with grease (W)	1.6307 kg/m	1.814 kg/m
Ultimate breaking strength	130.32 kN	140.9 kN
Coefficient of linear expansion	0.0000193 per ° C	0.00002 per ° C
Modulus of elasticity (E)	69.00 kN/mm ²	71.00 kN/mm ²

Span (L)	Existing ACSR	Proposed Low Loss Conductor
300m	Zebra	
Temperature		
Minimum (T min)	15°C	15°C
Everyday (T)	32°C	32°C
Maximum (T max)	75°C	90°C
Wind Pressure (P)	970 N/m ²	970 N/m ²
Minimum factor of safety for Conductors and Earthwires based on Ultimate Strength		
At Maximum working tension	2.5	2.5
Everyday Temperature, still air	4.5	4.5

As per the technical specification the proposed low loss conductor can be operated up to 90°C.

The detailed sag tension calculation for the both existing Zebra conductors and proposed conductors are given in the Appendix C.



[University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

2.5 Tower Structure Design

1. Technical requirement of the Transmission Line

- | | | |
|------|-----------------|------------------------------|
| I. | Voltage | 132kV |
| II. | Circuit | Double Circuit |
| III. | Peak | One |
| IV. | Phase Conductor | Low Loss ACSR and ACSR Zebra |
| V. | Earthwire | OPGW (D=13.25mm) |

- | | |
|------------------|---|
| 2. Wind Pressure | 970N/m ² on Conductor and OPGW |
| | 1170 N/m ² on Insulator |

		1640 N/m ² on Tower Body (1.5 times the projected area of the members of one face of the tower)
3. Span	Normal Span	300m
	Wind Span	360m for Normal Condition (NC)
		270m for Broken wire Condition (BWC)
	Max. Weight Span	600m (NC) and 450m (BWC)
	Min. Weight Span	150m (NC) and 112.5m (BWC)
4. Conductor Temperature	Min. Temp	15°C
	Everyday Temp	32°C
	Max. Temp	75°C
5. Conductor Height (Ground Clearance)		Min height of the phase conductor = 6.7m + 0.3m (Survey error) + Max Sag of the conductor
6. Electrical Clearance	0° - 10°	1650mm
	10° - 40°	1550mm
7. Safety Factors		
Tower	Normal Condition	2.0
	Broken wire Condition	1.25
Conductor	Max Working Tension	2.5
	Everyday Temp	4.5

Note: Following Load Calculations are carried out as per the Transmission Line Structures By SS Murthy and AR Santhakumar

Normal Conduction (Min.Temp- Full Wind)

Normal Conduction		
	Max Wt	Min Wt
For Earth Wire(OPGW)		
Transverse Loads		
Win Load on Earthwire	Ne*De*Swnnnc*Pe*Sin(90)^2*F1	472
Due to Deviation	Ne*Te*Sin(θ2/2)^2*F1	0
	Total	472
		472
Vertical Loads		
Weight of Earthwire	Ne*We*Swtnc*F1	271
	Total	271
		68
Longitudinal Loads		
		0
For Conductor (ACSR/ZEBRA)		
Transverse Loads		
Wind Load on Conductor	Nc*Dc*Swnnnc*Pc*Sin(90)^2*F1	1020
Win Load on Insulator	0.5*Ni*Di*Pi*F1	31
Due to Deviation	Nc*Tc*Sin(θ2/2)^2*F1	0
	Total	1051
		1051
Vertical Loads		
Weight of Conductor	Nc*Wc*Swtnc*F1	979
Weight of Insulator	Ni*Wi*F1	70
	Total	1049
		315
Longitudinal Loads		
		0
		0



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

Broken Wire Conduction (Min.Temp- Full Wind)

Broken Wire Conduction		
	Max Wt	Min Wt
For Earth Wire(OPGW)		
Transverse Loads		
Win Load on Earthwire Due to Deviation	$Ne*De*Swnbwc*Pe*\sin(90)^2*F2$ $Ne*Te*\sin(\theta2/2)^2*F2$	354 0
	Total	354
	354	354
Vertical Loads		
Weight of Earthwire	$Ne*We*Swnbwc*F2$	203
	Total	203
	203	51
Longitudinal Loads		
	$Ne*Te*\cos(\theta1/2)F2$	2193
	Total	2193
	2193	2193
For Conductor (ACSR/ZEBRA)		
 Transverse Loads		
Win Load on Conductor Win Load on Insulator Due to Deviation	$Nc*Dc*Swnbwc*Pc*\sin(90)^2*F2$ $0.5*Ni*Di*Pi*F2$ $Nc*Tc*\sin(\theta2/2)^2*F2$	765 31 0
	Total	796
	796	796
Vertical Loads		
Weight of Conductor Weight of Insulator	$Nc*Wc*Swtbwc*F2$ $Ni*Wi*F2$	734 70
	Total	804
	804	253
Longitudinal Loads		
	$0.7*Nc*Tc*\cos(\theta1/2)F2$	3677
	Total	3677
	3677	3677

University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations

www.lib.mrt.ac.lk

Swnnnc

Standard Wind Span in Normal Conduction

Swtnc

Standard Weight in Normal Conduction

Swnbwc

Standard Wind Span in Broken Wire Conduction

2.6 Electrical Clearance Diagram of 132kV Transmission Tower

The Electrical Clearance Diagram of 132kV Transmission Tower is given in the Appendix – D.

2.7 Wind Load on Tower




Figure 2.7: Wind Load on Tower

Note: Wind pressure on tower = $1640 \text{ N/m}^2 = 167\text{kg}$

Table 2.7: Wind load on a TDL single peak tower


Description	Net Area (m ²)	Wind Pressure (kg/m ³)	Coefficient as per the Specification	Actual Wind (kg)	Distribution (kg)	Applied (kg)
A- B	1.353	167	1.5	339	170	175
					170+221	400
B- C	1.766	167	1.5	443		
					221+267	500
C- D	2.130	167	1.5	534		
					267+842	1135
D- E	6.712	167	1.5	1684		
					842+430	1300
E- F	3.434	167	1.5	861		
					430+861	1320
F- G	6.870	167	1.5	1723		
					862	880


University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
 Applied Load is calculated 2% higher than the actual distribution load (Additional safety factor to cover Name, Joint plate areas). Net area of the tower is calculated from the members used and the detail drawing with the member dimensions are attached as Appendix – E.


As per the load calculated above the loading trees were draw for the Normal and Broken wire Conditions. Total 18 different cases have been analyzed the detailed analyzed are as follows.

In order to ensure the additional safety Drag coefficient is not considered (or taken as 1).


2.8 Load Showing on Tree Diagram for Each Case





LOADING TREE




LOADING TREE



LOADING TREE



LOADING TREE




University of Moratuwa, Sri Lanka
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

3.0 SOFTWARE USED FOR STRUCTURAL ANALYSIS AND MODELING

PLS-TOWER is the modeling MS-WINDOWS based software developed by Power Line Systems for the analysis and design of transmission structures. All these programs have many features in common. It is now used by hundreds of organizations in over eighty countries and is probably the most widely used tower program in the world.

PLS-TOWER deals with the analysis and design of steel latticed towers.







Figure: 3.0 shows typical transmission towers configurations which can be modeled with PLS-TOWER.

3.1 Design Criteria

The design of tower based on varying conductor size under different atmospheric conditions, environmental impacts and possible abnormal conditions arising from accidental and natural failures was computed using PLS – TOWER software was obtained. The PLS – TOWER software is more user friendly for Transmission Tower designing compared with other software. The relevant usages of land and Steel materials were calculated and tabled with cost based on market values.

3.2 Modeling and Analysis in PLS – Tower (for TDL tower)

1. Step by step instruction and method for modeling and analysis of PLS – Tower are shown in Appendix F.
2. Analysis Results as shown in Appendix G for a TDL+9 tower.



Similarly, all types of towers (TD1, TD3, TD6 and TDT) were used in the 73km of Vavuniya Kilinochchi transmission Project analyzed for the new conductors (Low Loss conductor) and the result for each tower analysis have been tabulated in the Appendix H. According to my result minor changes to be done in the tower members to replace the low loss conductor.

3.3 Wind Span Vs Angle of Deviation

Angle of deviation is important for profile design which is used to determine the type of tower to be used for a particular span and the optimum design will depend on the Wind Span Vs Angle of Deviation of the tower.




Figure 3.3: Wind Span Vs Angle of Deviation

The transverse load imposed on a tower by one conductor

Where  T $H_1 = 2T \sin\left(\frac{\mu}{2}\right) + L W_c$
Tension of the conductor

L Wind Span

W_c Wind Load per unit length

μ Line Angle

For General Condition

Normal Wind Span $L_n = 360\text{m}$

Line Angle μ_n

by resolving the forces

$$2T \sin\left(\frac{\mu_n}{2}\right) + L_n W_c = 2T \sin\left(\frac{\mu}{2}\right) + L W_c$$

Wind load on conductor per meter run $W_c = 970 \times 28.62 \times 10^{-3} = 27.76\text{Nm}$

$$\text{Wind load on earth wire per meter run } W_e = 970 \times 9.8 \times 10^{-3} = 9.5 \text{ Nm}$$

Maximum allowable working tension of the conductor $T_c = 51,000 \text{ N}$

(As per the Sag Tension Calculation)

Maximum allowable working tension of the earth wire $T_e = 18,762 \text{ N}$

(As per the Sag Tension Calculation)

i. Suspension Towers

For Conductor

$$27.7614 \times L + 2 \times 51000 \times \sin(\mu/2) = 27.7614 \times 360 + 2 \times 51,000 \times \sin(0)$$

$$27.7614 L = 9994.1 - 102,000 \sin(\mu/2)$$

For Earthwire

$$9.5 \times L + 2 \times 18,762 \times \sin(\mu/2) = 9.506 \times 360 + 2 \times 18,762 \times \sin(0)$$

$$9.5 L = 3,422.16 - 37,524 \sin(\mu/2)$$

Table 3.3.1: Angle of Deviation of TDL tower

	Angle of Deviation (Degree)	University of Moratuwa, Sri Lanka.	
		Conductor	Earthwire
	0	360.0	360.0
	1	327.9	325.6
	2	295.9	291.1
	3	263.8	256.7
	4	231.8	222.2
	5	199.7	187.8
	6	167.7	153.4
	7	135.7	119.0
	8	103.7	84.6
	9	71.7	50.3
	10	39.8	16.0

ii. Angle Tower (TD1)

For Conductor

$$27.7614 \times L + 2 \times 51,000 \times \sin(\mu/2) = 27.7614 \times 360 + 2 \times 51,000 \times \sin(5)$$

$$27.7614 L = 18,883.1 - 102,000 \sin(\mu/2)$$

For Earthwire

$$9.5 \times L + 2 \times 18,762 \times \sin(\mu/2) = 9.506 \times 360 + 2 \times 18,762 \times \sin(5)$$

$$9.5 L = 6,692.59 - 37,524 \sin(\mu/2)$$

Table 3.3.2: Angle of Deviation of TD1 tower

Angle of Deviation (degree)	Wind Span (m)	
	Conductor	Earthwire
0	680.2	704.0
1	648.2	669.6
2	616.1	635.1
3	584.0	600.7
4	552.0	566.3
5	520.0	531.9
6	487.9	497.4
7	455.9	463.1
8	423.9	428.7
9	392.0	394.3
10	360.0	360.0
11	328.1	325.7
12	296.2	291.4
13	264.3	257.2
14	232.5	223.0
15	200.6	188.8

Similarly Angle of Deviation for the other towers such as TD3, TD6 and TDT were calculated and the values are shown in the Appendix I.

3.4 Creep Calculation (Temperature Shift Calculation)

Creep in a conductor is defined as permanent set in the conductor. It is a continuous process and takes place throughout its life. The rate of creep is higher initially but decreases with time. Creep compensation is provided for by over tensioning of the conductor in the form of temperature correction.

Creep strain leads to increase in length and in turn the sag of an overhead line conductor with passage of time. The effect of intermittent high temperature operation of transmission lines accelerates creep strain.

For this calculation the assessment method in [9] was used.

$$e = K \frac{(Tx100)^B}{T_{ult}} O^\emptyset t^y \quad \dots \dots \dots \text{Eq (4)}$$

e = Creep strain mm/km

T = Tension in conductor at 32 °C (kg)

University of Moratuwa, Sri Lanka.
Ultimate Tensile Strength of Conductor (kg)

[Electronic Theses](#)
[www.Grubis-Contact.de](#)

B Ø_v = Creep Indices

Ω = Conductor Temperature °C

t = Duration in Hrs

Where

From Table 2

$$K = 1.4$$

$$B = 1.3$$

$$\emptyset = 0$$

$$y = 0.16$$

Conversion of Tension to temperature differences is calculated from the equation of sag calculations.

$$\frac{W^2 ES^2}{24T_2^2} - \frac{T_2}{A} = \frac{W^2 ES^2}{24T_1^2} - \frac{T_1}{A} + \alpha Et \quad \dots \dots \dots \text{Eq (8)}$$

W	=	Unit weight of conductor (kg/m)
S	=	Span Length (m)
E	=	Young's Modulus of conductor (kg/cm ²)
T_1	=	Final Tension of Conductor (kg)
T_2	=	Initial Tension of Conductor (kg)
A	=	Cross sectional Area of Conductor (cm ²)
α	=	Co-efficient of Linear Expansion of Conductor (per °C)
t	=	Temperature Difference (°C)

Where


University of Moratuwa, Sri Lanka.
 Electronic Theses & Dissertations
aETD@UM
www.lib.mrt.ac.lk

Table 3.4.1: Creep Calculation

Span (m)	T1 Tension at 32 °C (kg) (at UTS/2.5)	T(ult) Ultimate Tension(kg)	T1 *100/T(ult) (%)
200	2950.89		22.21
300	2948.87	13288.94	22.19
400	2803.77		21.10
500	2731.11		20.55

As the result of the calculation above table indicates that the percentage of everyday tension - (T1) to ultimate tension-T(ult) does not vary with the length of equivalent span. The percentage of creep can be calculated from the Equation (4) of *Transmission*

Line Structures by S. Murthy and AR Santhakumar [7] and values are tabulated as follows.

Table 3.4.2: Creep Calculation

Span(m)	T x 100 T _{ult}	e mm/km for 10 years (87600hrs)	e mm/km for 24 hrs	Balance Creep e _{10Y} - e _{24H} mm/km
200	22.21	486.9	131.1	355.8
300	22.19	486.3	130.9	355.4
400	21.10	455.5	122.6	332.9
500	20.55	440.1	118.5	321.6

Average value of balance creep = 341.4mm/km = 0.034%

Therefore, Percentage of creep at everyday temperature is 0.034% for Zebra-ACSR conductor.

In order to allow the above balance creep of 341.4mm to happen in 87576 hr the conductor tension to be increased than the final tension of the conductor at everyday temperature.



University of Moratuwa, Sri Lanka

Electronic Theses & Dissertations

www.lib.mrt.ac.lk

Difference in tension is given by

$$\Delta T = \frac{12CT_1^3}{W^2S^2}$$

Where W Unit weight of conductor (kg/m)

 S Equivalent Span (m)

 C Percentage Creep

 T₁ Final Tension of Conductor at 32°C (Daily operating Temperature)

Accordingly tension to be applied as the initial tension calculated by

$$T_2 = T_1 + \Delta T$$

The above increased initial tension T_2 will be maintained at the site condition above initial tension to be calculated using the Equation (4) of Transmission Line Structures by S. Murthy and AR Santhakumar [7].

$$\frac{W^2 ES^2}{24T_2^2} - \frac{T_2}{A} = \frac{W^2 ES^2}{24T_1^2} - \frac{T_1}{A} + aET$$

$$t = \frac{\frac{W^2 EAS^2}{24} \left(\frac{1}{T_2^2} - \frac{1}{T_1^2} \right) - (T_2 - T_1)}{aEA}$$

$$\frac{W^2 EAS^2}{24} = 377320.7S^2$$

Table 3.4.3 : Creep Calculation Result

Span (m)	Final Tension at 32°C T_1 (kg)	Tension Increase for 0.034% creep ΔT (kg)	Initial Tension at 32°C $T_1 + \Delta T$	Tempera. Difference t ($^\circ\text{C}$)
200	2950.89	985.62	3936.51	-26.55
300	2948.87	437.16	3386.03	-21.00
400	2803.77	211.36	3015.13	-19.02
500	2731.11	125.02	2856.13	-18.38

Therefore, the average Temperature difference is -22°C

Accordingly the temperature difference, for 10 years creep for Zebra conductor is (-) 22°C .

4.0 PROFILE DESIGN


4.1 Clearances to Ground, objects under the line and at crossings

As per the CEB specification the line clearances to the ground, objects are described as follows,

Table 4.1: Line Clearances as per the CEB specification.


132 kV LINE CLEARANCES

		132 kV
Minimum Clearance from Conductor: To Ground	m	6.7
Metal Clad or Roofed Buildings, or other Buildings or Structures upon which a man may stand	m	4.1
To earthed cradle Guard Wires	m	4
To Electric power Line Wires (Line to Earth)		3.7
To be added to the above Clearance to Allow for Survey and sagging error	m	0.3
Minimum horizontal spacing between outermost conductor of adjacent power line in still air	m	15.3
Spacing between P + T Line and cradle guard	m	1.8



4.2 PLS-CADD Software

PLS-CADD is an overhead power line design program which is easy to design graphical user interface. It integrates all aspects of line design into a single stand-alone program with a simple, logical, consistent interface also used to design the plane, profile, route selection process.





PLS-CADD software is used to design the profile. The detail profile design of a section of Vavuniya Kilinochchi Transmission Line is attached as Appendix J. For this Design actual survey data is important therefore I obtained the survey data from our office. Those data's loaded in to PLS CADD software then the profile design was carried out for this design the above calculations such as Creep, Sag Tension, conductor data and earth wire technical data.



University of Moratuwa, Sri Lanka
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

5.0 COST and TIME IMPACTS OF A NEW TRANSMISSION LINE CONSTRUCTION

The detailed cost and time structure for construction of a new transmission line is mentioned below. This average data is taken from several CEB projects for a construction of around 60km length double circuit transmission line.



Conclusion

The study of tower and profile design for different conductor was analysed with the help of PLS tower and PLS -CADD software and different cases based on the tower types were analysed to obtain the optimum use of the existing transmission line and maximum cost and the time benefit.

As the objective of the study was to obtain an optimum electrical and mechanical of equilibrium between the cost and the current rating of the existing transmission line with varying the different conductor. This computed with varying cost of a new transmission line project including the prices of steel, different cost of land depending on location and environmental impacts.

Further, the study also based on the temperature rise of the conductor and the proposed new low loss conductor can be operated up to 90°C which is more suitable for countries like Sri Lanka.



[University of Moratuwa, Sri Lanka.](#)

[Electronic Theses & Dissertations](#)

www.lib.mrt.ac.lk


This study conform that any transmission line designed based on the CEB specifications using the ACSR Zebra can be replaced by a Low loss, high rating conductor. The detailed analyses of Tower and Profile shows that modifications are required for some towers.

Therefore, it is recommended to select the low loss conductor within the economical range of sizes given above to reap maximum financial benefit. Apart from the financial benefit the important aspect of the above recommendation is to be highlighted here as a non-cash benefit where an immense gain is realized in terms of environmental impact. Similarly, the new design of towers and profile could be analysed for different parameters, shapes, sizes and configuration in order to ascertain benefits over cost and environmental advantages through further studies.

Reference List





- [1] Prasad Rao, N. Samuel Knight, G.M. Mohan, S.J. and Lakshmanan, N. (2012) Studies on failure of transmission line towers in testing. Journal of Engineering Structures. Vol. 35 & Vol.25
- [2] Abdullah Fakhir Mohammed, Mustafa özakca and Nildemtaysi. (2012) Optimal design of transmission Towers using genetic algorithm. Journal of Constructional Technologies.Vol. 4, No 2, pp. 115-123.
- [3] R. Thrash, A. Murrah, M. Lancaster, and K. Nuckles, "Overhead conductor manual," 2nd ed: Southwire, 2007.
- [4] ASCE 52. 1971. Guide for Design of Steel Transmission Towers. American Society of Civil Engineers. 1971. [5] BS EN 60071-1: Insulation co-ordination - Definitions, principles and rules," British Standards, 2006
- [6] IEEE Guide for Determining the effects of high-temperature operation on conductors, connectors, and accessories," IEEE Std. 1283-2004, pp.1-28,
2005
 University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
- [7] Murthy, S.S. www.mut.ac.lk., 1990. Transmission Line Structures. McGraw-Hill Book Co. Singapore, pp. 179-180.
- [8] Ceylon Electricity Board. Transmission Development Plan 2011-2021
- [9] Bradbury,J.,Dey,p., Orawski, G.Pickup, KH, Long-Term Creep assessment for overhead –line conductors.
- [10] Abdullah Fakhir Mohammed, Mustafa özakca and Nildemtaysi. (2012) Optimal design of transmission Towers using genetic algorithm. Journal of Constructional Technologies.Vol. 4, No 2, pp. 115-123

Appendix A Existing 132kV Tower Details



Appendix B

Specification Comparison of Conductors

		Adoption in this project		Reference		
Description		Unit	Low Loss TACSR/AS 550mm ²	Low Loss ACSR/AS 550mm ²	TACSR/AS "Zebra"	ACSR "Zebra"
Nominal Diameter (*)		-	28.62	28.62	28.62	28.62
Cross Sectional Area (*)	AL	mm ²	550.4	550.4	428.9	428.9
	Core		40.08	40.08	55.59	55.59
	Total		590.5	590.5	484.5	484.5
Nominal Weight (*)		kg/km	1,814	1,814	1,555	1,621
Ultimate Tensile Strength (*)		kN	140.9	140.9	130.4	131.9
DC Resistant at 20°C (*)		Ω /km	0.0526	0.0519	0.0657	0.0674
Max. Allowable Temperature		°C	150	150	150	90
Current(A)	66.15°C	66.15°C	757	762	-	-
	75°C	75°C	-	875	767	757
	90°C	90°C	-	1,077	-	930
	136.1°C	136.1°C	1,514	N/A	-	N/A
	150°C	150°C	1,622	N/A	1,423	N/A
Cross Section		-				


Note : Specific values (marked:(*)) for above conductors are calculated in accordance with IEC 61089-1991 for ACSR "Zebra"

& TACSR/AS "Zebra" and in accordance with IEC 62219-2002 for Low Loss ACSR/AS 550mm² & Low Loss TACSR/AS 550mm².


Comparison of conductor specifications

For the Zebra conductors

Option	Conductor Type	Diameter (mm)	Cross section Area (mm ²)	Weight (kg/km)	Calculated DC Resistance @ 20°C Ohms/km	Current Rating (A)
Zebra	ACSR	28.62	428	1621	0.0674	760
Rubus	AAAC	31.50	500	1620	0.0566	940
Camel	ACSR	30.18	475	1797	0.0611	820
Option 1	TACSR/AS	28.62	428	1555	0.0657	1420
Option 2	Low Loss TACSR	28.62	550	1814	0.0519	1070



Zebra



Option 1






Option 2

Comparison of conductor specifications

For the Lynx conductor

Option	Conductor Type	Diameter (mm)	Cross section Area (mm ²)	Weight (kg/km)	Calculated DC Resistance @ 20°C Ohms/km	Current Rating (A)
Lynx	ACSR	19.55	183	865	0.1576	450
Panther	ACSR	21	200	1001	0.1362	490
Option 1	GTACSR 	19.2	210	851	0.140	875
Option 2	GZTACSR	18.5	195	803	0.150	920



Appendix C

Sag Tension Calculation

Wind force on conductor per meter run,

$$\begin{aligned} p &= 970 \times 28.62 \times 10^{-3} && \text{N/m} \\ &= 27.7614 && \text{N/m} \end{aligned}$$

$$\text{Wind force on conductor} = 27.7614 \text{ N/m} \quad \mathbf{27.76 \text{ N/m}}$$

Loading factor at 15 °C

$$\text{With wind, } Q_1 = \frac{(p^2 + w^2)^{1/2}}{w}$$

Where, p - wind force on conductor per meter run
w - Weight of the conductor per meter

$$Q_1 = \frac{\{(27.7614/9.80665)^2 + 1.631\}^{1/2}}{1.631}$$

$$Q_1 = 2.0031 \quad \mathbf{2.00}$$



$$Q_2 = 1.0 \quad \mathbf{1.00}$$

Maximum allowable working tension of the conductor

Maximum working tension of ZEBRA conductor = UTS / 2.5

$$= 52760 \text{ N}$$

(Note : UTS of Insulator = 160kN, Maximum WT = 160/3 = 53.3 kN > 51.000 kN)

However in order to satisfy the design condition at 32°C , UTS/4.5
the maximum allowable working tension is assumed as = 51000 N

Maximum allowable working stress of the conductor

$$f_1 = \frac{51000}{484.5} \text{ N/mm}^2$$

$$= 105.2632 \text{ N/mm}^2 \quad \mathbf{105.26 \text{ N/mm}^2}$$

Weight of conductor with grease/m/mm²

$$\frac{\$}{f_1^2} = \frac{1.631 \times 9.80665}{484.5} \text{ N/mm}^2$$

$$\frac{\$}{f_1^2} = \frac{0.033013 \text{ N/mm}^2}{24} \text{ N/mm}^2$$

Then the working stress f_2 can be determined by the following formula

$$\frac{f_2^2 [f_1 - (f_1 - a^2 \$^2 Q_1^2 E - \alpha t E)]}{24 f_1^2} = \frac{a^2 \$^2 Q_2^2 E}{24}$$

Where	$a =$	Conductor span in meters
	$E =$	Modulus of elasticity in N/mm ²
	$\alpha =$	Coefficient of linear expansion in per °C
	$t =$	Temperature difference ($t_{req} - t_{min}$)

Then the Sag can be determined by the following formula;

$$\text{Sag} = \frac{a^2 \$ Q_2}{8 f_2}$$

Co-ordinates of the curves can be determined by the following formula;

$$\text{Sag}_{req \text{ at } 15^\circ\text{C}} = \frac{\text{Equivalent Span Sag at } 15^\circ\text{C}}{\text{Equivalent Span}} \times (\text{Required Span})^2$$

University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

SAG at 15°C with wind load

Initial Tension	=	51000 N	
Sag	=	$\frac{w \times \text{span}^2 \times Q_1}{8 \times T}$	w - unit wt of conductor N/m
			T - Initial Tension N
Sag	=	$\frac{1.631 \times 9.80665 \times 300^{2 \times 2.0031}}{8 \times 51000}$	
	=	7.06754 m	7.07 m

SAG at 15°C without wind load

For Equivalent span (m) = 300

$$\frac{f_2^2 [f_1 - (f_1 - a^2 \$^2 Q_1^2 E - \alpha t E)]}{24 f_1^2} = \frac{a^2 \$^2 Q_2^2 E}{24}$$

$$t = (15 - 15)^\circ\text{C}$$

$$\frac{(f_1 - a^2 \$^2 Q_1^2 E - \alpha t E)}{24 f_1^2} = \frac{105.2632 - \{300^2 \times 0.033013^2 \times 2.0031^2 \times 69 \times 10^3\}}{24 \times 105.2632^2}$$

$$- 0.0000193 \times 0 \times 69 \times 10^3$$

$$\begin{aligned} &= 105.2632 - 102.1196 \\ &= 3.1436 \end{aligned}$$

$$\begin{aligned} \frac{a^2 \cdot S^2 \cdot Q_2^2 \cdot E}{24} &= \frac{300^2 \times 0.033013^2 \times 1^2 \times 69 \times 10^3}{24} \\ &= 281995.429 \end{aligned}$$

Therefore the equation,

$$f_2^3 - 3.1436 f_2^2 = 281995.4292$$

Solving by Newton Raphsan methods

	$f_2 = \{281995.4292 + 3.1436 f_2^2\}^{1/3}$
Starting	$f_2 = 66.7$
	$f_2 = 66.64299$
	$f_2 = 66.64120$
	$f_2 = 66.64114$
Then	$T = \frac{32287.632}{66.64114 \times 484.5} N$
	$T = 32287.632 N$
Sag =	$\frac{300^2 \times 0.033013 \times 1}{8 \times 66.64114} m$
	$5.5730 m$
	$5.57 m$

SAG at 32°C without wind load

For Equivalent span (m) = 300

$$\frac{f_2^2 [f_1 - (f_1 - \frac{a^2 \cdot S^2 \cdot Q_1^2 \cdot E}{24}) - \alpha t E]}{24 f_1^2} = \frac{a^2 \cdot S^2 \cdot Q_2^2 \cdot E}{24}$$

$$t = (32 - 15) ^\circ C$$

$$17 ^\circ C$$

$$\frac{(f_1 - a^2 \cdot S^2 \cdot Q_1^2 \cdot E - \alpha t E)}{24 f_1^2} = \frac{105.2632 - \{300^2 \times 0.033013^2 \times 2.0031^2 \times 69 \times 10^3\}}{24 \times 105.2632^2}$$

$$-0.0000193 * 17 * 69 * 10^3$$

$$= \quad 105.2632 - 102.1196 \quad -22.6389 \\ = \quad -19.4953$$

$$\begin{aligned} a^2 \frac{\$^2 Q_2^2 E}{24} &= \frac{300^2 \times 0.033013^2 \times 1^2 \times 69 \times 10^3}{24} \\ &= 281995.429 \end{aligned}$$

Therefore the equation,

$$f_2^3 + 19.4953f_2^2 = 281995.4292$$

Solving by Newton Raphsan methods

$$f_2 = \{281995.4292 - 19.4953f_2^2\}^{1/3}$$

Starting

$$\begin{aligned} f_2 &= 59.679000 \\ f_2 &= 59.679881 \\ f_2 &= 59.679689 \\ f_2 &= 59.679731 \\ f_2 &= 59.679722 \\ f_2 &= 59.679724 \\ f_2 &= 59.679724 \\ f_2 &= 59.679724 \end{aligned}$$

$$\text{Then } T = 59.679724 \times 484.5 \quad N$$

$$= 28914.826 \quad \text{University of Moratuwa, Sri Lanka.} \quad 28914.83 \text{ N}$$

Note : at 32°C Tension should be less than 45% of Sag

$$\begin{aligned} \text{Sag} &= \frac{300^2 \times 0.033013 \times 1}{8 \times 59.679724} \\ &= 6.2231 \text{ m} \quad \text{Ok} \end{aligned}$$

SAG at 75°C without wind load

For Equivalent span (m) = 300

$$\frac{f_2^2 [f_1 - (f_1 - a^2 \$^2 Q_1^2 E - \alpha t E)]}{24f_1^2} = \frac{a^2 \$^2 Q_2^2 E}{24}$$

$$t = (75 - 15)^\circ C$$

$$60^\circ C$$

$$\begin{aligned} \frac{(f_1 - a^2 \$^2 Q_1^2 E - \alpha t E)}{24f_1^2} &= \frac{105.2632 - \{300^2 \times 0.033013^2 \times 2.0031^2 \times 69 \times 10^3\}}{24 \times 105.2632^2} \\ &\quad - 0.0000193 \times 60 \times 69 \times 10^3 \end{aligned}$$

$$\begin{aligned} &= 105.2632 - 102.120 \quad -79.902 \\ &= -76.7584 \end{aligned}$$

$$a^2 \$^2 Q_2^2 E = \frac{300^2 \times 0.033013^2 \times 1^2 \times 69 \times 10^3}{24}$$

$$24 = \frac{24}{281995.429}$$

Therefore the equation,

$$f_2^3 + 76.7584 f_2^2 = 281995.4292$$

Solving by Newton Raphson methods

Starting	$f_2 = \sqrt[3]{281995.4292 - 76.7584f_2^2}$
	$f_2 = 47.616234$
	$f_2 = 47.6162340$

Then	$T = 47.6162340 \times 484.5$	N
	23070.065	N
		23070.07 N

$$\text{Sag} = \frac{300^2 \times 0.03303 \times 1}{8 \times 47.6162340}$$



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

7.80 m

Sag Tension Calculation of Proposed Low Loss Conductor

Wind force on conductor per meter run,

$$\begin{aligned} p &= 970 \times 28.62 \times 10^{-3} && \text{N/m} \\ &= 27.7614 && \text{N/m} \end{aligned}$$

$$\text{Wind force on conductor} = 27.7614 \text{ N/m} \quad \mathbf{27.76 \text{ N/m}}$$

Loading factor at 15 ° C

$$\text{With wind, } Q_1 = \frac{(p^2 + w^2)^{1/2}}{w}$$

Where, p - wind force on conductor per meter run

w - Weight of the conductor per meter

$$Q_1 = \frac{\{(27.7614/9.80665)^2 + 1.631\}^{1/2}}{1.814}$$

$$Q_1 = 1.8535 \quad \mathbf{1.85}$$

Loading factor at given temperature without wind,



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

$$Q_2 = 1.0 \quad \mathbf{1.00}$$

Maximum allowable working tension of the conductor

Maximum working tension of Proposed Low Loss conductor = UTS / 2.5

$$= 56360 \text{ N}$$

(Note : UTS of Insulator = 160kN, Maximum WT = 160/3 = 53.3 kN > 51.000 kN)

However in order to satisfy the design condition at 32°C , UTS/4.5
the maximum allowable working tension is assumed as = 51000 N

Maximum allowable working stress of the conductor

$$f_i = \frac{51000}{484.5} \text{ N/mm}^2$$

$$= 105.2632 \text{ N/mm}^2 \quad \mathbf{105.26 \text{ N/mm}^2}$$

Weight of conductor with grease/m/mm²

$$\frac{\$}{\$} = \frac{1.631 \times 9.80665}{484.5} \text{ N/m/mm}^2$$

$$\frac{\$}{24f_1^2} = \frac{0.036717 \text{ N/mm}^2}{0.04 \text{ N/mm}^2}$$

Then the working stress f_2 can be determined by the following formula

$$\frac{f_2^2[f_1 - (a^2 \$ Q_1^2 E - \alpha t E)]}{24f_1^2} = \frac{a^2 \$ Q_2^2 E}{24}$$

Where	$a =$	Conductor span in meters
	$E =$	Modulus of elasticity in N/mm^2
	$\alpha =$	Coefficient of linear expansion in per $^\circ\text{C}$
	$t =$	Temperature difference $(t_{\text{req}} - t_{\text{min}})$

Then the Sag can be determined by the following formular ;

$$\text{Sag} = \frac{a^2 \$ Q_2}{8f_2}$$

Co-ordinates of the curves can be determined by the following formular

$$\text{Sag}_{\text{req at } 15^\circ\text{C}} = \frac{\text{Equivalent Span Sag at } 15^\circ\text{C}}{(\text{Equivalent Span})^2} \times (\text{Required Span})^2$$

SAG at 15°C with wind load



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

Initial Tension = 51000 N

$$\begin{aligned} \text{Sag} &= \frac{w \times \text{span}^2 \times Q_1}{8 \times T} & w - \text{unit wt of conductor} & \text{N/m} \\ && T - \text{Initial Tension} & \text{N} \\ \text{Sag} &= \frac{1.631 \times 9.80665 \times 300^{2 \times 2.0031}}{8 \times 51000} \\ &= 7.27325 \text{ m} & & 7.27 \text{ m} \end{aligned}$$

SAG at 15°C without wind load

For Equivalent span (m) = 300

$$\frac{f_2^2[f_1 - (a^2 \$ Q_1^2 E - \alpha t E)]}{24f_1^2} = \frac{a^2 \$ Q_2^2 E}{24}$$

$$t = (15 - 15) {}^\circ\text{C}$$

$$\begin{aligned} (f_1 - a^2 \$ Q_1^2 E - \alpha t E) &= 105.2632 - \frac{\{300^2 \times 0.033013^2 \times 2.0031^2 \times 69 \times 10^3\}}{24 \times 105.2632^2} \\ &\quad - 0.0000193 \times 0 \times 69 \times 10^3 \end{aligned}$$

$$= \quad 105.2632 - 111.2859 \\ = \quad -6.0227$$

$$\frac{a^2 \cdot S^2 \cdot Q_2^2 \cdot E}{24} = \frac{300^2 \times 0.033013^2 \times 1^2 \times 69 \times 10^3}{24} \\ = \quad 358936.786$$

Therefore the equation,

$$f_2^3 - 3.1436 f_2^2 = 281995.4292$$

Solving by Newton Raphsan methods

	$f_2 = \{281995.4292 + 3.1436 f_2^2\}^{1/3}$
Starting	$f_2 = 66.7$
	$f_2 = 69.25346$
	$f_2 = 69.10784$
	$f_2 = 69.11630$
	$f_2 = 69.11581$
	$f_2 = 69.11584$
	$f_2 = 69.11584$
	$f_2 = 69.11584$
	$f_2 = 69.11584 \text{ N/mm}^2$

Then $T = \frac{69.11584 \times 484.5}{33486.624} \text{ N}$

 University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

$\text{Sag} = \frac{300^2 \times 0.033013 \times 1}{8 \times 66.64114} \text{ m}$

$$33486.62 \text{ N}$$

$$5.9764 \text{ m}$$

$$5.98 \text{ m}$$

SAG at 32°C without wind load

For Equivalent span (m) = 300

$$\frac{f_2^2 [f_1 - (f_1 - \frac{a^2 \cdot S^2 \cdot Q_1^2 \cdot E}{24} - \alpha t E)]}{24 f_1^2} = \frac{a^2 \cdot S^2 \cdot Q_2^2 \cdot E}{24}$$

$$t = (32 - 15)^\circ \text{C}$$

$$17^\circ \text{C}$$

$$\frac{(f_1 - a^2 \cdot S^2 \cdot Q_1^2 \cdot E - \alpha t E)}{24 f_1^2} = \frac{105.2632 - \{300^2 \times 0.033013^2 \times 2.0031^2 \times 69 \times 10^3\}}{24 \times 105.2632^2} \\ = -0.0000193 * 17 * 69 * 10^3$$

$$= 105.2632 - 111.2859 - 24.14 \\ = -30.1627$$

$$\frac{a^2 \cdot \frac{Q_2^2}{2} \cdot E}{24} = \frac{300^2 \times 0.033013^2 \times 1^2 \times 69 \times 10^3}{24}$$

$$= 358936.786$$

Therefore the equation,

$$f_2^3 + 19.4953f_2^2 = 281995.4292$$

Solving by Newton Raphson methods

$$f_2 = \{281995.4292 - 19.4953f_2^2\}^{1/3}$$

Starting

$$\begin{aligned} f_2 &= 59.679000 \\ f_2 &= 63.122612 \\ f_2 &= 62.036966 \\ f_2 &= 62.389931 \\ f_2 &= 62.276284 \\ f_2 &= 62.312992 \\ f_2 &= 62.301148 \\ f_2 &= 62.304971 \end{aligned}$$

$$\begin{aligned} \text{Then } T &= 62.304971 \times 484.5 & N \\ &= 30186.758 & N & \mathbf{30186.76 N} \end{aligned}$$

Note : at 32°C Tension should be less UTS/4.5 =

 **University of Moratuwa, Sri Lanka.**
31311.1.N
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

Ok

6.63 m

SAG at 75°C without wind load

For Equivalent span (m) = 300

$$\frac{f_2^2 [f_1 - (f_1 - \frac{a^2 \cdot \frac{Q_1^2}{2} \cdot E}{24}) - \alpha t E]}{24f_1^2} = \frac{a^2 \cdot \frac{Q_2^2}{2} \cdot E}{24}$$

$$t = (75 - 15)^\circ C$$

$$60^\circ C$$

$$\begin{aligned} (f_1 - \frac{a^2 \cdot \frac{Q_1^2}{2} \cdot E}{24f_1^2} - \alpha t E) &= \frac{105.2632 - \{300^2 \times 0.033013^2 \times 2.0031^2 \times 69 \times 10^3\}}{24 \times 105.2632^2} \\ &\quad - 0.0000193 \times 60 \times 69 \times 10^3 \end{aligned}$$

$$\begin{aligned} &= 105.2632 - 111.286 & -85.2 \\ &= -91.2227 \end{aligned}$$

$$\begin{aligned} \frac{a^2 \cdot \frac{Q_2^2}{2} \cdot E}{24} &= \frac{300^2 \times 0.033013^2 \times 1^2 \times 69 \times 10^3}{24} \\ &= 358936.786 \end{aligned}$$

Therefore the equation,

$$f_2^3 + 76.7584 f_2^2 = 281995.4292$$

Solving by Newton Raphsan methods

$$\begin{array}{ll} f_2 = & \{281995.4292 - 76.7584f_2^2\}^{1/3} \\ \text{Starting } f_2 = & 47.616234 \\ f_2 = & 52.4523327 \\ f_2 = & 48.5055184 \\ f_2 = & 51.8043689 \\ f_2 = & 49.0987901 \\ f_2 = & 51.3539141 \\ f_2 = & 49.4985096 \\ f_2 = & 51.0419075 \\ \mathbf{f_2 =} & \mathbf{49.7694532} \end{array}$$

Then $T = 49.7694532 \times 484.5 \quad N$
 $24113.300 \quad N \quad \mathbf{24113.30 \quad N}$


$$\text{Sag} = \frac{300^2 \times 0.03303 \times 1}{8 \times 47.6162340}$$




8.2995 m
University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

8.30 m

Appendix D



Appendix E





Appendix F

Modeling & Analysis in PLS - Tower


Step by Step instruction and method for modeling and analysis of PLS – Tower

Open New Job



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

1. General Data (General>General Data)



2. Steel Material Properties (Component>Steel Material)

lower - [tias_o.zmj]

File Edit View General Components Geometry Loads Model Window Help

Steel Material Properties (From file "f:\kctp-cebl\lot - b\kec\tower design\tdl\9versin\tdls9.smp")

A146: PROJECT
MILD STEEL-BSEN:10025-S275JR
HIGH TENSILE STEEL-BSEN:10025-S255JR

Steel Material Label	Modulus of Elasticity (MPa)	Yield Stress Fy (MPa)	Member All. Stress Hyp. 1 (MPa)	Member All. Stress Hyp. 2 (MPa)	Member Rupture Hyp. 1 (MPa)	Member Rupture Hyp. 2 (MPa)	Member Bearing Hyp. 1 (MPa)
1 MS	199948	275	410 0	0	0	0	0
2 HT	199948	355	510 0	0	0	0	0
3							
4							
5							

University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

3. Define of Angle Properties (Component> Angle.....)

Angle Properties (From file "f:\kctp-ceb\lot - kec\tower design\tdl\9versin\tdls\tdls9.ang")

?



University of Moratuwa, Sri Lanka
Electronic Theses & Dissertations

	Angle Type	Angle Size	Long Leg (cm)	Short Leg (cm)	Thick. (cm)	Unit Weight (N/m)	Gross Area (cm^2)	w/t Ratio	Radius of Gyration Rz (cm)	Radius of Gyration Ry (cm)	Number of Angles	Wind Width (cm)	Short Edge Dist. (cm)	Long Edge Dist. (cm)	Optimize Cost Factor	Section Modulus (cm^3)
1	SAE	DUMMY	4.5	3	0.03	0.1	0.1	12	1.42	0.42	0.63	1	0	1	1	0.7
2	SAE	45*45*5	4.5	4.5	0.5	33.4	4.2763	6.9	1.36	0.36	0.88	1	4.5	2.25	1	2.5
3	SAE	50*50*5	5	5	0.5	37.3	4.7887	7.8	1.52	0.52	0.98	1	5	2.5	1	3.1
4	SAE	50*50*6	5	5	0.6	44.2	5.6787	6.34	1.51	0.51	0.97	1	5	2.5	1	3.7
5	SAE	55*55*5	5.5	5.5	0.5	41.2	5.272	8.7	1.67	1.67	1.07	1	5.5	2.75	1	3.7
6	SAE	60*60*5	6	6	0.5	45.2	5.7538	9.7	1.83	0.83	1.17	1	6	3	1	4.4
7	SAE	60*60*6	6	6	0.6	53	6.8438	7.92	1.82	1.82	1.17	1	6	3	1	5.3
8	SAE	75*75*6	7.5	7.5	0.6	66.7	8.6583	10.34	2.3	2.3	1.47	1	7.5	3.75	1	8.4
9	SAE	90*90*7	9	9	0.7	94.2	12.1353	10.65	2.76	2.76	1.76	1	9	4.5	4.5	14.1
10	SAE	100*100*7	10	10	0.7	105	13.5353	12.08	3.08	3.08	1.97	1	10	5	1	17.7
11	SAE	100*100*8	10	10	0.8	118.7	15.3853	10.44	3.07	3.07	1.96	1	10	5	1	20.1
12	SAE	90*90*6	9	9	0.6	81.4	10.47	12.59	2.77	2.77	1.77	1	9	4.5	4.5	12.2
13	SAE	120*120*10	12	12	1	178.5	23.06	10	3.69	3.69	2.36	1	12	6	1	36.2
14	SAE	110*110*10	10	10	1	162.8	21.06	9	3.37	3.37	2.15	1	11	5.5	1	30.1
15	SAE	80*80*6	8	8	0.6	71.6	9.29	11	2.46	2.46	1.57	1	8	4	1	9.7
16	SAE	70*70*5	7	7	0.5	53	6.77	11.6	2.15	2.15	1.37	1	7	3.5	1	6.1
17	SAE	65*65*5	6.5	6.5	0.5	49.1	6.25	10.7	1.99	1.99	1.27	1	6.5	3.25	1	5.2

Save Save As Merge Report Cancel

<

Row 7 SAE '60*60*6: Number of angles making up a section: 1 for single or round, 2 for double angles, 4 for composite sections with 4 angles


Type 14:22
10/11/2

4. Define the Bolt Properties (Component>Bolt.....)



University of Moratuwa, Sri Lanka
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

5. Define Joints Geometry (Geometry>Primary Joint)



6. Define Joints Geometry (Geometry>Secondary Joint)

Secondary Joints												
	Joint Label	Symmetry Code	Origin Joint	End Joint	Fraction	Elevation	X Disp. Rest.	Y Disp. Rest.	Z Disp. Rest.	X Rot. Rest.	Y Rot. Rest.	Z Rot. Rest.
1	B1	XY-Symmetry	AP	BP	0	4.2325	Free	Free	Free	Free	Free	
2	B2	XY-Symmetry	AP	BP	0	7.633	Free	Free	Free	Free	Free	
3	B3	XY-Symmetry	AP	BP	0	10.385	Free	Free	Free	Free	Free	
4	B4	XY-Symmetry	AP	BP	0	12.325	Free	Free	Free	Free	Free	
5	C1	XY-Symmetry	BP	CP	0	15.333	Free	Free	Free	Free	Free	
6	C2	XY-Symmetry	BP	CP	0	16.54	Free	Free	Free	Free	Free	
7	C3	XY-Symmetry	BP	CP	0	18.651	Free	Free	Free	Free	Free	
8	C4	XY-Symmetry	BP	CP	0	19.694	Free	Free	Free	Free	Free	
9	C5	XY-Symmetry	BP	CP	0	20.67	Free	Free	Free	Free	Free	
10	C6	XY-Symmetry	BP	CP	0	23.324	Free	Free	Free	Free	Free	
11	C1SF0.50	X-Symmetry	C1S	C1Y	0.5	0	Free	Free	Free	Free	Free	
12	C1YF0.50	Y-Symmetry	C1Y	C1XY	0.5	0	Free	Free	Free	Free	Free	
13	C4SF0.50	X-Symmetry	C4S	C4Y	0.5	0	Free	Free	Free	Free	Free	
14	C4YF0.50	Y-Symmetry	C4Y	C4XY	0.5	0	Free	Free	Free	Free	Free	
15	X1	XY-Symmetry	AP	BP	0	-6	Free	Free	Free	Free	Free	
16	X2	XY-Symmetry	AP	BP	0	-9	Free	Free	Free	Free	Free	
17	X3	XY-Symmetry	AP	BP	0	-15	Fixed	Fixed	Fixed	Fixed	Fixed	
18	X1XF0.50	Y-Symmetry	X1X	X1S	0.5	0	Free	Free	Free	Free	Free	
19	X1SF0.50	X-Symmetry	X1S	X1Y	0.5	0	Free	Free	Free	Free	Free	
20	X2XF0.50	Y-Symmetry	X2X	X2S	0.5	0	Free	Free	Free	Free	Free	
21	X2SF0.50	X-Symmetry	X2S	X2Y	0.5	0	Free	Free	Free	Free	Free	
22												
23												

Click here to select column and show table popup menu.



OK

Cancel

Type



7. Define Angle Group (Geometry>Angle Group..)

Angle Groups							
	Group Label	Group Description	Angle Type	Angle Size	Material Type	Element Type	Group Type
1	M1	M1	SAE	100*100*8	HT	Truss	Leg
2	M2	M2	SAE	100*100*7	HT	Truss	Leg
3	M3	M3	SAE	90*90*7	HT	Truss	Leg
4	M4	M4	SAE	90*90*7	HT	Truss	Leg
5	M5	M5	SAE	90*90*6	HT	Truss	Leg
6	M6	M6	SAE	75*75*6	HT	Truss	Leg
7	M7	M7	SAE	60*60*6	HT	Truss	Leg
8	D1	D1	SAE	50*50*5	MS	Truss	Crossing Diagonal
9	D2	D2	SAE	50*50*5	MS	Truss	Crossing Diagonal
10	D5	D5	SAE	45*45*5	MS	Truss	Crossing Diagonal
11	D6	D6	SAE	45*45*5	MS	Truss	Crossing Diagonal
12	D9	D9	SAE	50*50*5	MS	Truss	Crossing Diagonal
13	D10	D10	SAE	50*50*5	MS	Truss	Crossing Diagonal
14	D11	D11	SAE	45*45*5	MS	Truss	Crossing Diagonal
15	D12	D12	SAE	45*45*5	MS	Truss	Crossing Diagonal
16	D13	D13	SAE	45*45*5	MS	Truss	Crossing Diagonal
17	D14	D14	SAE	45*45*5	MS	Truss	Crossing Diagonal
18	D15	D15	SAE	45*45*5	MS	Truss	Crossing Diagonal
19	D16	D16	SAE	45*45*5	MS	Truss	Other
20	D17	D17	SAE	45*45*5	MS	Truss	Other
21	D18	D18	SAE	50*50*5	MS	Truss	Crossing Diagonal
22	D19	D19	SAE	50*50*5	MS	Truss	Crossing Diagonal

Click here to select column and show table popup menu.



OK Cancel

Ty

8. Define Angle Member

University of Moratuwa
Electronic Theses & Dissertations
www.libm.mrt.ac.lk

Angle Member Connectivity

Model Check Report

No errors or relevant warnings detected.



Angle: 'M1P'

Group: M1

HT

SME: 100*100*8


Dimensions (cm)

a = 10.0000
b = 10.0000
c = 0.8000
M1.6
nb = 5
nh = 2.0000
d = 1.6000
h = 1.7500
e = 2.5000
s = 4.0000
f = 2.5000
g = 2.5000
Capacity= (kN)

Diagram showing the angle member with dimensions and coordinate system.

Member Label	Group Label	Section Label	Symmetry Code	Origin Joint	End Joint	Ecc. Code	Rest. Code	Bolt Ratio	Bolt Type	# Bolts	# Holes	# Shear Planes	Connect Leg	Short Edge Dist. (cm)	Long Edge Dist. (cm)	End Dist. (cm)	Bolt Spaci. (cm)
1 M1	M1	S1	XY-Symmetry	AP	B1S	1	4	0.25	M16	5	2	2	Both	2.5	2.5	0	0
2 M2	M2	S1	XY-Symmetry	B1S	B2S	1	4	0.25	M16	7	2	1	Both	2.5	2.5	0	0
3 M3	M3	S1	XY-Symmetry	B2S	B3S	1	4	0.33	M16	6	2	2	Both	2.5	2.5	0	0
4 M4	M4	S1	XY-Symmetry	B3S	B4S	1	4	0.5	M16	6	2	2	Both	2.5	2.5	0	0
5 M5	M5	S1	XY-Symmetry	B4S	BP	1	4	0.5	M16	6	2	2	Both	2.5	2.5	0	0
6 M6	M6	S2	XY-Symmetry	BP	C1S	1	4	0.5	M16	4	2	1	Both	2.5	2.5	0	0
7 M61	M6	S2	XY-Symmetry	C1S	C2S	1	4	1	M16	4	2	1	Both	2.5	2.5	0	0
8 M62	M6	S2	XY-Symmetry	C2S	C3S	1	4	0.5	M16	4	2	1	Both	2.5	2.5	0	0
9 M7	M7	S2	XY-Symmetry	C3S	C4S	1	4	1	M16	4	2	1	Both	2.5	2.5	0	0
10 M71	M7	S2	XY-Symmetry	C4S	C5S	1	4	1	M16	4	2	1	Both	2.5	2.5	0	0
11 M72	M7	S2	XY-Symmetry	C5S	C6S	1	4	0.5	M16	4	2	1	Both	2.5	2.5	0	0
12 M73	M7	S2	XY-Symmetry	C6S	CP	1	4	1	M16	4	2	1	Both	2.5	2.5	0	0

9. Model View



Isometric View

View from Left /Right

View from Top

View from Front



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

10. Define the Load Cases (Load>Vector Load(LCA File)...)

Vector Load Cases - [f:\kctcp-ceb]\lot - b kec\tower design\td\9versin\tds\tds9.lca] [?](#)

Edit Loading Method Parameters		Note that SF stands for Strength Factor, NOT Safety Factor													
	Description	Dead Load Factor	Wind Area Factor	SF for Steel Poles	SF for Wood Poles	SF for Conc. Ult.	SF for First Crack	SF for Conc. Tens.	SF for Non Braces Insuls.	SF for Braces Insuls.	SF for Point Loads	Wind/Ice Model	Trans. Wind Pressure (Pa)	Longit. Wind Pressure (Pa)	Ice Thick. (cm)
<input checked="" type="checkbox"/> Wind loads on insulators and insulator weights included in Point Loads	b001-NCMX	2	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
1	b002-NCMN	2	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
2	b003-PRDX	1.25	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
3	b004PRMN	1.25	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
4	b005-1LMX	1.25	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
5	b006-1LMN	1.25	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
6	b007-2LMX	1.25	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
7	b008-2LMN	1.25	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
8	b009-3LMX	1.25	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
9	b010-3LMN	1.25	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
10	b011-1RMX	1.25	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
11	b012-1RMIN	1.25	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
12	b013-2RMX	1.25	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
13	b014-2RMN	1.25	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
14	b015-3RMX	1.25	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
15	b016-3RMN	1.25	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
16	b017-NCLSMX	2	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
17	b018-NCLSMN	2	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
18	b019-PKL-SMX	1.25	1	1	1	0	0	1	1	1	1	Edit (15 Wind on Face	0	0	0.000 C
19															

Row 15 'b015-3RMX': Strength factor to be used for insulators: 0 will prevent this component from being checked, 0.5 will halve its strength. Range: 0 to 3.4e+038

Save As


Type 10/11

11. Point Load

Point Loads - [b001-NCMX]

Model Check Report
No errors or relevant warnings detected.





Joint Label	Vertical Load (N)	Transverse Load (N)	Longitudinal Load (N)		Load Comment
			AP	AX	
1 AP	0	8784	0	0	AP
2 AX	0	8784	0	0	AX
3 AY	0	8784	0	0	AY
4 AXY	0	8784	0	0	AY
5 GAX	23670	30941	0	0	CAX
6 CAP	23670	30941	0	0	CAP
7 CCX	23670	25348	0	0	CCX
8 CCP	23670	25348	0	0	CCP
9 CEX	23670	24420	0	0	CEX
10 CEP	23670	24420	0	0	CEP
11 JAP	9200	10197	0	0	JAP
12 X2S	0	6375	0	0	X2S
13 X2X	0	6375	0	0	X2X
14 X2Y	0	6375	0	0	X2Y
15 X2XY	0	6375	0	0	X2XY


OK Cancel

Row 14 'X2Y': Longitudinal is along the X axis (positive coming out of the screen)

Section 15: 10/11, 



12. Check the Model (Model>check)



Results:

Tower Version 9.20 14:36:10 10 November 2013

Check of model "132 kv D/C tower type TDLS"

Checking 19 Joints
Checking 1 Bolt properties
Checking 276 Angle elements
Checking 64 Angle groups
Checking 3 Equipment properties
Checking load case "b001-NCMX"
 Checking 15 concentrated loads
Checking load case "b002-NCMN"
 Checking 15 concentrated loads
Checking load case "b003-PKMX"
 Checking 15 concentrated loads
Checking load case "b004-PKMN"
 Checking 15 concentrated loads
Checking load case "b005-1LMX"
 Checking 15 concentrated loads
Checking load case "b006-1LMN"
 Checking 15 concentrated loads
Checking load case "b007-2LMX"
 Checking 15 concentrated loads
Checking load case "b008-2LMN"
 Checking 15 concentrated loads
Checking load case "b009-3LMX"
 Checking 15 concentrated loads
Checking load case "b010-3LMN"
 Checking 15 concentrated loads
Checking load case "b011-1RMX"
 Checking 15 concentrated loads
Checking load case "b012-1RMN"
 Checking 15 concentrated loads
Checking load case "b013-2RMX"
 Checking 15 concentrated loads
Checking load case "b014-2R MN"
 Checking 15 concentrated loads
Checking load case "b015-3RMX"
 Checking 15 concentrated loads
Checking load case "b016-3RMN"
 Checking 15 concentrated loads
Checking load case "b017-NCLSMX"
 Checking 15 concentrated loads
Checking load case "b018-NCLSMN"
 Checking 15 concentrated loads
Checking load case "b019-PKLSMX"
 Checking 15 concentrated loads
Checking load case "b020-PKLSMN"
 Checking 15 concentrated loads

```
Checking load case "b021-1LLSMX"
    Checking 15 concentrated loads
Checking load case "b022-1LLSMN"
    Checking 15 concentrated loads
Checking load case "b023-2LLSMX"
    Checking 15 concentrated loads
Checking load case "b024-2LLSMN"
    Checking 15 concentrated loads
Checking load case "b025-3LLSMX"
    Checking 15 concentrated loads
Checking load case "b026-3LLSMN"
    Checking 15 concentrated loads
Checking load case "b027-NCRSMX"
    Checking 15 concentrated loads
Checking load case "b028-NCRSMN"
    Checking 15 concentrated loads
Checking load case "b029-PKRSMX"
    Checking 15 concentrated loads
Checking load case "b030-PKRSMN"
    Checking 15 concentrated loads
Checking load case "b031-1RRSMX"
    Checking 15 concentrated loads
Checking load case "b032-1RRSMN"
    Checking 15 concentrated loads
Checking load case "b033-2RRSMX"
    Checking 15 concentrated loads
Checking load case "b034-2RRSMN"
    Checking 15 concentrated loads
Checking load case "b035-3RRSMX"
    Checking 15 concentrated loads
Checking load case "b036-3RRSMN"
    Checking 15 concentrated loads
Checking 68 Secondary Joints
Checking 3 sections

Checking 1 Clamp properties
Checking 15 Clamp insulators
Checking 15 PLS-CADD links
Total of 0 errors detected while checking
```

Checking if a model for analysis can be built...
Model built successfully.


Checking view...

```
Joint Errors report: (Joint errors shown in red in current geometry view)
  0 Errors detected
```

```
Joint Warnings report: (Joint warnings shown in green in current geometry view)
  0 Warnings detected
```

```
Member Warnings report: (Member warnings shown in green in current geometry
view)
  0 Warnings detected
```

13. Analysis the Model (Model> Run)



Joints Geometry:

Joint Label	Symmetry Code	X Coord. (m)	Y Coord. (m)	Z Coord. (m)	X Disp. Rest.	Y Disp. Rest.	Z Disp. Rest.	X Rot. Rest.	Y Rot. Rest.	Z Rot. Rest.
AP	XY-Symmetry	2.031	2.031	0	Free	Free	Free	Free	Free	Free
BP	XY-Symmetry	1	1	0	Free	Free	Free	Free	Free	Free
CP	XY-Symmetry	0.75	0.75	24.32	Free	Free	Free	Free	Free	Free
JAP	None	0	0	0	Free	Free	Free	Free	Free	Free
CAP	X-Symmetry	0	4.24	14.47	Free	Free	Free	Free	Free	Free
CCP	X-Symmetry	0	3.937	18.88	Free	Free	Free	Free	Free	Free
CEP	X-Symmetry	0	3.85	23.44	Free	Free	Free	Free	Free	Free
AX	X-GenXY	2.031	-2.031	0	Free	Free	Free	Free	Free	Free
AXY	XY-GenXY	-2.031	-2.031	0	Free	Free	Free	Free	Free	Free
AY	Y-GenXY	-2.031	2.031	0	Free	Free	Free	Free	Free	Free
BX	X-GenXY	1	-1	14.47	Free	Free	Free	Free	Free	Free
BXY	XY-GenXY	-1	-1	14.47	Free	Free	Free	Free	Free	Free
BY	Y-GenXY	-1	1	14.47	Free	Free	Free	Free	Free	Free
CX	X-GenXY	0.75	-0.75	24.32	Free	Free	Free	Free	Free	Free
CXY	XY-GenXY	-0.75	-0.75	24.32	Free	Free	Free	Free	Free	Free
CY	Y-GenXY	-0.75	0.75	24.32	Free	Free	Free	Free	Free	Free
CAX	X-Gen	0	-4.24	14.47	Free	Free	Free	Free	Free	Free
CCX	X-Gen	0	3.937	18.88	Free	Free	Free	Free	Free	Free
CEX	X-Gen	0	3.85	23.44	Free	Free	Free	Free	Free	Free

Secondary Joints:

Joint Label	Symmetry Code	Origin Joint	End Joint	Fraction	Elevation	X Disp. Rest.	Y Disp. Rest.	Z Disp. Rest.	X Rot. Rest.	Y Rot. Rest.	Z Rot. Rest.
					(m)						
B1S	XY-Symmetry	AP	BP	0	4.21	Free	Free	Free	Free	Free	Free
B2S	XY-Symmetry	AP	BP	0	7.61	Free	Free	Free	Free	Free	Free
B3S	XY-Symmetry	AP	BP	0	10.39	Free	Free	Free	Free	Free	Free
B4S	XY-Symmetry	AP	BP	0	12.63	Free	Free	Free	Free	Free	Free
C1S	XY-Symmetry	BP	CP	0	15.53	Free	Free	Free	Free	Free	Free
C2S	XY-Symmetry	BP	CP	0	16.54	Free	Free	Free	Free	Free	Free
C3S	XY-Symmetry	BP	CP	0	18.88	Free	Free	Free	Free	Free	Free
C4S	XY-Symmetry	BP	CP	0	19.89	Free	Free	Free	Free	Free	Free
C5S	XY-Symmetry	BP	CP	0	20.87	Free	Free	Free	Free	Free	Free
C6S	XY-Symmetry	BP	CP	0	23.24	Free	Free	Free	Free	Free	Free
C1SF0.50S	X-Symmetry	C1S	C1Y	0.5	0	Free	Free	Free	Free	Free	Free
C1YF0.50S	Y-Symmetry	C1Y	C1XY	0.5	0	Free	Free	Free	Free	Free	Free
C4SF0.50S	X-Symmetry	C4S	C4Y	0.5	0	Free	Free	Free	Free	Free	Free
C4YF0.50S	Y-Symmetry	C4Y	C4XY	0.5	0	Free	Free	Free	Free	Free	Free
X1S	XY-Symmetry	AP	BP	0	-6	Free	Free	Free	Free	Free	Free
X2S	XY-Symmetry	AP	BP	0	-9	Free	Free	Free	Free	Free	Free
X3S	XY-Symmetry	AP	BP	0	-15	Fixed	Fixed	Fixed	Fixed	Fixed	Fixed
X1XF0.50S	Y-Symmetry	X1X	X1S	0.5	0	Free	Free	Free	Free	Free	Free
X1SF0.50S	X-Symmetry	X1S	X1Y	0.5	0	Free	Free	Free	Free	Free	Free
X2XF0.50S	Y-Symmetry	X2X	X2S	0.5	0	Free	Free	Free	Free	Free	Free
X2SF0.50S	X-Symmetry	X2S	X2Y	0.5	0	Free	Free	Free	Free	Free	Free
B1X	X-GenXY	AP	BP	0	4.21	Free	Free	Free	Free	Free	Free
B1XY	XY-GenXY	AP	BP	0	4.21	Free	Free	Free	Free	Free	Free
B1Y	Y-GenXY	AP	BP	0	4.21	Free	Free	Free	Free	Free	Free

Secondary Joints:

Joint Label	Symmetry Code	Origin Joint	End Joint	Fraction	Elevation	X Disp. Rest.	Y Disp. Rest.	Z Disp. Rest.	X Rot. Rest.	Y Rot. Rest.	Z Rot. Rest.
(m)											
B2X	X-GenXY	AP	BP	0	7.61	Free	Free	Free	Free	Free	Free
B2XY	XY-GenXY	AP	BP	0	7.61	Free	Free	Free	Free	Free	Free
B2Y	Y-GenXY	AP	BP	0	7.61	Free	Free	Free	Free	Free	Free
B3X	X-GenXY	AP	BP	0	10.39	Free	Free	Free	Free	Free	Free
B3XY	XY-GenXY	AP	BP	0	10.39	Free	Free	Free	Free	Free	Free
B3Y	Y-GenXY	AP	BP	0	10.39	Free	Free	Free	Free	Free	Free
B4X	X-GenXY	AP	BP	0	12.63	Free	Free	Free	Free	Free	Free
B4XY	XY-GenXY	AP	BP	0	12.63	Free	Free	Free	Free	Free	Free
B4Y	Y-GenXY	AP	BP	0	12.63	Free	Free	Free	Free	Free	Free
C1X	X-GenXY	BP	CP	0	15.53	Free	Free	Free	Free	Free	Free
C1XY	XY-GenXY	BP	CP	0	15.53	Free	Free	Free	Free	Free	Free
C1Y	Y-GenXY	BP	CP	0	15.53	Free	Free	Free	Free	Free	Free
C2X	X-GenXY	BP	CP	0	16.54	Free	Free	Free	Free	Free	Free
C2XY	XY-GenXY	BP	CP	0	16.54	Free	Free	Free	Free	Free	Free
C2Y	Y-GenXY	BP	CP	0	16.54	Free	Free	Free	Free	Free	Free
C3X	X-GenXY	BP	CP	0	18.88	Free	Free	Free	Free	Free	Free
<hr/>											
Joint Label	Symmetry Code	Origin Joint	End Joint	Fraction	Elevation	X Disp. Rest.	Y Disp. Rest.	Z Disp. Rest.	X Rot. Rest.	Y Rot. Rest.	Z Rot. Rest.
(m)											
C3XY	XY-GenXY	BP	CP	0	18.88	Free	Free	Free	Free	Free	Free
C3Y	Y-GenXY	BP	CP	0	18.88	Free	Free	Free	Free	Free	Free
C4X	X-GenXY	BP	CP	0	19.89	Free	Free	Free	Free	Free	Free
C4XY	XY-GenXY	BP	CP	0	19.89	Free	Free	Free	Free	Free	Free
C4Y	Y-GenXY	BP	CP	0	19.89	Free	Free	Free	Free	Free	Free
C5X	X-GenXY	BP	CP	0	20.87	Free	Free	Free	Free	Free	Free
C5XY	XY-GenXY	BP	CP	0	20.87	Free	Free	Free	Free	Free	Free
C5Y	Y-GenXY	BP	CP	0	20.87	Free	Free	Free	Free	Free	Free
C6X	X-GenXY	BP	CP	0	23.24	Free	Free	Free	Free	Free	Free
C6XY	XY-GenXY	BP	CP	0	23.24	Free	Free	Free	Free	Free	Free
C6Y	Y-GenXY	BP	CP	0	23.24	Free	Free	Free	Free	Free	Free
C1SF0.50X	X-Gen	C1S	C1Y	0.5	0	Free	Free	Free	Free	Free	Free
C1YF0.50Y	Y-Gen	C1Y	C1XY	0.5	0	Free	Free	Free	Free	Free	Free
C4SF0.50X	X-Gen	C4S	C4Y	0.5	0	Free	Free	Free	Free	Free	Free
C4YF0.50Y	Y-Gen	C4Y	C4XY	0.5	0	Free	Free	Free	Free	Free	Free
X1X	X-GenXY	AP	BP	0	-6	Free	Free	Free	Free	Free	Free
X1XY	XY-GenXY	AP	BP	0	-6	Free	Free	Free	Free	Free	Free
X1Y	Y-GenXY	AP	BP	0	-6	Free	Free	Free	Free	Free	Free
X2X	X-GenXY	AP	BP	0	-9	Free	Free	Free	Free	Free	Free
X2XY	XY-GenXY	AP	BP	0	-9	Free	Free	Free	Free	Free	Free
X2Y	Y-GenXY	AP	BP	0	-9	Free	Free	Free	Free	Free	Free
X3X	X-GenXY	AP	BP	0	-15	Fixed	Fixed	Fixed	Fixed	Fixed	Fixed
X3XY	XY-GenXY	AP	BP	0	-15	Fixed	Fixed	Fixed	Fixed	Fixed	Fixed
X3Y	Y-GenXY	AP	BP	0	-15	Fixed	Fixed	Fixed	Fixed	Fixed	Fixed
X1XF0.50Y	Y-Gen	X1X	X1S	0.5	0	Free	Free	Free	Free	Free	Free
X1SF0.50X	X-Gen	X1S	X1Y	0.5	0	Free	Free	Free	Free	Free	Free
X2XF0.50Y	Y-Gen	X2X	X2S	0.5	0	Free	Free	Free	Free	Free	Free
X2SF0.50X	X-Gen	X2S	X2Y	0.5	0	Free	Free	Free	Free	Free	Free

Angle Groups:

Group Label	Group Description	Group Angle Type	Angle Size	Material Type	Element Type	Group Type	Optimize Group	Allow. Angle For Optimize	Add. Width (cm)
M1	M1	SAE	100*100*8	HT	Truss	Leg	Size + Type	10.000	
M2	M2	SAE	100*100*7	HT	Truss	Leg	Size + Type	10.000	
M3	M3	SAE	90*90*7	HT	Truss	Leg	Size + Type	10.000	
M4	M4	SAE	90*90*7	HT	Truss	Leg	Size + Type	10.000	
M5	M5	SAE	90*90*6	HT	Truss	Leg	Size + Type	10.000	
M6	M6	SAE	75*75*6	HT	Truss	Leg	Size + Type	10.000	
M7	M7	SAE	60*60*6	HT	Truss	Leg	Size + Type	10.000	
D1	D1	SAE	50*50*5	MS	Truss Crossing	Diagonal	Size + Type	10.000	
D2	D2	SAE	50*50*5	MS	Truss Crossing	Diagonal	Size + Type	10.000	
D5	D5	SAE	45*45*5	MS	Truss Crossing	Diagonal	Size + Type	10.000	
D6	D6	SAE	45*45*5	MS	Truss Crossing	Diagonal	Size + Type	10.000	
D9	D9	SAE	50*50*5	MS	Truss Crossing	Diagonal	Size + Type	10.000	
D10	D10	SAE	50*50*5	MS	Truss Crossing	Diagonal	Size + Type	10.000	
D11	D11	SAE	45*45*5	MS	Truss Crossing	Diagonal	Size + Type	10.000	
D12	D12	SAE	45*45*5	MS	Truss Crossing	Diagonal	Size + Type	10.000	
D13	D13	SAE	45*45*5	MS	Truss Crossing	Diagonal	Size + Type	10.000	
D14	D14	SAE	45*45*5	MS	Truss Crossing	Diagonal	Size + Type	10.000	
D15	D15	SAE	45*45*5	MS	Truss Crossing	Diagonal	Size + Type	10.000	
D16	D16	SAE	45*45*5	MS	Truss	Other	Size + Type	10.000	
D17	D17	SAE	45*45*5	MS	Truss	Other	Size + Type	10.000	
D18	D18	SAE	50*50*5	MS	Truss Crossing	Diagonal	Size + Type	10.000	
D19	D19	SAE	50*50*5	MS	Truss Crossing	Diagonal	Size + Type	10.000	
D20	D20	SAE	45*45*5	MS	Truss Crossing	Diagonal	Size + Type	10.000	
D21	D21	SAE	45*45*5	MS	Truss	Other	Size + Type	10.000	
D22	D22	SAE	45*45*5	MS	Truss	Other	Size + Type	10.000	

Angle Groups:

Group Label	Group Description	Angle Type	Angle Size	Material Type	Element Type	Group Type	Optimize Group	Allow. Angle	Add. Width
						For Optimize			(cm)
D23	D23	SAE	50*50*5	MS	Truss	Crossing Diagonal	Size + Type	10.000	
D24	D24	SAE	50*50*5	MS	Truss	Crossing Diagonal	Size + Type	10.000	
D25	D25	SAE	45*45*5	MS	Truss	Crossing Diagonal	Size + Type	10.000	
D26	D26	SAE	45*45*5	MS	Truss	Crossing Diagonal	Size + Type	10.000	
D27	D27	SAE	45*45*5	MS	Truss	Crossing Diagonal	Size + Type	10.000	
D28	D28	SAE	45*45*5	MS	Truss	Crossing Diagonal	Size + Type	10.000	
D30	D30	SAE	50*50*5	MS	Truss	Crossing Diagonal	Size + Type	10.000	
D31	D31	SAE	50*50*5	MS	Truss	Crossing Diagonal	Size + Type	10.000	
D38	D38	SAE	50*50*5	MS	Truss	Other	Size + Type	10.000	
D39	D39	SAE	45*45*5	MS	Truss	Other	Size + Type	10.000	
D42	D42	SAE	60*60*5	MS	Truss	Other	Size + Type	10.000	
D43	D43	SAE	50*50*5	MS	Truss	Other	Size + Type	10.000	
H1	H1	SAE	50*50*5	MS	Truss	Other	Size + Type	10.000	
H2	H2	SAE	50*50*5	MS	Truss	Other	Size + Type	10.000	
H3	H3	SAE	45*45*5	MS	Beam	Other	Size + Type	10.000	
H4	H4	SAE	45*45*5	MS	Beam	Other	Size + Type	10.000	
H5	H5	SAE	50*50*5	MS	Truss	Other	Size + Type	10.000	
H6	H6	SAE	50*50*5	MS	Truss	Other	Size + Type	10.000	
H7	H7	SAE	45*45*5	MS	Beam	Other	Size + Type	10.000	
H8	H8	SAE	45*45*5	MS	Beam	Other	Size + Type	10.000	
H9	H9	SAE	50*50*5	MS	Truss	Other	Size + Type	10.000	
H10	H10	SAE	50*50*5	MS	Truss	Other	Size + Type	10.000	
Group Label	Group Description	Angle Type	Angle Size	Material Type	Element Type	Group Type	Optimize Group	Allow. Angle	Add. Width
						For Optimize			(cm)
H11	H11	SAE	50*50*5	MS	Truss	Other	Size + Type	10.000	
H12	H12	SAE	50*50*5	MS	Truss	Other	Size + Type	10.000	
H13	H13	SAE	60*60*5	MS	Beam	Other	Size + Type	10.000	
H14	H14	SAE	60*60*5	MS	Beam	Other	Size + Type	10.000	
H17	H17	SAE	60*60*5	MS	Beam	Other	Size + Type	10.000	
H18	H18	SAE	60*60*5	MS	Beam	Other	Size + Type	10.000	
B1	B1	SAE	75*75*6	MS	Truss	Other	Size + Type	10.000	
B2	B2	SAE	70*70*6	MS	Truss	Other	Size + Type	10.000	
B3	B3	SAE	60*60*6	HT	Truss	Other	Size + Type	10.000	
T1	T1	SAE	50*50*6	MS	Truss	Other	Size + Type	10.000	
T2	T2	SAE	45*45*5	MS	Truss	Other	Size + Type	10.000	
T3	T3	SAE	45*45*5	MS	Truss	Other	Size + Type	10.000	
P1	P1	SAE	50*50*6	MS	Truss	Other	Size + Type	10.000	
M8	M8	SAE	120*120*8	HT	Truss	Leg	Size + Type	10.000	
M10	M10	SAE	100*100*8	HT	Truss	Leg	Size + Type	10.000	
M12	M12	SAE	100*100*10	HT	Truss	Leg	Size + Type	10.000	
DUMM	DUMM	SAE	DUMMY	MS		Fictitious	Size + Type	10.000	



University of Moratuwa, Sri Lanka
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

Appendix G

Successfully performed linear analysis

Member check option: ASCE 10

Connection rupture check: Not Checked

Crossing diagonal check: Fixed

Loads from file: d:\msc\ei\msc research project\pls tower design\tower design\tacsr_as\tdl.lca

*** Analysis Results:

Maximum element usage is 93.48% for Angle "H10Y" in load case "b009-3LMX"
Maximum insulator usage is 5.06% for Clamp "CA0" in load case "b005-1LMX"

Summary of Joint Support Reactions For All Load Cases:

Load Case Label	Joint Force (kN)	Long. Force (kN)	Tran. Force (kN)	Vert. Force (kN)	Shear Force (kN)	Tran. Moment (kN-m)	Long. Moment (kN-m)	Vert. Moment (kN-m)	Bending Moment (kN-m)	Found. Moment (kN-m)	Usage %
 University of Moratuwa, Sri Lanka Electronic Theses & Dissertations www.lib.mrt.ac.lk											
b001-NCMX	X3S	-50.20	-62.66	386.39	80.29	-0.00	-0.00	-0.00	0.00	0.00	0.00
b001-NCMX	X3X	35.93	-48.35	-277.79	60.24	-0.00	-0.00	-0.00	0.00	0.00	0.00
b001-NCMX	X3XY	-36.25	-50.46	-282.38	62.13	-0.00	-0.00	-0.00	0.00	0.00	0.00
b001-NCMX	X3Y	50.52	-64.77	390.99	82.14	-0.00	-0.00	-0.00	0.00	0.00	0.00
b002-NCMN	X3S	-49.38	-63.64	380.54	80.55	-0.00	-0.00	-0.00	0.00	0.00	0.00
b002-NCMN	X3X	38.28	-52.48	-297.59	64.96	-0.00	-0.00	-0.00	0.00	0.00	0.00
b002-NCMN	X3XY	-38.28	-52.48	-297.59	64.96	-0.00	-0.00	-0.00	0.00	0.00	0.00
b002-NCMN	X3Y	49.38	-63.64	380.54	80.55	-0.00	-0.00	-0.00	0.00	0.00	0.00
b003-PKMX	X3S	-38.99	-48.90	308.10	62.55	-0.00	-0.00	-0.00	0.00	0.00	0.00
b003-PKMX	X3X	15.02	-22.99	-109.71	27.46	-0.00	-0.00	-0.00	0.00	0.00	0.00
b003-PKMX	X3XY	-28.44	-38.32	-228.32	47.73	-0.00	-0.00	-0.00	0.00	0.00	0.00
b003-PKMX	X3Y	25.56	-33.57	189.49	42.20	-0.00	-0.00	-0.00	0.00	0.00	0.00
b004PKMN	X3S	-36.75	-46.60	290.26	59.34	-0.00	-0.00	-0.00	0.00	0.00	0.00
b004PKMN	X3X	17.26	-25.30	-127.54	30.62	-0.00	-0.00	-0.00	0.00	0.00	0.00
b004PKMN	X3XY	-29.83	-39.64	-238.53	49.61	-0.00	-0.00	-0.00	0.00	0.00	0.00
b004PKMN	X3Y	24.18	-32.25	179.27	40.31	-0.00	-0.00	-0.00	0.00	0.00	0.00
b005-1LMX	X3S	-38.69	-55.16	318.90	67.37	-0.00	-0.00	-0.00	0.00	0.00	0.00
b005-1LMX	X3X	5.11	-26.36	-98.17	26.85	-0.00	-0.00	-0.00	0.00	0.00	0.00
b005-1LMX	X3XY	-38.20	-34.21	-238.67	51.28	-0.00	-0.00	-0.00	0.00	0.00	0.00
b005-1LMX	X3Y	25.45	-26.30	175.44	36.60	-0.00	-0.00	-0.00	0.00	0.00	0.00
b006-1LMN	X3S	-36.86	-53.40	304.76	64.88	-0.00	-0.00	-0.00	0.00	0.00	0.00
b006-1LMN	X3X	6.81	-28.12	-111.31	28.93	-0.00	-0.00	-0.00	0.00	0.00	0.00
b006-1LMN	X3XY	-39.90	-35.97	-251.81	53.72	-0.00	-0.00	-0.00	0.00	0.00	0.00
b006-1LMN	X3Y	23.62	-24.54	161.31	34.06	-0.00	-0.00	-0.00	0.00	0.00	0.00
b007-2LMX	X3S	-38.98	-56.19	328.72	68.38	-0.00	-0.00	-0.00	0.00	0.00	0.00
b007-2LMX	X3X	5.39	-24.64	-86.74	25.22	-0.00	-0.00	-0.00	0.00	0.00	0.00
b007-2LMX	X3XY	-37.71	-35.93	-248.57	52.09	-0.00	-0.00	-0.00	0.00	0.00	0.00
b007-2LMX	X3Y	24.96	-25.27	164.10	35.52	-0.00	-0.00	-0.00	0.00	0.00	0.00
b008-2LMN	X3S	-37.15	-54.42	314.62	65.90	-0.00	-0.00	-0.00	0.00	0.00	0.00
b008-2LMN	X3X	7.10	-26.40	-99.92	27.34	-0.00	-0.00	-0.00	0.00	0.00	0.00
b008-2LMN	X3XY	-39.42	-37.69	-261.75	54.54	-0.00	-0.00	-0.00	0.00	0.00	0.00
b008-2LMN	X3Y	23.14	-23.51	150.00	32.99	-0.00	-0.00	-0.00	0.00	0.00	0.00

b009-3LMX	X3S	-39.03	-57.49	338.72	69.48	-0.00	-0.00	-0.00	0.00	0.00
b009-3LMX	X3X	5.45	-23.22	-75.74	23.86	-0.00	-0.00	-0.00	0.00	0.00
b009-3LMX	X3XY	-37.47	-37.34	-258.12	52.90	-0.00	-0.00	-0.00	0.00	0.00
b009-3LMX	X3Y	24.72	-23.98	152.65	34.44	-0.00	-0.00	-0.00	0.00	0.00
b010-3LMN	X3S	-37.21	-55.72	324.62	67.00	-0.00	-0.00	-0.00	0.00	0.00
b010-3LMN	X3X	7.16	-24.99	-88.93	25.99	-0.00	-0.00	-0.00	0.00	0.00
b010-3LMN	X3XY	-39.18	-39.11	-271.31	55.35	-0.00	-0.00	-0.00	0.00	0.00
b010-3LMN	X3Y	22.90	-22.21	138.56	31.90	-0.00	-0.00	-0.00	0.00	0.00
b011-1RMX	X3S	-48.44	-44.66	316.10	65.89	-0.00	-0.00	-0.00	0.00	0.00
b011-1RMX	X3X	14.86	-15.86	-95.37	21.73	-0.00	-0.00	-0.00	0.00	0.00
b011-1RMX	X3XY	-28.10	-44.71	-238.82	52.81	-0.00	-0.00	-0.00	0.00	0.00
b011-1RMX	X3Y	15.35	-36.81	175.60	39.88	-0.00	-0.00	-0.00	0.00	0.00
b012-1RMN	X3S	-46.74	-42.89	302.95	63.44	-0.00	-0.00	-0.00	0.00	0.00
b012-1RMN	X3X	16.69	-17.62	-109.50	24.27	-0.00	-0.00	-0.00	0.00	0.00
b012-1RMN	X3XY	-29.93	-46.47	-252.96	55.28	-0.00	-0.00	-0.00	0.00	0.00
b012-1RMN	X3Y	13.65	-35.04	162.45	37.61	-0.00	-0.00	-0.00	0.00	0.00
b013-2RMX	X3S	-47.97	-46.37	326.09	66.72	-0.00	-0.00	-0.00	0.00	0.00
b013-2RMX	X3X	14.39	-14.83	-84.12	20.66	-0.00	-0.00	-0.00	0.00	0.00
b013-2RMX	X3XY	-28.40	-45.74	-248.74	53.84	-0.00	-0.00	-0.00	0.00	0.00
b013-2RMX	X3Y	15.65	-35.09	164.27	38.42	-0.00	-0.00	-0.00	0.00	0.00
b014-2R MN	X3S	-46.27	-44.61	312.91	64.27	-0.00	-0.00	-0.00	0.00	0.00
b014-2R MN	X3X	16.21	-16.59	-98.22	23.20	-0.00	-0.00	-0.00	0.00	0.00
b014-2R MN	X3XY	-30.22	-47.50	-262.84	56.30	-0.00	-0.00	-0.00	0.00	0.00
b014-2R MN	X3Y	13.95	-33.33	151.09	36.13	-0.00	-0.00	-0.00	0.00	0.00
b015-3RMX	X3S	-33.29	-41.42	253.43	53.14	-0.00	-0.00	-0.00	0.00	0.00
b015-3RMX	X3X	20.60	-28.64	-156.60	35.28	-0.00	-0.00	-0.00	0.00	0.00
b015-3RMX	X3XY	-22.01	-31.93	-174.86	38.78	-0.00	-0.00	-0.00	0.00	0.00
b015-3RMX	X3Y	30.15	-40.04	235.54	50.12	-0.00	-0.00	-0.00	0.00	0.00
b016-3RMN	X3S	-31.59	-39.66	240.24	50.70	-0.00	-0.00	-0.00	0.00	0.00
b016-3RMN	X3X	22.43	-30.40	-170.69	37.78	-0.00	-0.00	-0.00	0.00	0.00
b016-3RMN	X3XY	-23.83	-33.69	-188.95	41.27	-0.00	-0.00	-0.00	0.00	0.00
b016-3RMN	X3Y	28.45	-38.28	222.35	47.69	-0.00	-0.00	-0.00	0.00	0.00
b017-NCLSMX	X3S	-34.04	-48.83	261.90	59.52	-0.00	-0.00	-0.00	0.00	0.00
b017-NCLSMX	X3X	21.66	-36.39	-169.00	42.35	-0.00	-0.00	-0.00	0.00	0.00
b017-NCLSMX	X3XY	-21.66	-36.39	-169.00	42.35	-0.00	-0.00	-0.00	0.00	0.00
b017-NCLSMX	X3Y	34.04	-48.83	261.90	59.52	-0.00	-0.00	-0.00	0.00	0.00
b018-NCLSMN	X3S	-33.66	-47.88	258.88	50.00	-0.00	-0.00	-0.00	0.00	0.00
b018-NCLSMN	X3X	24.36	-37.93	-189.93	45.08	-0.00	-0.00	-0.00	0.00	0.00
b018-NCLSMN	X3XY	-24.36	-37.93	-189.93	45.08	-0.00	-0.00	-0.00	0.00	0.00
b018-NCLSMN	X3Y	33.66	-47.29	258.98	58.04	-0.00	-0.00	-0.00	0.00	0.00
b019-PKLSMX	X3S	-27.14	-37.32	215.94	46.14	-0.00	-0.00	-0.00	0.00	0.00
b019-PKLSMX	X3X	6.89	-15.26	-47.35	16.74	-0.00	-0.00	-0.00	0.00	0.00
b019-PKLSMX	X3XY	-19.46	-29.61	-158.34	35.43	-0.00	-0.00	-0.00	0.00	0.00
b019-PKLSMX	X3Y	14.57	-22.97	104.95	27.21	-0.00	-0.00	-0.00	0.00	0.00
b020-PKLSMN	X3S	-27.36	-36.87	218.10	45.91	-0.00	-0.00	-0.00	0.00	0.00
b020-PKLSMN	X3X	8.13	-15.71	-56.45	17.69	-0.00	-0.00	-0.00	0.00	0.00
b020-PKLSMN	X3XY	-21.56	-31.04	-175.06	37.79	-0.00	-0.00	-0.00	0.00	0.00
b020-PKLSMN	X3Y	13.93	-21.54	99.49	25.65	-0.00	-0.00	-0.00	0.00	0.00
b021-1LLSMX	X3S	-21.30	-31.06	165.85	37.66	-0.00	-0.00	-0.00	0.00	0.00
b021-1LLSMX	X3X	11.48	-21.68	-95.36	24.53	-0.00	-0.00	-0.00	0.00	0.00
b021-1LLSMX	X3XY	-14.72	-22.45	-109.15	26.84	-0.00	-0.00	-0.00	0.00	0.00
b021-1LLSMX	X3Y	20.00	-28.22	151.78	34.59	-0.00	-0.00	-0.00	0.00	0.00
b022-1LLSMN	X3S	-21.07	-30.16	164.09	36.79	-0.00	-0.00	-0.00	0.00	0.00
b022-1LLSMN	X3X	13.03	-22.57	-107.38	26.06	-0.00	-0.00	-0.00	0.00	0.00
b022-1LLSMN	X3XY	-16.28	-23.34	-121.17	28.45	-0.00	-0.00	-0.00	0.00	0.00
b022-1LLSMN	X3Y	19.77	-27.33	150.02	33.73	-0.00	-0.00	-0.00	0.00	0.00
b023-2LLSMX	X3S	-26.93	-43.72	233.01	51.34	-0.00	-0.00	-0.00	0.00	0.00
b023-2LLSMX	X3X	-1.71	-16.92	-27.81	17.01	-0.00	-0.00	-0.00	0.00	0.00
b023-2LLSMX	X3XY	-27.72	-27.20	-175.17	38.83	-0.00	-0.00	-0.00	0.00	0.00
b023-2LLSMX	X3Y	14.17	-15.56	83.10	21.05	-0.00	-0.00	-0.00	0.00	0.00
b024-2LLSMN	X3S	-26.70	-42.82	231.28	50.47	-0.00	-0.00	-0.00	0.00	0.00
b024-2LLSMN	X3X	-0.16	-17.81	-39.86	17.81	-0.00	-0.00	-0.00	0.00	0.00
b024-2LLSMN	X3XY	-29.28	-28.09	-187.23	40.57	-0.00	-0.00	-0.00	0.00	0.00
b024-2LLSMN	X3Y	13.95	-14.67	81.37	20.24	-0.00	-0.00	-0.00	0.00	0.00
b025-3LLSMX	X3S	-26.97	-44.90	242.05	52.38	-0.00	-0.00	-0.00	0.00	0.00
b025-3LLSMX	X3X	-1.67	-15.63	-17.72	15.72	-0.00	-0.00	-0.00	0.00	0.00
b025-3LLSMX	X3XY	-27.49	-28.49	-183.81	39.59	-0.00	-0.00	-0.00	0.00	0.00
b025-3LLSMX	X3Y	13.94	-14.38	72.61	20.03	-0.00	-0.00	-0.00	0.00	0.00
b026-3LLSMN	X3S	-26.75	-44.01	240.34	51.50	-0.00	-0.00	-0.00	0.00	0.00
b026-3LLSMN	X3X	-0.11	-16.52	-29.79	16.52	-0.00	-0.00	-0.00	0.00	0.00
b026-3LLSMN	X3XY	-29.05	-29.38	-195.88	41.31	-0.00	-0.00	-0.00	0.00	0.00

b026-3LLSMN	X3Y	13.72	-13.49	70.89	19.24	-0.00	-0.00	-0.00	0.00	0.00
b027-NCRSMX	X3S	-37.87	-48.83	291.49	61.79	-0.00	-0.00	-0.00	0.00	0.00
b027-NCRSMX	X3X	25.48	-36.39	-198.60	44.42	-0.00	-0.00	-0.00	0.00	0.00
b027-NCRSMX	X3XY	-25.48	-36.39	-198.60	44.42	-0.00	-0.00	-0.00	0.00	0.00
b027-NCRSMX	X3Y	37.87	-48.83	291.49	61.79	-0.00	-0.00	-0.00	0.00	0.00
b028-NCRSMN	X3S	-35.16	-47.28	270.57	58.93	-0.00	-0.00	-0.00	0.00	0.00
b028-NCRSMN	X3X	25.86	-37.93	-201.52	45.91	-0.00	-0.00	-0.00	0.00	0.00
b028-NCRSMN	X3XY	-25.86	-37.93	-201.52	45.91	-0.00	-0.00	-0.00	0.00	0.00
b028-NCRSMN	X3Y	35.16	-47.28	270.57	58.93	-0.00	-0.00	-0.00	0.00	0.00
b029-PKRSMX	X3S	-29.53	-37.32	234.43	47.59	-0.00	-0.00	-0.00	0.00	0.00
b029-PKRSMX	X3X	9.29	-15.26	-65.85	17.86	-0.00	-0.00	-0.00	0.00	0.00
b029-PKRSMX	X3XY	-21.85	-29.61	-176.84	36.80	-0.00	-0.00	-0.00	0.00	0.00
b029-PKRSMX	X3Y	16.97	-22.97	123.44	28.56	-0.00	-0.00	-0.00	0.00	0.00
b030-PKRSMN	X3S	-27.86	-36.38	221.53	45.82	-0.00	-0.00	-0.00	0.00	0.00
b030-PKRSMN	X3X	9.50	-16.20	-67.50	18.78	-0.00	-0.00	-0.00	0.00	0.00
b030-PKRSMN	X3XY	-22.06	-30.55	-178.49	37.68	-0.00	-0.00	-0.00	0.00	0.00
b030-PKRSMN	X3Y	15.30	-22.03	110.54	26.82	-0.00	-0.00	-0.00	0.00	0.00
b031-1RRSMX	X3S	-24.49	-30.02	182.88	38.75	-0.00	-0.00	-0.00	0.00	0.00
b031-1RRSMX	X3X	14.67	-20.64	-112.39	25.33	-0.00	-0.00	-0.00	0.00	0.00
b031-1RRSMX	X3XY	-15.97	-23.48	-126.47	28.39	-0.00	-0.00	-0.00	0.00	0.00
b031-1RRSMX	X3Y	21.24	-29.25	169.10	36.15	-0.00	-0.00	-0.00	0.00	0.00
b032-1RRSMN	X3S	-22.94	-29.13	170.86	37.08	-0.00	-0.00	-0.00	0.00	0.00
b032-1RRSMN	X3X	14.90	-21.54	-114.15	26.19	-0.00	-0.00	-0.00	0.00	0.00
b032-1RRSMN	X3XY	-16.20	-24.37	-128.23	29.26	-0.00	-0.00	-0.00	0.00	0.00
b032-1RRSMN	X3Y	19.69	-28.36	157.08	34.53	-0.00	-0.00	-0.00	0.00	0.00
b033-2RRSMX	X3S	-37.50	-34.78	249.01	51.14	-0.00	-0.00	-0.00	0.00	0.00
b033-2RRSMX	X3X	8.85	-7.98	-43.80	11.92	-0.00	-0.00	-0.00	0.00	0.00
b033-2RRSMX	X3XY	-21.61	-36.14	-193.72	42.11	-0.00	-0.00	-0.00	0.00	0.00
b033-2RRSMX	X3Y	8.06	-24.50	101.64	25.79	-0.00	-0.00	-0.00	0.00	0.00
b034-2RRSMN	X3S	-35.94	-33.89	236.95	49.40	-0.00	-0.00	-0.00	0.00	0.00
b034-2RRSMN	X3X	9.08	-8.88	-45.53	12.70	-0.00	-0.00	-0.00	0.00	0.00
b034-2RRSMN	X3XY	-21.84	-37.03	-195.44	42.99	-0.00	-0.00	-0.00	0.00	0.00
b034-2RRSMN	X3Y	6.51	-23.61	89.58	24.49	-0.00	-0.00	-0.00	0.00	0.00
b035-3RRSMX	X3S	-37.27	-36.07	257.67	51.86	-0.00	-0.00	-0.00	0.00	0.00
b035-3RRSMX	X3X	8.63	-6.80	232.34	10.99	-0.00	-0.00	-0.00	0.00	0.00
b035-3RRSMX	X3XY	-21.66	-37.32	-202.78	43.15	-0.00	-0.00	-0.00	0.00	0.00
b035-3RRSMX	X3Y	8.11	-23.48	218.28	21.56	-0.00	-0.00	-0.00	0.00	0.00
b036-3RRSMN	X3S	-35.71	-35.18	245.61	50.13	-0.00	-0.00	-0.00	0.00	0.00
b036-3RRSMN	X3X	8.85	-7.69	-55.06	11.75	-0.00	-0.00	-0.00	0.00	0.00
b036-3RRSMN	X3XY	-21.88	-38.21	-204.50	44.03	-0.00	-0.00	-0.00	0.00	0.00
b036-3RRSMN	X3Y	6.55	-22.32	79.51	23.26	-0.00	-0.00	-0.00	0.00	0.00



 University of Moratuwa Sri Lanka
 Electronic Theses & Dissertations
www.lib.mrt.ac.lk

Summary of Joint Support Reactions For All Load Cases in Direction of Leg:

Load Case Total Vert. Force (kN)	Support Origin Joint Joint Member Leg Dir.	Leg Force In Residual Shear			Residual Shear Horizontal To Leg (kN)	Total Long. Force (kN)	Total Tran. Force (kN)			
		Perpendicular								
		To Leg (kN)	To Leg (kN)	Force (kN)						
<hr/>										
b001-NCMX 386.39	X3S	X2S	M12P	394.443	12.617	12.725	-50.20	-62.66		
b001-NCMX -277.79	X3X	X2X	M12X	-283.973	12.350	12.451	35.93	-48.35		
b001-NCMX -282.38	X3XY	X2XY	M12XY	-288.803	13.862	13.972	-36.25	-50.46		
b001-NCMX 390.99	X3Y	X2Y	M12Y	399.273	14.125	14.241	50.52	-64.77		
b002-NCMN 380.54	X3S	X2S	M12P	388.709	14.338	14.458	-49.38	-63.64		
b002-NCMN -297.59	X3X	X2X	M12X	-304.278	13.916	14.027	38.28	-52.48		
b002-NCMN -297.59	X3XY	X2XY	M12XY	-304.278	13.916	14.027	-38.28	-52.48		
b002-NCMN 380.54	X3Y	X2Y	M12Y	388.709	14.338	14.458	49.38	-63.64		

b003-PKMX 308.10	X3S	X2S	M12P	314.256	9.063	9.124	-38.99	-48.90
b003-PKMX -109.71	X3X	X2X	M12X	-112.751	8.767	8.852	15.02	-22.99
b003-PKMX -228.32	X3XY	X2XY	M12XY	-233.086	8.825	8.880	-28.44	-38.32
b003-PKMX 189.49	X3Y	X2Y	M12Y	193.921	9.054	9.146	25.56	-33.57
b004PKMN 290.26	X3S	X2S	M12P	296.131	9.057	9.118	-36.75	-46.60
b004PKMN -127.54	X3X	X2X	M12X	-130.877	8.762	8.847	17.26	-25.30
b004PKMN -238.53	X3XY	X2XY	M12XY	-243.479	8.817	8.873	-29.83	-39.64
b004PKMN 179.27	X3Y	X2Y	M12Y	183.528	9.048	9.139	24.18	-32.25
b005-1LMX 318.90	X3S	X2S	M12P	325.632	14.099	14.173	-38.69	-55.16
b005-1LMX -98.17	X3X	X2X	M12X	-100.569	15.613	15.632	5.11	-26.36
b005-1LMX -238.67	X3XY	X2XY	M12XY	-243.984	7.973	8.089	-38.20	-34.21
b005-1LMX 175.44	X3Y	X2Y	M12Y	179.164	4.496	4.569	25.45	-26.30
b006-1LMN 304.76	X3S	X2S	M12P	311.270	14.161	14.236	-36.86	-53.40
b006-1LMN -111.31	X3X	X2X	M12X	-113.939	15.669	15.688	6.81	-28.12
b006-1LMN -251.81	X3XY	X2XY	M12XY	-257.354	7.999	8.116	-39.90	-35.97
b006-1LMN 161.31	X3Y	X2Y	M12Y	164.801	4.546	4.620	23.62	-24.54
b007-2LMX 328.72	X3S	X2S	M12P	335.458	14.088	14.148	-38.98	-56.19
b007-2LMX -86.74	X3X	X2X	M12X	89.148	14.004	14.636	5.39	-24.64
b007-2LMX -248.57	X3XY	X2XY	M12XY	85.554	6.762	-37.71	-35.93	
b007-2LMX 164.10	X3Y	X2Y	M12Y	167.812	5.447	5.537	24.96	-25.27
b008-2LMN 314.62	X3S	X2S	M12P	321.131	14.145	14.205	-37.15	-54.42
b008-2LMN -99.92	X3X	X2X	M12X	-102.554	14.658	14.690	7.10	-26.40
b008-2LMN -261.75	X3XY	X2XY	M12XY	-267.285	6.689	6.797	-39.42	-37.69
b008-2LMN 150.00	X3Y	X2Y	M12Y	153.485	5.490	5.581	23.14	-23.51
b009-3LMX 338.72	X3S	X2S	M12P	345.467	14.464	14.509	-39.03	-57.49
b009-3LMX -75.74	X3X	X2X	M12X	-78.151	14.071	14.118	5.45	-23.22
b009-3LMX -258.12	X3XY	X2XY	M12XY	-263.428	5.633	5.726	-37.47	-37.34
b009-3LMX 152.65	X3Y	X2Y	M12Y	156.357	6.449	6.555	24.72	-23.98
b010-3LMN 324.62	X3S	X2S	M12P	331.150	14.519	14.564	-37.21	-55.72
b010-3LMN -88.93	X3X	X2X	M12X	-91.568	14.126	14.174	7.16	-24.99
b010-3LMN -271.31	X3XY	X2XY	M12XY	-276.845	5.673	5.767	-39.18	-39.11
b010-3LMN 138.56	X3Y	X2Y	M12Y	142.040	6.486	6.592	22.90	-22.21
b011-1RMX 316.10	X3S	X2S	M12P	322.783	8.369	8.493	-48.44	-44.66
b011-1RMX -95.37	X3X	X2X	M12X	-97.719	4.279	4.348	14.86	-15.86
b011-1RMX -238.82	X3XY	X2XY	M12XY	-244.188	14.050	14.120	-28.10	-44.71
b011-1RMX	X3Y	X2Y	M12Y	179.368	15.885	15.908	15.35	-36.81

175.60	b012-1RMN	X3S	X2S	M12P	309.412	8.341	8.464	-46.74	-42.89
302.95	b012-1RMN	X3X	X2X	M12X	-112.082	4.229	4.297	16.69	-17.62
-109.50	b012-1RMN	X3XY	X2XY	M12XY	-258.550	13.987	14.057	-29.93	-46.47
-252.96	b012-1RMN	X3Y	X2Y	M12Y	165.997	15.828	15.851	13.65	-35.04
162.45	b013-2RMX	X3S	X2S	M12P	332.772	7.089	7.203	-47.97	-46.37
326.09	b013-2RMX	X3X	X2X	M12X	-86.462	5.209	5.295	14.39	-14.83
-84.12	b013-2RMX	X3XY	X2XY	M12XY	-254.108	14.045	14.101	-28.40	-45.74
-248.74	b013-2RMX	X3Y	X2Y	M12Y	168.042	14.903	14.940	15.65	-35.09
164.27	b014-2R MN	X3S	X2S	M12P	319.366	7.054	7.168	-46.27	-44.61
312.91	b014-2R MN	X3X	X2X	M12X	-100.789	5.166	5.251	16.21	-16.59
-98.22	b014-2R MN	X3XY	X2XY	M12XY	-268.435	13.989	14.044	-30.22	-47.50
-262.84	b014-2R MN	X3Y	X2Y	M12Y	154.635	14.848	14.885	13.95	-33.33
151.09	b015-3RMX	X3S	X2S	M12P	258.800	8.609	8.689	-33.29	-41.42
253.43	b015-3RMX	X3X	X2X	M12X	-160.312	8.335	8.409	20.60	-28.64
-156.60	b015-3RMX	X3XY	X2XY	M12XY	-178.866	9.282	9.348	-22.01	-31.93
-174.86	b015-3RMX	X3Y	X2Y	M12Y	240.622	9.530	9.604	30.15	-40.04
235.54	b016-3RMN	X3S	X2S	M12P	245.384	8.552	8.630	-31.59	-39.66
240.24	b016-3RMN	X3X	X2X	M12X	-174.629	8.278	8.351	22.43	-30.40
-170.69	b016-3RMN	X3XY	X2XY	M12XY	-193.183	9.225	9.291	-23.83	-33.69
-188.95	b016-3RMN	X3Y	X2Y	M12Y	227.205	9.472	9.545	28.45	-38.28
222.35	b017-NCLSMX	X3S	X2S	M12P	268.165	14.857	14.982	-34.04	-48.83
261.90	b017-NCLSMX	X3X	X2X	M12X	-173.625	14.435	14.550	21.66	-36.39
-169.00	b017-NCLSMX	X3XY	X2XY	M12XY	-173.625	14.435	14.550	-21.66	-36.39
-169.00	b017-NCLSMX	X3Y	X2Y	M12Y	268.165	14.857	14.982	34.04	-48.83
261.90	b018-NCLSMN	X3S	X2S	M12P	265.047	13.703	13.818	-33.66	-47.29
258.98	b018-NCLSMN	X3X	X2X	M12X	-194.751	13.281	13.387	24.36	-37.93
-189.93	b018-NCLSMN	X3XY	X2XY	M12XY	-194.751	13.281	13.387	-24.36	-37.93
-189.93	b018-NCLSMN	X3Y	X2Y	M12Y	265.047	13.703	13.818	33.66	-47.29
258.98	b019-PKLSMX	X3S	X2S	M12P	220.612	9.381	9.445	-27.14	-37.32
215.94	b019-PKLSMX	X3X	X2X	M12X	-49.398	9.086	9.173	6.89	-15.26
-47.35	b019-PKLSMX	X3XY	X2XY	M12XY	-162.001	9.141	9.199	-19.46	-29.61
-158.34	b019-PKLSMX	X3Y	X2Y	M12Y	108.009	9.371	9.464	14.57	-22.97
104.95	b020-PKLSMN	X3S	X2S	M12P	222.708	8.668	8.726	-27.36	-36.87
218.10	b020-PKLSMN	X3X	X2X	M12X	-58.557	8.372	8.454	8.13	-15.71
-56.45	b020-PKLSMN	X3XY	X2XY	M12XY	-178.892	8.432	8.484	-21.56	-31.04
-175.06									

b020-PKLSMN 99.49	X3Y	X2Y	M12Y	102.373	8.660	8.748	13.93	-21.54
b021-1LLSMX 165.85	X3S	X2S	M12P	169.805	9.547	9.623	-21.30	-31.06
b021-1LLSMX -95.36	X3X	X2X	M12X	-98.021	9.328	9.390	11.48	-21.68
b021-1LLSMX -109.15	X3XY	X2XY	M12XY	-112.092	8.285	8.363	-14.72	-22.45
b021-1LLSMX 151.78	X3Y	X2Y	M12Y	155.435	8.542	8.618	20.00	-28.22
b022-1LLSMN 164.09	X3S	X2S	M12P	167.932	8.889	8.960	-21.07	-30.16
b022-1LLSMN -107.38	X3X	X2X	M12X	-110.158	8.673	8.730	13.03	-22.57
b022-1LLSMN -121.17	X3XY	X2XY	M12XY	-124.229	7.630	7.702	-16.28	-23.34
b022-1LLSMN 150.02	X3Y	X2Y	M12Y	153.562	7.885	7.956	19.77	-27.33
b023-2LLSMX 233.01	X3S	X2S	M12P	238.192	13.908	13.971	-26.93	-43.72
b023-2LLSMX -27.81	X3X	X2X	M12X	-29.286	14.310	14.347	-1.71	-16.92
b023-2LLSMX -175.17	X3XY	X2XY	M12XY	-179.301	6.716	6.827	-27.72	-27.20
b023-2LLSMX 83.10	X3Y	X2Y	M12Y	85.522	5.826	5.920	14.17	-15.56
b024-2LLSMN 231.28	X3S	X2S	M12P	236.354	13.264	13.322	-26.70	-42.82
b024-2LLSMN -39.86	X3X	X2X	M12X	-41.458	13.697	13.728	-0.16	-17.81
b024-2LLSMN -187.23	X3XY	X2XY	M12XY	-191.473	6.298	6.400	-29.28	-28.09
b024-2LLSMN 81.37	X3Y	X2Y	M12Y	83.684	5.302	5.389	13.95	-14.67
b025-3LLSMX 242.05	X3S	X2S	M12P	247.242	14.834	14.283	-26.97	-44.90
b025-3LLSMX -17.72	X3X	X2X	M12X	-187.934	13.917	-1.67	-15.63	
b025-3LLSMX -183.81	X3XY	X2XY	M12XY	-187.934	5.932	6.029	-27.49	-28.49
b025-3LLSMX 72.61	X3Y	X2Y	M12Y	75.026	6.652	6.762	13.94	-14.38
b026-3LLSMN 240.34	X3S	X2S	M12P	245.414	13.602	13.646	-26.75	-44.01
b026-3LLSMN -29.79	X3X	X2X	M12X	-31.389	13.231	13.277	-0.11	-16.52
b026-3LLSMN -195.88	X3XY	X2XY	M12XY	-200.116	5.429	5.519	-29.05	-29.38
b026-3LLSMN 70.89	X3Y	X2Y	M12Y	73.198	6.181	6.283	13.72	-13.49
b027-NCRSMX 291.49	X3S	X2S	M12P	297.766	11.063	11.157	-37.87	-48.83
b027-NCRSMX -198.60	X3X	X2X	M12X	-203.225	10.641	10.725	25.48	-36.39
b027-NCRSMX -198.60	X3XY	X2XY	M12XY	-203.225	10.641	10.725	-25.48	-36.39
b027-NCRSMX 291.49	X3Y	X2Y	M12Y	297.766	11.063	11.157	37.87	-48.83
b028-NCRSMN 270.57	X3S	X2S	M12P	276.639	12.217	12.320	-35.16	-47.28
b028-NCRSMN -201.52	X3X	X2X	M12X	-206.344	11.796	11.889	25.86	-37.93
b028-NCRSMN -201.52	X3XY	X2XY	M12XY	-206.344	11.796	11.889	-25.86	-37.93
b028-NCRSMN 270.57	X3Y	X2Y	M12Y	276.639	12.217	12.320	35.16	-47.28
b029-PKRSMX 234.43	X3S	X2S	M12P	239.113	7.019	7.064	-29.53	-37.32
b029-PKRSMX -65.85	X3X	X2X	M12X	-67.899	6.726	6.793	9.29	-15.26
b029-PKRSMX	X3XY	X2XY	M12XY	-180.501	6.788	6.827	-21.85	-29.61

-176.84								
123.44	b029-PKRSMX	X3Y	X2Y	M12Y	126.510	7.017	7.091	16.97 -22.97
221.53	b030-PKRSMN	X3S	X2S	M12P	226.088	7.737	7.788	-27.86 -36.38
-67.50	b030-PKRSMN	X3X	X2X	M12X	-69.669	7.443	7.517	9.50 -16.20
-178.49	b030-PKRSMN	X3XY	X2XY	M12XY	-182.271	7.502	7.547	-22.06 -30.55
110.54	b030-PKRSMN	X3Y	X2Y	M12Y	113.485	7.732	7.812	15.30 -22.03
182.88	b031-1RRSMX	X3S	X2S	M12P	186.834	6.381	6.447	-24.49 -30.02
-112.39	b031-1RRSMX	X3X	X2X	M12X	-115.050	6.070	6.122	14.67 -20.64
-126.47	b031-1RRSMX	X3XY	X2XY	M12XY	-129.420	7.090	7.142	-15.97 -23.48
169.10	b031-1RRSMX	X3Y	X2Y	M12Y	172.763	7.376	7.426	21.24 -29.25
170.86	b032-1RRSMN	X3S	X2S	M12P	174.697	7.033	7.105	-22.94 -29.13
-114.15	b032-1RRSMN	X3X	X2X	M12X	-116.923	6.727	6.785	14.90 -21.54
-128.23	b032-1RRSMN	X3XY	X2XY	M12XY	-131.294	7.747	7.804	-16.20 -24.37
157.08	b032-1RRSMN	X3Y	X2Y	M12Y	160.626	8.032	8.087	19.69 -28.36
249.01	b033-2RRSMX	X3S	X2S	M12P	254.138	5.832	5.918	-37.50 -34.78
-43.80	b033-2RRSMX	X3X	X2X	M12X	-45.231	3.886	3.949	8.85 -7.98
-193.72	b033-2RRSMX	X3XY	X2XY	M12XY	-197.901	11.575	11.616	-21.61 -36.14
101.64	b033-2RRSMX	X3Y	X2Y	M12Y	104.122	12.420	12.446	8.06 -24.50
236.95	b034-2RRSMN	X3S	X2S	M12P	241.966	6.144	6.240	-35.94 -33.89
-45.53	b034-2RRSMN	X3X	X2X	M12X	-47.069	4.304	4.376	9.08 -8.88
-195.44	b034-2RRSMN	X3XY	X2XY	M12XY	-199.739	12.210	12.256	-21.84 -37.03
89.58	b034-2RRSMN	X3Y	X2Y	M12Y	91.950	13.028	13.058	6.51 -23.61
257.67	b035-3RRSMX	X3S	X2S	M12P	262.797	4.763	4.840	-37.27 -36.07
-33.34	b035-3RRSMX	X3X	X2X	M12X	-34.762	4.910	4.986	8.63 -6.80
-202.78	b035-3RRSMX	X3XY	X2XY	M12XY	-206.979	11.977	12.006	-21.66 -37.32
91.58	b035-3RRSMX	X3Y	X2Y	M12Y	94.070	11.930	11.969	8.11 -23.21
245.61	b036-3RRSMN	X3S	X2S	M12P	250.615	5.166	5.251	-35.71 -35.18
-35.06	b036-3RRSMN	X3X	X2X	M12X	-36.590	5.267	5.352	8.85 -7.69
-204.50	b036-3RRSMN	X3XY	X2XY	M12XY	-208.806	12.594	12.628	-21.88 -38.21
79.51	b036-3RRSMN	X3Y	X2Y	M12Y	81.888	12.562	12.607	6.55 -22.32

OVERTURNING MOMENT SUMMARY FOR ALL LOAD CASES:

Load Case	Transverse	Longitudinal	Resultant
	Moment (kN-m)	Moment (kN-m)	Moment (kN-m)
b001-NCMX	6431.576	-0.000	6431.576
b002-NCMN	6521.575	-0.000	6521.575
b003-PKMX	4018.067	1140.682	4176.843
b004PKMN	4018.067	1067.386	4157.424

b005-1LMX	3996.709	1365.390	4223.502
b006-1LMN	3987.170	1365.390	4214.477
b007-2LMX	3982.034	1569.690	4280.247
b008-2LMN	3973.177	1569.690	4272.009
b009-3LMX	3968.125	1771.669	4345.667
b010-3LMN	3959.464	1771.669	4337.760
b011-1RMX	3971.272	1365.390	4199.440
b012-1RMN	3980.811	1365.390	4208.461
b013-2RMX	3958.416	1569.690	4258.284
b014-2R MN	3967.273	1569.690	4266.518
b015-3RMX	3945.029	173.825	3948.857
b016-3RMN	3953.690	173.825	3957.509
b017-NCLSMX	4143.928	-0.000	4143.928
b018-NCLSMN	4317.087	-0.000	4317.087
b019-PKLSMX	2532.047	1067.386	2747.831
b020-PKLSMN	2640.272	1140.683	2876.142
b021-1LLSMX	2510.689	133.963	2514.260
b022-1LLSMN	2609.375	133.963	2612.811
b023-2LLSMX	2496.014	1429.470	2876.364
b024-2LLSMN	2595.382	1429.470	2963.003
b025-3LLSMX	2482.105	1613.406	2960.393
b026-3LLSMN	2581.669	1613.406	3044.354
b027-NCRSMX	4713.189	-0.000	4713.189
b028-NCRSMN	4540.030	-0.000	4540.030
b029-PKRSMX	2887.842	1067.386	3078.789
b030-PKRSMN	2779.617	1067.386	2977.513
b031-1RRSMX	2841.047	133.963	2844.203
b032-1RRSMN	2742.361	133.963	2745.631
b033-2RRSMX	2828.190	1429.470	3168.918
b034-2RRSMN	2728.822	1429.470	3080.561
b035-3RRSMX	2814.804	1613.406	3244.410
b036-3RRSMN	2715.240	1613.406	3158.419

*** Overall summary for all load cases - Usage = Maximum Stress / Allowable Stress
Printed capacities do not include the strength factor entered for each loadcase.



Electronic Theses & Dissertations

Group Summary (Compression Portion):

www.lib.mrt.ac.lk

Label Shear	Group Capacity	Group Capacity	Angle Bearing	Angle Bearing	Steel Size	Max Strength	Max Usage	Comp. Length	Comp. Curve	Comp. No.	Comp. Capacity	Comp. Capacity	L/R
M1	M1	SAE 100*100*7	355.0	83.12	83.12			M1P	-329.636	b001-NCMX	396.599		
720.000		514.080 0.250	0.250	0.250	0.250	54.31	4.280		1	6			
M2	M2	SAE 90*90*7	355.0	89.45	89.45			M2P	-322.034	b001-NCMX	384.104		
360.000		514.080 0.250	0.250	0.250	0.250	49.10	3.456		1	6			
M3	M3	SAE 90*90*7	355.0	78.84	78.84			M3P	-296.929	b001-NCMX	376.600		
720.000		514.080 0.330	0.330	0.330	0.330	52.89	2.821		1	6			
M4	M4	SAE 90*90*7	355.0	81.95	81.95			M4Y	-286.610	b001-NCMX	349.724		
720.000		514.080 0.500	0.500	0.500	0.500	64.69	2.277		1	6			
M5	M5	SAE 90*90*6	355.0	83.46	83.46			M5P	-250.469	b009-3LMX	300.091		
720.000		440.640 0.500	0.500	0.500	0.500	52.98	1.876		1	6			
M6	M6	SAE 75*75*6	355.0	93.26	93.26			M6P	-223.827	b009-3LMX	289.275		
240.000		293.760 0.500	0.500	0.500	0.500	36.18	1.064		1	4			
M7	M7	SAE 60*60*6	355.0	73.39	73.39			M7P	-118.000	b003-PKMX	160.780		
240.000		293.760 1.000	1.000	1.000	1.000	86.72	1.015		1	4			
D1	D1	SAE 50*50*5	275.0	69.43	69.43			D1P	-20.258	b012-1RMN	29.179		
120.000		98.400 0.450	0.450	0.276	198.64	6.710			5	2			
D2	D2	SAE 50*50*5	275.0	65.98	65.98			D2Y	-19.252	b009-3LMX	29.179		
120.000		98.400 0.450	0.450	0.276	198.64	6.710			5	2			
D5	D5	SAE 45*45*5	275.0	80.47	80.47			D5X	-24.782	b005-1LMX	30.796		
120.000		98.400 0.450	0.450	0.276	179.71	5.431			5	2			
D6	D6	SAE 45*45*5	275.0	71.68	71.68			D6P	-22.075	b012-1RMN	30.796		

120.000		98.400	0.450	0.450	0.276	179.71	5.431	5	2		
D9	D9	SAE	50*50*5		275.0	73.54	73.54	D9P	-30.755	b012-1RMN	41.823
120.000		98.400	0.550	0.550	0.220	159.73	4.414	5	2		
D10	D10	SAE	50*50*5		275.0	69.87	69.87	D10Y	-29.223	b009-3LMX	41.823
120.000		98.400	0.550	0.550	0.220	159.73	4.414	5	2		
D11	D11	SAE	45*45*5		275.0	85.90	85.90	D11X	-37.706	b005-1LMX	43.896
120.000		98.400	0.550	0.550	0.220	144.43	3.571	5	2		
D12	D12	SAE	45*45*5		275.0	76.50	76.50	D12P	-33.579	b012-1RMN	43.896
120.000		98.400	0.550	0.550	0.220	144.43	3.571	5	2		
D13	D13	SAE	45*45*5		275.0	78.90	78.90	D13P	-47.121	b012-1RMN	59.725
120.000		98.400	0.550	0.550	0.220	117.71	2.911	3	2		
D14	D14	SAE	45*45*5		275.0	74.96	74.96	D14Y	-44.770	b009-3LMX	59.725
120.000		98.400	0.550	0.550	0.220	117.71	2.911	3	2		
D15	D15	SAE	45*45*5		275.0	60.21	60.21	D15X	-22.268	b011-1RMX	36.983
120.000		98.400	0.500	0.500	0.500	160.71	2.828	5	2		
D16	D16	SAE	45*45*5		275.0	72.72	72.72	D162P	-48.911b014-2R MN		67.264
120.000		98.400	1.000	1.000	0.500	101.68	1.383	3	2		
D17	D17	SAE	45*45*5		275.0	82.75	82.75	D172Y	-55.661	b008-2LMN	67.264
120.000		98.400	1.000	1.000	0.500	101.68	1.383	3	2		
D18	D18	SAE	50*50*5		275.0	75.13	75.13	D18X	-58.045	b007-2LMX	77.257
120.000		98.400	0.500	0.500	0.250	97.85	2.975	3	2		
D19	D19	SAE	50*50*5		275.0	85.47	85.47	D19P	-66.034	b013-2RMX	77.257
120.000		98.400	0.500	0.500	0.250	97.85	2.975	3	2		
D20	D20	SAE	45*45*5		275.0	47.18	47.18	D20P	-21.103	b013-2RMX	44.732
120.000		98.400	0.500	0.500	0.500	142.72	2.512	5	2		
D21	D21	SAE	45*45*5		275.0	75.48	75.48	D212X	-53.168	b009-3LMX	70.436
120.000		98.400	1.000	1.000	0.500	94.58	1.286	3	2		
D22	D22	SAE	45*45*5		275.0	75.69	75.69	D222Y	-53.312	b009-3LMX	70.436
120.000		98.400	1.000	1.000	0.500	94.58	1.286	3	2		
D23	D23	SAE	50*50*5		275.0	86.43	86.43	D23X	-68.270	b010-3LMN	78.986
120.000		98.400	0.500	0.500	0.250	94.36	2.869	3	2		
D24	D24	SAE	50*50*5		275.0	81.45	81.45	D24Y	-64.331	b010-3LMN	78.986
120.000		98.400	0.500	0.500	0.250	94.36	2.869	3	2		
D25	D25	SAE	45*45*5		275.0	30.77	30.77	D25X	-16.940	b009-3LMX	55.061
120.000		98.400	0.500	0.500	0.500	124.93	2.199	D26P	-17.842b035-3RRSM		65.146
D26	D26	SAE	45*45*5		275.0	36.26	36.26				
60.000	49.200	0.500	0.500	0.500	126.33	2.881					
D27	D27	SAE	45*45*5		275.0	50.19	47.52	D27Y	-23.380b027-NCRSM		65.146
60.000	49.200	0.500	0.500	0.500	106.30	1.871					
D28	D28	SAE	45*45*5		275.0	16.07	11.98	D28P	-6.970b036-3RRSM		58.173
120.000		98.400	0.500	0.500	0.500	120.53	2.121	5	2		
D30	D30	SAE	50*50*5		275.0	66.60	66.60	D30XY	-18.843	b012-1RMN	28.292
120.000		98.400	0.450	0.450	0.280	202.31	6.834	5	2		
D31	D31	SAE	50*50*5		275.0	51.90	51.90	D31X	-14.684	b005-1LMX	28.292
120.000		98.400	0.450	0.450	0.280	202.31	6.834	5	2		
D38	D38	SAE	50*50*5		275.0	64.02	64.02	D38XY	-28.678	b011-1RMX	44.797
120.000		98.400	0.320	0.320	0.160	153.07	7.271	5	2		
D39	D39	SAE	45*45*5		275.0	60.85	60.85	D39P	-20.320	b011-1RMX	33.395
120.000		98.400	0.320	0.320	0.160	171.08	7.271	5	2		
D42	D42	SAE	55*55*5		275.0	80.59	80.59	D42XY	-29.134b017-NCLSM		36.149
120.000		98.400	0.400	0.400	0.200	185.10	7.728	5	2		
D43	D43	SAE	50*50*5		275.0	52.83	52.83	D43P	-14.816	b011-1RMX	28.044
120.000		98.400	0.400	0.400	0.200	203.37	7.728	5	2		
H1	H1	SAE	50*50*5		275.0	32.05	22.07	H1P	-12.559	b002-NCMN	56.908
120.000		98.400	1.000	1.000	0.500	131.58	2.000	5	2		
H2	H2	SAE	50*50*5		275.0	74.90	74.90	H2Y	-42.625	b011-1RMX	56.908
120.000		98.400	1.000	1.000	0.500	131.58	2.000	5	2		
H3	H3	SAE	45*45*5		275.0	18.61	18.61	FH327X	-11.751	b005-1LMX	63.147
120.000		98.400	1.000	1.000	1.000	110.57	0.973	3	2		
H4	H4	SAE	45*45*5		275.0	45.10	16.70	H4Y	-10.544	b012-1RMN	63.147
120.000		98.400	1.000	1.000	1.000	110.57	0.973	3	2		
H5	H5	SAE	50*50*5		275.0	20.01	0.00	H5X	0.000		67.347
120.000		98.400	1.000	1.000	0.500	116.85	1.776	3	2		
H6	H6	SAE	50*50*5		275.0	67.01	67.01	H6Y	-45.132	b013-2RMX	67.347
120.000		98.400	1.000	1.000	0.500	116.85	1.776	3	2		
H7	H7	SAE	45*45*5		275.0	16.17	16.17	FH741X	-11.147	b007-2LMX	68.926
120.000		98.400	1.000	1.000	1.000	97.99	0.862	3	2		
H8	H8	SAE	45*45*5		275.0	45.30	16.43	H8Y	-11.326b014-2R MN		68.926
120.000		98.400	1.000	1.000	1.000	97.99	0.862	3	2		
H9	H9	SAE	50*50*5		275.0	18.29	0.00	H9X	0.000		75.014
120.000		98.400	1.000	1.000	0.500	102.29	1.555	3	2		

H10	H10	SAE	50*50*5	275.0	93.48	93.48	H10Y	-39.528	b009-3LMX	42.284
120.000	98.400	1.000	1.000	1.000	158.66	1.555	5	2		
H11	H11	SAE	50*50*5	275.0	36.37	36.37	H11X	-16.295	b001-NCMX	44.803
120.000	98.400	1.000	1.000	1.000	153.06	1.500	5	2		
H12	H12	SAE	50*50*5	275.0	31.72	11.38	H12Y	-5.097	b036-3RRSM	44.803
120.000	98.400	1.000	1.000	1.000	153.06	1.500	5	2		
H13	H13	SAE	60*60*5	275.0	26.55	26.55	H13P	-16.616	b009-3LMX	62.595
120.000	98.400	0.500	0.500	0.500	139.22	3.258	5	2		
H14	H14	SAE	60*60*5	275.0	19.80	19.80	FH1473P	-12.392	b012-1RMN	62.595
120.000	98.400	0.500	0.500	0.500	139.22	3.258	5	2		
H17	H17	SAE	60*60*5	275.0	39.83	39.83	H17Y	-17.683	b017-NCLSM	44.390
120.000	98.400	0.500	0.500	0.500	172.35	4.033	5	2		
H18	H18	SAE	60*60*5	275.0	20.26	20.26	FH1875X	-8.994	b006-1LMN	44.390
120.000	98.400	0.500	0.500	0.500	172.35	4.033	5	2		
B1	B1	SAE	75*75*6	275.0	74.08	74.08	B1P	-87.468	b005-1LMX	125.520
120.000	118.080	0.500	0.500	0.500	115.33	3.391	2	2		
B2	B2	SAE	70*70*6	275.0	77.42	77.42	B2P	-88.978	b007-2LMX	114.925
120.000	118.080	0.500	0.500	0.500	116.75	3.176	2	2		
B3	B3	SAE	60*60*6	355.0	83.26	83.26	B3P	-90.828	b009-3LMX	109.089
120.000	146.880	0.600	0.600	0.400	108.36	3.169	2	2		
T1	T1	SAE	50*50*5	275.0	44.73	44.73	T1X	-11.628	b012-1RMN	25.993
120.000	98.400	1.000	1.000	0.500	234.91	3.571	6	2		
T2	T2	SAE	45*45*5	275.0	57.74	57.74	T2X	-12.465	b014-2R MN	21.589
120.000	98.400	1.000	1.000	0.500	246.36	3.350	6	2		
T3	T3	SAE	45*45*5	275.0	59.34	51.99	T3P	-22.280	b010-3LMN	42.852
120.000	98.400	0.600	0.600	0.400	153.06	3.367	6	2		
P1	P1	SAE	50*50*6	275.0	42.38	42.38	P1P	-36.705	b003-PKMX	86.600
120.000	118.080	0.500	0.500	0.330	113.08	3.324	1	2		
M8	M8	SAE	100*100*7	355.0	81.75	81.75	M8P	-347.057	b001-NCMX	424.527
720.000	514.080	0.250	0.250	0.250	38.70	3.050	1	6		
M10	M10	SAE	100*100*7	355.0	86.85	86.85	M10P	-352.709	b001-NCMX	406.134
720.000	514.080	0.160	0.160	0.160	49.54	6.099	1	6		
M12	M12	SAE	100*100*8	355.0	83.01	83.01	M12Y	-374.414	b001-NCMX	451.029
720.000	587.520	0.200	0.200	0.200	62.24	6.099	1	6		
DUMM	DUMM	SAE	100*100*8	355.0	0.000	0.000	DUMMXY	-10.177	b001-NCMX	0.209
120.000	5.904	0.500	0.500	0.500	365.64	4.607	5	2		

University of Moratuwa, Sri Lanka
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

Group Summary (Tension Portion):

Group Tens.	Group Conn.	Angle Tens.	Angle Conn.	Steel Conn.	Max Length	Max No.	Tension No.	Tension Of	Tension Hole	Tension	Net	
Label	Desc.	Type	Conn.	Conn.	Size	Strength	Usage	In Use	Control	Force	Control	Section
Shear Shear	Bearing	Rupture	Tens.	Bolts	Tens.	Bolts	Holes	Diameter	Tens.	Member	Load Case	Capacity
Capacity	Capacity	Capacity	Member	Tens.	(MPa)	%	%		(kN)		(kN)	
(kN)	(kN)	(kN)	(m)	(m)	(MPa)	(%)	(%)		(kN)		(kN)	
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	
M1	M1	SAE	100*100*7	355.0	83.12	64.05	M1X	252.073	b002-NCMN	393.528		
720.000	514.080	0.000	4.280	6	2.000	1.75						
M2	M2	SAE	90*90*7	355.0	89.45	71.44	M2XY	245.629	b010-3LMN	343.828		
360.000	514.080	0.000	3.456	6	2.000	1.75						
M3	M3	SAE	90*90*7	355.0	78.84	68.03	M3XY	233.902	b010-3LMN	343.828		
720.000	514.080	0.000	2.821	6	2.000	1.75						
M4	M4	SAE	90*90*7	355.0	81.95	67.25	M4XY	231.211	b010-3LMN	343.828		
720.000	514.080	0.000	2.277	6	2.000	1.75						
M5	M5	SAE	90*90*6	355.0	83.46	71.42	M5XY	212.203	b010-3LMN	297.135		
720.000	440.640	0.000	1.876	6	2.000	1.75						
M6	M6	SAE	75*75*6	355.0	93.26	76.65	M61XY	178.464	b010-3LMN	232.820		
240.000	293.760	0.000	1.008	4	2.000	1.75						
M7	M7	SAE	60*60*6	355.0	73.39	55.89	M71XY	94.123	b029-PKRS	168.405		
240.000	293.760	0.000	0.977	4	2.000	1.75						
D1	D1	SAE	50*50*5	275.0	69.43	20.57	D1XY	19.923	b005-1LMX	96.864		
120.000	98.400	0.000	6.710	2	1.000	1.75						
D2	D2	SAE	50*50*5	275.0	65.98	18.30	D2X	17.725	b012-1RMN	96.864		
120.000	98.400	0.000	6.710	2	1.000	1.75						
D5	D5	SAE	45*45*5	275.0	80.47	29.34	D5Y	24.699	b012-1RMN	84.182		
120.000	98.400	0.000	5.431	2	1.000	1.75						

D6	D6	SAE	45*45*5	275.0	71.68	27.87	D6XY	23.460	b009-3LMX	84.182
120.000		98.400	0.000	5.431	2	1.000		1.75		
D9	D9	SAE	50*50*5	275.0	73.54	31.45	D9XY	30.468	b005-1LMX	96.864
120.000		98.400	0.000	4.414	2	1.000		1.75		
D10	D10	SAE	50*50*5	275.0	69.87	28.00	D10X	27.119	b012-1RMN	96.864
120.000		98.400	0.000	4.414	2	1.000		1.75		
D11	D11	SAE	45*45*5	275.0	85.90	44.83	D11Y	37.743	b012-1RMN	84.182
120.000		98.400	0.000	3.571	2	1.000		1.75		
D12	D12	SAE	45*45*5	275.0	76.50	42.59	D12XY	35.854	b009-3LMX	84.182
120.000		98.400	0.000	3.571	2	1.000		1.75		
D13	D13	SAE	45*45*5	275.0	78.90	55.63	D13XY	46.831	b005-1LMX	84.182
120.000		98.400	0.000	2.911	2	1.000		1.75		
D14	D14	SAE	45*45*5	275.0	74.96	49.53	D14X	41.692	b012-1RMN	84.182
120.000		98.400	0.000	2.911	2	1.000		1.75		
D15	D15	SAE	45*45*5	275.0	60.21	17.57	D15X	14.793	b006-1LMN	84.182
120.000		98.400	0.000	2.828	2	1.000		1.75		
D16	D16	SAE	45*45*5	275.0	72.72	58.49	D162XY	49.242	b007-2LMX	84.182
120.000		98.400	0.000	1.383	2	1.000		1.75		
D17	D17	SAE	45*45*5	275.0	82.75	66.55	D172X	56.022	b013-2RMX	84.182
120.000		98.400	0.000	1.383	2	1.000		1.75		
D18	D18	SAE	50*50*5	275.0	75.13	59.48	D18Y	57.618	b014-2R MN	96.864
120.000		98.400	0.000	2.975	2	1.000		1.75		
D19	D19	SAE	50*50*5	275.0	85.47	67.69	D19XY	65.572	b008-2LMN	96.864
120.000		98.400	0.000	2.975	2	1.000		1.75		
D20	D20	SAE	45*45*5	275.0	47.18	18.32	D20P	15.426	b008-2LMN	84.182
120.000		98.400	0.000	2.512	2	1.000		1.75		
D21	D21	SAE	45*45*5	275.0	75.48	65.55	D212XY	55.184	b010-3LMN	84.182
120.000		98.400	0.000	1.286	2	1.000		1.75		
D22	D22	SAE	45*45*5	275.0	75.69	61.77	D222XY	51.999	b010-3LMN	84.182
120.000		98.400	0.000	1.286	2	1.000		1.75		
D23	D23	SAE	50*50*5	275.0	86.43	67.87	D23XY	65.741	b009-3LMX	96.864
120.000		98.400	0.000	2.869	2	1.000		1.75		
D24	D24	SAE	50*50*5	275.0	81.45	68.05	D24XY	65.918	b009-3LMX	96.864
120.000		98.400	0.000	2.869	2	1.000		1.75		
D25	D25	SAE	45*45*5	275.0	80.77	14.59	D25P	12.279	b010-3LMN	84.182
120.000		98.400	0.000	2.199	2	1.000		1.75		
D26	D26	SAE	45*45*5	275.0	86.26	11.28			b010-3LMN	84.182
60.000	49.200		0.000	1.871	1	1.000		1.75		
D27	D27	SAE	45*45*5	275.0	50.19	50.19	D27X	24.694	b035-3RRSM	84.182
60.000	49.200		0.000	1.871	1	1.000		1.75		
D28	D28	SAE	45*45*5	275.0	16.07	16.07	D28P	13.526	b009-3LMX	84.182
120.000		98.400	0.000	2.121	2	1.000		1.75		
D30	D30	SAE	50*50*5	275.0	66.60	20.20	D30P	19.562	b009-3LMX	96.864
120.000		98.400	0.000	6.834	2	1.000		1.75		
D31	D31	SAE	50*50*5	275.0	51.90	15.01	D31Y	14.535	b012-1RMN	96.864
120.000		98.400	0.000	6.834	2	1.000		1.75		
D38	D38	SAE	50*50*5	275.0	64.02	28.77	D38Y	27.864	b011-1RMX	96.864
120.000		98.400	0.000	7.271	2	1.000		1.75		
D39	D39	SAE	45*45*5	275.0	60.85	23.22	D39XY	19.546	b006-1LMN	84.182
120.000		98.400	0.000	7.271	2	1.000		1.75		
D42	D42	SAE	55*55*5	275.0	80.59	27.90	D42Y	27.450	b017-NCLSM	108.826
120.000		98.400	0.000	7.728	2	1.000		1.75		
D43	D43	SAE	50*50*5	275.0	52.83	14.27	D43XY	13.827	b006-1LMN	96.864
120.000		98.400	0.000	7.728	2	1.000		1.75		
H1	H1	SAE	50*50*5	275.0	32.05	32.05	H1X	31.046	b001-NCMX	96.864
120.000		98.400	0.000	2.000	2	1.000		1.75		
H2	H2	SAE	50*50*5	275.0	74.90	15.84	H2P	15.344	b006-1LMN	96.864
120.000		98.400	0.000	2.000	2	1.000		1.75		
H3	H3	SAE	45*45*5	275.0	18.61	3.88	H3P	3.262	b012-1RMN	84.182
120.000		98.400	0.000	0.973	2	1.000		1.75		
H4	H4	SAE	45*45*5	275.0	45.10	45.10	FH428P	37.966	b005-1LMX	84.182
120.000		98.400	0.000	0.973	2	1.000		1.75		
H5	H5	SAE	50*50*5	275.0	20.01	20.01	H5X	19.384	b001-NCMX	96.864
120.000		98.400	0.000	1.776	2	1.000		1.75		
H6	H6	SAE	50*50*5	275.0	67.01	23.07	H6P	22.342	b034-2RRSM	96.864
120.000		98.400	0.000	1.776	2	1.000		1.75		
H7	H7	SAE	45*45*5	275.0	16.17	3.94	H7P	3.319	b014-2R MN	84.182
120.000		98.400	0.000	0.862	2	1.000		1.75		
H8	H8	SAE	45*45*5	275.0	45.30	45.30	FH842P	38.131	b007-2LMX	84.182
120.000		98.400	0.000	0.862	2	1.000		1.75		
H9	H9	SAE	50*50*5	275.0	18.29	18.29	H9X	17.720	b017-NCLSM	96.864

120.000		98.400	0.000	1.555	2	1.000	1.75			
H10	H10	SAE	50*50*5	275.0	93.48	20.58	H10P	19.932b036-3RRSM	96.864	
120.000		98.400	0.000	1.555	2	1.000	1.75			
H11	H11	SAE	50*50*5	275.0	36.37	1.67	H11P	1.618b018-NCLSM	96.864	
120.000		98.400	0.000	1.500	2	1.000	1.75			
H12	H12	SAE	50*50*5	275.0	31.72	31.72	H12P	30.721 b001-NCMX	96.864	
120.000		98.400	0.000	1.500	2	1.000	1.75			
H13	H13	SAE	60*60*5	275.0	26.55	15.90	FH1372Y	15.643 b012-1RMN	120.750	
120.000		98.400	0.000	3.258	2	1.000	1.75			
H14	H14	SAE	60*60*5	275.0	19.80	12.34	H14X	12.146 b005-1LMX	120.750	
120.000		98.400	0.000	3.258	2	1.000	1.75			
H17	H17	SAE	60*60*5	275.0	39.83	17.81	FH1774Y	17.523b017-NCLSM	120.750	
120.000		98.400	0.000	4.033	2	1.000	1.75			
H18	H18	SAE	60*60*5	275.0	20.26	9.01	H18P	8.869 b011-1RMX	120.750	
120.000		98.400	0.000	4.033	2	1.000	1.75			
B1	B1	SAE	75*75*6	275.0	74.08	49.55	B1XY	58.511 b012-1RMN	188.305	
120.000		118.080	0.000	3.391	2	1.000	1.75			
B2	B2	SAE	70*70*6	275.0	77.42	51.50	B2XY	60.808b014-2R MN	173.498	
120.000		118.080	0.000	3.176	2	1.000	1.75			
B3	B3	SAE	60*60*6	355.0	83.26	48.85	B3XY	58.617b036-3RRSM	185.112	
120.000		146.880	0.000	3.169	2	1.000	1.75			
T1	T1	SAE	50*50*5	275.0	44.73	43.22	T1Y	41.869 b005-1LMX	96.864	
120.000		98.400	0.000	3.571	2	1.000	1.75			
T2	T2	SAE	45*45*5	275.0	57.74	49.82	T2Y	41.937 b007-2LMX	84.182	
120.000		98.400	0.000	3.350	2	1.000	1.75			
T3	T3	SAE	45*45*5	275.0	59.34	59.34	T3Y	49.951 b009-3LMX	84.182	
120.000		98.400	0.000	3.367	2	1.000	1.75			
P1	P1	SAE	50*50*6	275.0	42.38	35.03	P1XY	34.470b020-PKLSM	98.414	
120.000		118.080	0.000	3.324	2	2.000	1.75			
M8	M8	SAE	100*100*7	355.0	81.75	67.21	M8X	264.473 b002-NCMN	393.528	
720.000		514.080	0.000	3.050	6	2.000	1.75			
M10	M10	SAE	100*100*7	355.0	86.85	68.15	M10X	268.176 b002-NCMN	393.528	
720.000		514.080	0.000	6.099	6	2.000	1.75			
M12	M12	SAE	100*100*8	355.0	83.01	63.57	M12X	284.010 b002-NCMN	446.778	
720.000		587.520	0.000	6.099	6	2.000	1.75			
DUMM	DUMM	SAE	DUMMY	275.0	0.00	0.00	DUM1Y	0.107 b001-NCMX	1.176	
120.000		5.904	0.000	1.000	10	1.000	1.00			



University of Moratuwa, Sri Lanka
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

*** Maximum Stress Summary for Each Load Case

Summary of Maximum Usages by Load Case:

Load Case	Maximum Element Usage %	Element Label	Element Type
b001-NCMX	89.45	M2P	Angle
b002-NCMN	83.96	M2Y	Angle
b003-PKMX	88.83	M6P	Angle
b004PKMN	80.70	M6P	Angle
b005-1LMX	85.90	D11X	Angle
b006-1LMN	85.84	D11X	Angle
b007-2LMX	84.71	D19Y	Angle
b008-2LMN	84.81	D19Y	Angle
b009-3LMX	93.48	H10Y	Angle
b010-3LMN	86.66	M61P	Angle
b011-1RMX	78.85	D13P	Angle
b012-1RMN	78.90	D13P	Angle
b013-2RMX	85.47	D19P	Angle
b014-2R MN	85.32	D19P	Angle
b015-3RMX	56.83	M2P	Angle
b016-3RMN	53.17	M2P	Angle
b017-NCLSMX	80.59	D42XY	Angle
b018-NCLSMN	74.43	D42XY	Angle
b019-PKLSMX	52.75	M61P	Angle
b020-PKLSMN	60.53	M61P	Angle
b021-1LLSMX	51.74	D42X	Angle
b022-1LLSMN	48.23	D42X	Angle

b023-2LLSMX	72.85	D42X	Angle
b024-2LLSMN	69.31	D42X	Angle
b025-3LLSMX	79.50	D23X	Angle
b026-3LLSMN	78.62	D23X	Angle
b027-NCRSMX	81.01	M6Y	Angle
b028-NCRSMN	66.48	D42XY	Angle
b029-PKRSMX	81.02	M6P	Angle
b030-PKRSMN	69.33	M6P	Angle
b031-1RRSMX	50.15	M6Y	Angle
b032-1RRSMN	43.49	D42XY	Angle
b033-2RRSMX	73.02	D171P	Angle
b034-2RRSMN	67.46	D19P	Angle
b035-3RRSMX	80.60	M6P	Angle
b036-3RRSMN	77.35	D23P	Angle

Summary of Insulator Usages:

Insulator Label	Insulator Type	Maximum Usage %	Load Case	Weight (N)
JA0	Clamp	2.78	b003-PKMX	0.0
CA0	Clamp	5.06	b005-1LMX	0.0
CBO	Clamp	5.06	b011-1RMX	0.0
CC0	Clamp	4.96	b007-2LMX	0.0
CD0	Clamp	4.96	b013-2RMX	0.0
CEO	Clamp	4.94	b009-3LMX	0.0
CF0	Clamp	4.56	b035-3RRSMX	0.0
AA0	Clamp	0.91	b002-NCMN	0.0
AA1	Clamp	0.91	b002-NCMN	0.0
AA2	Clamp	0.91	b002-NCMN	0.0
AA3	Clamp	0.91	b002-NCMN	0.0
XC0	Clamp	0.70	b002-NCMN	0.0
XC1	Clamp	0.70	b002-NCMN	0.0
XC2	Clamp	0.70	b002-NCMN	0.0
XC3	Clamp	0.70	b002-NCMN	0.0

*** Weight of structure (N):
 Weight of Angles*Section DLF: 52794.0
 Total: 52794.0

*** End of Report

University of Moratuwa, Sri Lanka.
 Electronic Theses & Dissertations
www.lib.mrt.ac.lk

Appendix H

Tower analys with New conductor loads

Serial No.	Tower Type	Body Extens ion	Modification if any	Serial No.	Tower Type	Body Extens ion	Modification if any
1	TDT	3		61	TDL	3	
2	TD3	6		62	TDL	0	
3	TDL	6		63	TDL	3	
4	TDL	9		64	TDL	0	
5	TDL	3		65	TDL	0	
6	TDL	6		66	TDL	0	
7	TDL	6		67	TD1	3	
8	TDL	9		68	TDL	3	
9	TDL	3		69	TDL	0	
10	TD1spe	6	2 members to be changed	70	TDL	0	
11	TDL	6		71	TDL	0	
12	TDL	6		72	TDL	0	
13	TDL	0		73	TDL	0	
14	TDL	3		74	TDL	3	
15	TDL	6		75	TD3	0	2 members to be changed
16	TDL	0		76	TDL	0	
17	TDL	0		77	TDL	0	
18	TDL	0		78	TDL	6	
19	TDL	0		79	TD1sus	9	
20	TD6	0	4 members to be changed	80	TD1sus	9	
21	TDL	3		81	TDL	3	
22	TDL	0		82	TDL	0	
23	TDL	6		83	TDL	3	
24	TDL	9	1 member to be changed	84	TDL	3	
25	TDL	0		85	TDL	3	
26	TDL	3		86	TD1	3	
27	TDL	0		87	TDL	3	
28	TDL	6		88	TDL	0	
29	TD1	6		89	TDL	0	
30	TDL	3		90	TDL	0	
31	TDL	6		91	TDL	0	
32	TDL	0		92	TDL	0	
33	TDL	3		93	TDL	3	
34	TDL	6		94	TDL	6	3 members to be changed
35	TDL	3		95	TD1sus	9	
36	TDL	3		96	TD1	6	
37	TD1	0		97	TDL	3	
38	TDL	9		98	TDL	6	
39	TDL	6		99	TDL	0	
40	TDL	3		100	TDL	0	
41	TDL	0		101	TDL	0	
42	TDL	3		102	TDL	3	



University of Moratuwa, Sri Lanka.
 Electronic Theses & Dissertations
www.mrt.ac.lk

43	TDL	3		103	TDL	3	
44	TDL	3		104	TDL	3	
45	TDL	0		105	TD6	0	
46	TDL	3		106	TDL	3	
47	TD1	0		107	TDL	3	
48	TDL	3		108	TDL	0	
49	TDL	0		109	TDL	3	
50	TDL	0		110	TDL	0	
51	TDL	3		111	TDL	0	
52	TDL	3		112	TDL	3	
53	TDL	0		113	TDL	0	
54	TDL	3		114	TDL	0	
55	TDL	0		115	TDL	3	
56	TDL	0		116	TDL	0	
57	TDL	0		117	TD1	0	
58	TDL	3		118	TDL	0	
59	TDL	3		119	TDL	0	
60	TD1	3		120	TDL	3	

Serial No.	Tower Type	Body Extens ion	Modification if any	Serial No.	Tower Type	Body Extens ion	Modification if any
121	TDL	0		181	TDL	0	
122	TDL	0		182	TDL	0	
123	TDL	0		183	TDL	0	
124	TDL	3		184	TDL	3	
125	TDL	3		185	TDL	0	
126	TDL	3		186	TDL	0	
127	TDL	3		187	TD1	0	
128	TDL	3		188	TDL	3	
129	TD3	0	4 members to be changed	189	TDL	0	
130	TDL	3		190	TDL	0	
131	TDL	3		191	TDL	0	
132	TDL	0		192	TDL	0	
133	TDL	0		193	TDL	0	
134	TDL	0		194	TDL	3	
135	TDL	0		195	TDL	0	
136	TDL	0		196	TDL	0	
137	TDL	3		197	TD1	0	
138	TD1	0		198	TDL	0	
139	TDL	0		199	TDL	0	
140	TDL	0		200	TDL	0	
141	TDL	3		201	TDL	3	
142	TDL	3		202	TDL	0	
143	TDL	3		203	TDL	0	
144	TDL	3		204	TDL	0	
145	TDL	3		205	TDL	0	
146	TDL	0		206	TD1	0	2 members to be changed
147	TDL	0		207	TDL	3	
148	TDL	0		208	TDL	0	
149	TD1	0		209	TDL	3	


 University of Moratuwa, Sri Lanka.
 Electronic Theses & Dissertations
www.lib.mrt.ac.lk

150	TDL	3		210	TDL	0
151	TDL	0		211	TDL	0
152	TDL	0		212	TDL	3
153	TDL	3		213	TDL	0
154	TDL	0		214	TDL	0
155	TDL	3		215	TDL	0
156	TDL	3		216	TDL	0
157	TDL	0		217	TD1	0
158	TDL	0		218	TDL	0
159	TD1	0		219	TDL	3
160	TDL	0		220	TDL	3
161	TDL	3		221	TDL	3
162	TDL	3		222	TDL	0
163	TDL	0		223	TDL	0
164	TDL	0		224	TDL	3
165	TDL	0		225	TDL	6
166	TDL	0		226	TDL	3
167	TD3	0	1 member to be changed	227	TDL	0
168	TDL	0		228	TD3	0
169	TDL	0		229	TD1	0
170	TDL	3		230	TDL	3
171	TDL	0		231	TD1spe	0
172	TDL	0		232	TD3	0
173	TDL	0		233	TDL	6
174	TDL	3		234	TDL	3
175	TDL	0		235	TDL	3
176	TDL	0		236	TD6	3
177	TD1	0	1 member to be changed	237	TDL	6
178	TDL	0		238	TDT	0
179	TDL	0				
180	TDL	3				



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

Appendix I

i. Angle Tower (TD3)

Angle of Deviation (Degree)	Wind Span (m)	
	Conductor	Earthwire
11	958.8	1003.3
12	926.9	969.0
13	895.0	934.8
14	863.2	900.6
15	831.4	866.4
16	799.6	832.3
17	767.9	798.2
18	736.2	764.2
19	704.5	730.2
20	672.9	696.2
21	641.4	662.3
22	609.9	628.5
23	578.4	594.7
24	547.0	561.0
25	515.7	527.3
26	484.4	493.7
27	453.2	460.2
28	422.1	426.7
29	391.0	393.3
30	360.0	360.0
31	329.1	326.8
32	298.2	293.6
33	267.4	260.5
34	236.7	227.6
35	206.1	194.7



University of Moratuwa, Sri Lanka.

Electronic Theses & Dissertations

www.lib.mrt.ac.lk

36	175.6	161.8	
37	145.1	129.1	
38	114.8	96.5	
39	84.5	64.0	
40	54.3	31.6	

iv. Angle Tower (TD6)

Angle of Deviation Degree	Wind Span (m)	
	Conductor	Earthwire
40	940.4	983.6
41	910.4	951.3
42	880.4	919.1
43	850.5	887.0
44	820.7	855.0
45	791.0	823.1
46	761.5	791.3
47	732.0	759.7
48	702.7	728.1
49	673.4	696.7
50	644.3	665.5
51	615.3	634.3
52	586.4	603.3
53	557.7	572.4
54	529.0	541.6
55	500.5	511.0
56	472.2	480.5
57	443.9	450.2
58	415.8	420.0



University of Moratuwa, Sri Lanka.
 Electronic Theses & Dissertations
www.lib.mrt.ac.lk

59	387.8	389.9
60	360.0	360.0
61	332.3	330.2
62	304.7	300.6
63	277.3	271.2
64	250.1	241.9
65	223.0	212.8
66	196.0	183.8
67	169.2	155.0
68	142.5	126.3
69	116.0	97.9
70	89.7	69.6

v. Angle Tower (TDT)

Angle of Deviation (Degree)	University of Moratuwa, Sri Lanka.	
	Conductor	Earthwire
75	721.3	748.2
76	696.0	721.0
77	670.8	693.9
78	645.8	667.1
79	621.0	640.4
80	596.3	613.9
81	571.8	587.6
82	547.6	561.5
83	523.5	535.6
84	499.5	509.9
85	475.8	484.4
86	452.3	459.1
87	428.9	434.0

88	405.7	409.1
89	382.8	384.5
90	360.0	360.0
91	337.4	335.7
92	315.1	311.7
93	292.9	287.9
94	270.9	264.3
95	249.1	240.9
96	227.6	217.7
97	206.2	194.8
98	185.1	172.1
99	164.2	149.6
100	143.5	127.3



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

Appendix J

