

## REFERENCES

- [1] BS, *BS 215-1&2 - Specification for aluminium conductors and aluminium Conductors, steel-reinforced for overhead power transmission. Aluminium conductors, steel-reinforced*, 1970.
- [2] IEC, *IEC 61089 - Round wire concentric lay overhead electrical stranded conductors, 1st ed.*, May 1991.
- [3] IEC, *IEC 60889 - Hard Drawn Aluminium wire for overhead conductors, 1st ed.*, 1987.
- [4] IEC, *IEC 62004 - Thermal Resistance Aluminium Alloy wire for overhead line conductors, 1st ed.*, 2007 - 02.
- [5] The Aluminum Association, *Aluminum Electrical Conductor Hand Book, Third Edition*, 1989.
- [6] Electric Power Research Institute, *Demonstration of Advanced Conductors for Overhead Transmission Lines, CEC-500-2013-030*, July 2008.
- [7] IEC, *IEC 60888 - Zinc Coated Steel Wires for stranded conductors, 1st ed.*, 1987.
- [8] CEB, *Technical Specification- Employers' Requirement- Part B (Transmission Line Construction), Volume 05 of 08, Feb 2011.*
-  University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)
- [9] CTC-Global, *Engineering Transmission Lines with High Capacity Low Sag ACCC conductors, 1st ed.*, 2011.
- [10] IEEE, *IEEE Standard 738 "IEEE Standard for Calculating the Current-Temperature Relationship of Bare Overhead Conductors"*, 2006.
- [11] C. R. Bayliss (Dr.) and B. Hardy (C Eng), *Transmission and Distribution Electrical Engineering, 3rd ed.*
- [12] "J Power Systems," [Online]. Available:  
<http://www.jpowers.co.jp/english/>, [Accessed May 17, 2014].
- [13] "Viscas Corporation," [Online]. Available:  
[http://www.viscas.com/english/e\\_index.html](http://www.viscas.com/english/e_index.html), [Accessed Feb 01, 2015].
- [14] "3M" [Online]. Available:  
[http://solutions.3m.com/wps/portal/3m/en\\_us/emd\\_accr/](http://solutions.3m.com/wps/portal/3m/en_us/emd_accr/) [Accessed Feb 01, 2015].
- [15] "CTC Cable Corporation," [Online]. Available: <http://www.ctcglobal.com/>.
- [16] KPTL, *Design of Transmission Lines, Structures and Foundations*, July, 2013.

- [17] ANSI /ASCE *Design of latticed steel transmission structures*, Oct 1997.
- [18] ISO, ISO 630 -*Structural Steels - Plates, Wide Flats, Bars, Sections and Profiles*, 2011
- [19] BS, BS 8004 -*Code of Practice for Foundations*, 1986
- [20] BS, BS 8110-1 *Structural Use of Concrete. Code of Practice for Design and Construction*, 1997.
- [21] H.B.D. Yasaranga, *Techno Economic Analysis on The Use of HTLS Conductors for Sri Lanka's Transmission System.*, 2015.
- [22] IEC, IEC 61597 "Overhead electrical conductors- Calculation methods for stranded bare conductors, 1st ed., May 1995.
- [23] "International Commission on Non-Ionizing Radiation Protection (ICNIRP)," [Online]. Available: <http://www.icnirp.org/>.
- [24] "Power Line Systems," [Online]. Available: <http://www.powlne.com/files/cables.html>.
- [25] W. J. Fabrycky, B. S. Blanchard, "Life-Cycle Cost and Economic Analysis," Prentice Hall, Englewood Cliffs, N.J., 1991



University of Moratuwa, Sri Lanka  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

## APPENDIX I: Sample Result Steps for Sag Tension Calculation

<b>S</b>	<b>Sag (m)</b>	<b>7.809</b>
<b>H<sub>2</sub></b>	Final Tension (N/mm <sup>2</sup> )	47.73
<b>UTS</b>	Tensile Strength (kN)	131.9
<b>m<sub>c</sub></b>	Unit mass of the conductor (kg/m)	1.632
<b>A</b>	Cross section Area (mm <sup>2</sup> )	484.5
<b>E</b>	Modulus of Elasticity (N/mm <sup>2</sup> )	69000
<b>α</b>	Linear Coefficient (C <sup>-1</sup> )	0.0000193
<b>P</b>	Wind pressure on conductor (N/m <sup>2</sup> )	970
<b>d</b>	Diameter of the conductor (mm)	28.62
<b>H<sub>1</sub></b>	Initial Tension (N/mm <sup>2</sup> )	109.23
<b>g</b>	Gravitational Constant (m/s <sup>2</sup> )	9.80665
<b>S</b>	Ruling Span Length (m)	300
<b>t<sub>1</sub></b>	Initial Temperature (°C)	7
<b>t<sub>2</sub></b>	Final Temperature (°C)	75
<b>h</b>	Level Difference (m)	0



University of Moratuwa, Sri Lanka.  
 Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

## APPENDIX II: Sample Calculation for CCC

**Heat Balance Equation;**  $P_j + P_{sol} = P_{rad} + P_{conv}$

$P_j$  = heat generated by joule effect  
 $P_{sol}$  = solar heat gain by conductor surface  
 $P_{rad}$  = heat loss by radiation  
 $P_{conv}$  = convection heat loss

**Solar Heat Gain;**  $P_{sol} = \gamma D S_i$

$$P_{sol} = 14.31 \text{W/m}$$

$\gamma$  = Solar radiation absorption coefficient (0.5)  
 $D$  = Conductor Diameter (0.02862m)  
 $S_i$  = intensity of solar radiation (1000W/m<sup>2</sup>)

**Radiated Heat Loss;**  $P_{rad} = S\pi D K_e (T_2^4 - T_1^4)$

 University of Moratuwa, Sri Lanka.  
 $P_{rad} = 15.3260 \text{W}$   
 $S$  Stefan-Boltzmann constant ( $5.67 \times 10^{-8} \text{ W/m}^2\text{k}^4$ )  
 $D$  conductor diameter (0.02862m)  
 $K_e$  emissivity coefficient (0.5)  
 $T_2$  final equilibrium temperature (75°C)  
 $T_1$  ambient temperature (32°C)

**Reynolds Number;**  $R_e = 1.644 \times 10^9 vD [T_1 - 0.5(T_2 - T_1)]^{-1.78}$

$$R_e = 788.55$$

$R_e$  = Reynolds number  
 $v$  = wind speed (0.5 m/s)  
 $D$  = conductor diameter (0.02862m)

**Nusselt Number;**  $N_u = 0.65 R_e^{0.2} + 0.023 R_e^{0.61}$

$$N_u = 15.920$$

**Conventional Heat Loss;**  $P_{\text{conv}} = \lambda N_u (T_2 - T_1) \pi$

$$P_{\text{conv}} = 55.5927$$

$\lambda$  = Thermal Conductivity of Air (0.02585W/m.k)

**Joule Effect;**  $P_j = R_t I^2$

$R_t$  = Resistance at t 0C ( $R_{25}=0.06841$ ,  $R_{75}=0.06841$ )

$$I = \left( \frac{P_{\text{rad}} + P_{\text{conv}} - P_{\text{sol}}}{R_t} \right)^{0.5}$$

$$I = 833A$$



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

### APPENDIX III: Energy Loss Calculation

Conductor	ACSR		ACCC
	ZEBRA		DUBLIN
<b>Diameter (mm)</b>	28.62		28.143
<b>AC Resistance at 25°C (ohms/km)</b>	0.06841		0.05534
<b>AC Resistance at 75°C (ohms/km)</b>	0.08149		0.06596
<b>Ultimate Tensile Strength (kN)</b>	132.3		183.3
<b>Unit Mass of Conductor (kg/m)</b>	1.621		1.5832
<b>Cross Sectional Area (mm<sup>2</sup>)</b>	429.1		524.5
<b>Modulus of Elasticity (N/mm<sup>2</sup>)</b>	69000		78000
<b>Linear Coefficient (°C<sup>-1</sup>)</b>	0.0000193		0.0000186
<hr/>			
<b>Conductors per phase:</b>	1		1
<b>Circuits:</b>	2		2
<b>@75</b>	833.0	<b>@68.27</b>	833.0
<b>@75</b>	833	<b>@180</b>	1712
<b>@100</b>	1070	<b>@200</b>	1813
<b>S-S Temp. (°C) at Peak Ampacity of ACSR Zebra:</b>	75.00		68.27
<b>Resistance at Peak Operating Amps (ohm/km)</b>	0.08148		0.06453

	Environmental Factors
1000	Sun Radiation (W/m <sup>2</sup> )
0.5	Wind Speed (ms <sup>-1</sup> )
0.5	Solar Radiation Absorption Coefficient
0.5	Emissivity coefficient
32	Ambient Temperature (°C)
0.02585	Air thermal Conductivity (Wm <sup>-1</sup> K <sup>-1</sup> )
5.67E-08	Stefan- Boltzmann Constant (Wm <sup>-2</sup> K <sup>-4</sup> )

Load and Generation Cost (Source; Statistics Digest2014, CEB)	
1	Line Length (km)
132	Voltage (kV)
833	Peak Operating Amps (A)
57.3%	Load Factor
37.7%	Loss Factor
190	Peak Power per Circuit (MW)
3	Phases/Circuit
19.97	Cost of Energy Generation (LKR/kWh)
0.8	CO <sub>2</sub> (kg/kWh)
0	Carbon Credit (LKR/MT)

*First Year Line Loss*

$$= \text{Phase current}^2 * \text{Unit Resistance} * \text{Line Length} \\ * \text{no. of conductors} * \text{Line Loss Factor} * 8760$$

$$\text{Load Factor} = \frac{\text{Average Demand}}{\text{Maximum Demand}}$$

$$\text{Loss Factor} = 0.2 * \text{Load Factor} + .8 * \text{Load Factor}^2$$

**For ACSR Zebra Conductor;**

Load Factor = 57.3%; from CEB Sources

Loss Factor = 37.7%

$$\text{First Year Line Loss} = 833^2 * .08148 * 1 * 6 * .377 * 8760$$

$$\text{First Year Line Loss} = 1121.09 \text{ MWh}$$

**For ACCC Dublin Conductor;**

$$\text{First Year Line Loss} = 833^2 * .06453 * 1 * 6 * .377 * 8760$$

$$\text{First Year Line Loss} = 887.87 \text{ MWh}$$

$$\text{Reduces First Year Line Losses by} = 1121.09 - 887.87$$

$$\begin{aligned} & \text{University of Moratuwa, Sri Lanka.} \\ & \text{Reduces First Year Line Losses by (\%)} = \frac{233.22}{1121.09} \\ & \qquad \qquad \qquad = 20.80\% \end{aligned}$$

$$\begin{aligned} \text{Saving} \left( \frac{\text{MLKR}}{\text{Year}} \right) &= \text{Line Loss Saving} * \text{Cost of Energy Generation} \\ &= 233.22 * 19.97 \\ &= 4.66 \end{aligned}$$

$$\text{Net Present Value} = \sum_{t=1}^n \frac{C}{\left(\frac{1}{1+i}\right)^n}$$

;  $i$  = discount rate (10%),

$n$  = nos. of years (40)

$$= \sum_{t=1}^{40} \frac{4.66}{\left(\frac{1}{1+.1}\right)^n}$$

$$\text{Reduction in 40yrs Losses (MLKR)} = 45.54$$

## APPENDIX IV: Sample Load Calculation for TDL Tower

### TOWER: TDL

#### BASIC DATA

Deviation Angle = 0

Basic Span = 300 m

Wind/Weight Span

Condition	Wind Span (m)	Weight Span (m) Maximum	Weight Span (m) Maximum
Normal Condition	360	600	150
Broken wire Condition	270	450	112.5

Wind Load on Tower = 1640 N/m<sup>2</sup>\*Projected Area

Wind Load Wires = 970 N/m<sup>2</sup>\*Projected Area

Wind Load Insulator = 1170 N/m<sup>2</sup>\*Projected Area

 University of Moratuwa, Sri Lanka.  
sag-Tension Calculation" for mechanical properties and wire tension under different  
conditions for Conductor ACSR - Zebra (400mm<sup>2</sup>)/OPGW/GSW 7/3.25 (1000 Grade)  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

#### Information Relevant to Element Design

All dimensions are in mm and Loads are in N (Newton) wherever not specified.

Loading calculation for Conductor/ Earth wire / OPGW are done as per technical specification requirements.

Members indicated as MS are as per ISO 630 1995(E) Gr. E 275

With minimum Yield stress = 275 MPa (Thickness<16mm)

265MPa (Thickness 16 to 40mm)

Member indicated as "HT" are as per ISO 630 1995(E) Gr. E 355

With minimum Yield stress = 355 MPa (Thickness<16mm)

345MPa (Thickness 16to40mm)

Bolt & Nuts are as per ISO 898 - 1.1999 (E) Class 5.6

For design of bolts and nuts the following stresses are used.

$$\text{Ultimate shearing stress} = 0.25 * \text{FU1} = 0.62 * 500 = 310 \text{N/mm}^2$$

As per clauses 4.3.2 of ASCE 10-97

Tower Design Performed as per ASCE 10-97 using 3D models in “PLC Tower” version 12.0

Loads applied in PLS - TOWER software by multiplying with Factor of Safety as furnished in Specification.

Condition	Normal Condition	Broken Wire Condition
Factor of Safety	2.50	1.25

Enough safety margin maintained in Broken Wire Condition for Cross Arm members to achieve 2.00 factor of safety in main cross arm members (PKLM, TCLM, MC LM & BC LM)

For design of each member maximum forces are derived from multiple analysis of tower with all loading conditions and all 3D models with various body extensions.



University of Moratuwa, Sri Lanka  
Electronic Theses & Dissertations

[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

#### Design Data

Earth Wire	7/3.25	Conductor ACSR 61/3.18		Insulators	
<b>Number Ne</b>	1.00	Number Nc	1.00	Number Ni	1.00
<b>Diameter De (mm)</b>	9.75	Diameter Dc (mm)	28.62	Diameter Di (mm)	255
<b>Weight We (kg/m)</b>	0.46	Weight Wc (kg/m)	1.62	Weight Wi (kg/m)	47.6
<b>Tension Te (N)</b>	18931	Tension Tc (N)	52920	Length Li (m)	2.10
<b>OPGW</b>				Insulators	
<b>Number Ne</b>	1.00	Clamp weight GSW	5.00	Number Ni	1.00
<b>Diameter De (m)</b>	12.50	Clamp weight OPGW	5.00	Diameter Di (mm)	255
<b>Weight We (kg/m)</b>	0.46			Weight Wi (kg/m)	47.6
<b>Tension Te (N)</b>	21620			Length Li (m)	2.10
<b>Spans in m</b>		Wind Pressure in kg/sqmm		Line Deviation	
<b>Normal Sn (m)</b>	300	Earth wire Pe (N/m <sup>2</sup> )	970	Angle	0.00
<b>Wind Span (m)</b>	360	Conductor Pc (N/m <sup>2</sup> )	970	Safety Factors	
<b>Max. Wt. Swt1 (m)</b>	600	Insulator Pi (N/m <sup>2</sup> )	1170	Normal Case	2.50
<b>Min. Wt. Swt2 (m)</b>	150	Man with Tools in KGS	150	Broken Wire	1.25

### **Formulae Used In Load Calculation**

Wind load on Conductor /Earth wire/ OPGW = Diameter \* Wind Span\*970N/m<sup>2</sup>

Angle pull Conductor / Earth wire = 2\*Maximum Working Tension \* sin (Deviation Angle/2)

Wind Load on insulator = 0.5\*Length of Insulator String \* Diameter of Insulator String \*1170N/m<sup>2</sup>

Weight of conductor/ Earth wire = Unit weight \* weight span

Earth wire Tension at broken wire condition = 1.0\* Maximum Working Tension

Conductor Tension at broken wire condition =0.7\*Maximum Working Tension

For Earth wire loads OPGW considered on Left Side & Earth wire GS 7/3.25(1000 Grade) Considered on Right Side.

### **Formulae Used In Tower Design**

L/R = Maximum of Lxx/Rxx or Lw/Rw

KL/R = L/R if (curve No. = 1) and (0<=L/R<=120) ASCE 10 Eq 3.7.5

=30+ (0.75\*(L/R)) if (curve No. =2) and (0<=L/R<=120) ASCE 10 Eq 3.7.6

=50+ (0.5\*(L/R)) if (curve No. =3) and (0<=L/R<=120) ASCE 10 Eq 3.7.7

= L/R if (curve No. = 3) and (0<=L/R<=120) ASCE 10 Eq 3.7.8

= 28.6+ (0.762\*(L/R)) if (curve No. 5))and (0<=L/R<=120) ASCE 10 Eq 3.7.9

=46.2+ (0.615\*(L/R)) if (curve No. 6)) and (120<=L/R<=250) ASCE10Eq3.7.10

Allowable compression stress Fa

Fa = (1.0.5\*(KL/R/Cc<sup>2</sup>)\*Fy) if KL/R<= Cc ASCE 10 Eq . 3.6.1

Fa = ( $\pi^2 * E$ ) KL if KL/R>= Cc ASCE 10 Eq . 3.6.2

Cc = Fa (2\*E) FY)<sup>1/2</sup> ASCE 10 Eq . 3.6.3

Allowable tension stress on net cross section area Ft.

Ft = 0.9\*Fy

Applied shear stress on a bolt S.

S = Applied maximum force (minimum cross sectional area of bolt \* number of bolts)

Applied Bearing Stress for one bolt B

B= Applied maximum force/ (Thickness of connected part \* bolt normal diameter \* Number of bolts)

### Loading Calculation for Conductor

Condition	Normal Condition		Broken wire Condition	
<b>Transverse Load</b>				
<b>Wind on wire</b>	$1*360*(28.62/1000)*970*2.5$	24985.26	$1*270(28.62/1000)*970*1.25$	9369.47
<b>Wind on Insulator string</b>	$1*1*0.5*255* 1170*2.5$	783.17	$1*1*.5*2.1*255*1170*1.25$	391.58
<b>Deviation load/Angle pull</b>	$1*2*52920*SIN(0)*2.5$	0.00	$1*2*52920*SIN(0)*1.25$	0.00
<b>Total (N)</b>		25768.43		9761.06
<b>Max Vertical Load</b>				
<b>Weight of Wire</b>	$1*600*(1.62*9.81)*2.5$	23860.31	$1*450(1.62*9.81)*1.25$	8947.62
<b>Weight of insulator stringing</b>	$1*(100*9.381)*2.5$	2453.25	$1*(100*9.81)* 1.25$	1226.63
<b>Weight of man with toolkit</b>	$150*9.81*2.5$	3679.88	$(150 *9.81)* 1.25$	1839.94
<b>Total (N)</b>		29993.43		12014.18
<b>Min Vertical load</b>				
<b>Weight of wire</b>	$1*150* (1.62*9.81)*2.5$	5965.08	$1*1125*(1.62*9.81)*1.25$	2236.90
<b>Weight of insulator string</b>	$1*(100*9.8.1)*2.5$	2453.25	$1*(100*9.8.1)*1.25$	1226.63
<b>TOTAL (N)</b>		8418.33		3463.53
<b>Longitudinal load</b>				
<b>Deviation load/Angle pull</b>			$1*52257*Cos (0)$	46305.00
<b>Total (N)</b>				46305.00
<b>Notes :-</b>				
1) F.O.S. for NC = 2.5				
2) F.O.S for BWC = 1.25 and cross Arm Member in BWC = 2.0				
3) Tower to be designed for single Circuit strung condition				

## Loading Calculation for GSW


Condition	Normal Condition		Broken wire Condition	
<b>Transverse Load</b> <b>Wind on wire</b> <b>Deviation load/Angle pull</b> <b>Total (N)</b>	$1*360*(9.75/1000)*970*2.5$ $1*2*18931*\text{SIN}(0)*2.5$	8511.75 0.00 8511.75	$1*270* (9.75/1000)*970*1.25$ $1*8931*1.25$	3191.91 0.00 3191.91
<b>Max Vertical Load</b> <b>Weight of Wire</b> <b>Clamp</b> <b>Weight of man with toolkit</b> <b>Total (N)</b>	$1*600*(1.632*9.81)*2.5$ $1*(100*9.81)*2.5$ $(150*9.81)*2.5$	6770.97 122.66 3679.88 10573.51	$1*450(1.632*9.81)*1.25$ $1*(100*9.81)*1.25$ $(150 *9.81)*1.25$	2539.11 61.33 1839.94 4440.38
<b>Min Vertical load</b> <b>Weight of wire</b> <b>Weight of Clamps</b> <b>TOTAL (N)</b>	$1*150*(1.632*9.81)*2.5$ $1*(100*9.81)*2.5$	1692.74 122.66 1815.41	$1*1125*(1.632*9.81)*1.25$ $1*(100*9.8.1)*1.25$	634.78 61.33 696.11
<b>Longitudinal load</b> <b>Deviation load/Angle pull</b> <b>Total (N)</b>		0.00	$1*18931* \text{Cos}(0)*1.25$	23663.75 23663.75
<b>Notes :-</b> 1) F.O.S. for NC = 2.5 2) F.O.S for BWC = 1.25 and cross Arm Member in BWC = 2.0 3) Tower to be designed for single Circuit strung condition				

## Loading Calculation for OPGW

Condition	Normal Condition		Broken wire Condition	
<b>Transverse Load</b>				
Wind on wire	$1*360*(12.5/1000)*970*2.5$	10912.50	$1*270*12.5/1000*970*1.25$	4092.19
Deviation load/Angle pull	$1*2*21620*\text{SIN}(0)*2.5$	0.00	$1*21620*\text{SIN}(0)*1.25$	0.00
<b>Total (N)</b>		10912.50		4092.19
<b>Max Vertical Load</b>				
Weight of Wire	$1*600*(0.46*9.81)*2.5$	6770.97	$1*450*(0.460*9.81)*1.25$	2539.11
Clamp	$1*(5*9.81)*2.5$	122.66	$1*(5*9.81)*1.25$	61.33
Weight of man with toolkit	$(150*9.81)*2.5$	3679.88	$(150*9.81)*1.25$	1839.94
<b>Total (N)</b>		10573.71		4440.38
<b>Min Vertical load</b>				
Weight of wire	$1*150*(0.46*9.81)*2.5$	1692.74	$1*112.5*(0.46*9.81)*1.25$	634.78
Weight of Clamps	$1*(5*9.81)*2.5$	122.66	$1*(5*9.81)*1.25$	61.33
<b>TOTAL (N)</b>		1815.41		696.11
<b>Longitudinal load</b>				
Deviation load/Angle pull			$1*21620*\text{COS}(0)*1.25$	27025.00
<b>Total (N)</b>		0.00		27025.00
<b>Notes :-</b>				
1) F.O.S. for NC = 2.5				
2) F.O.S for BWC = 1.25 and cross Arm Member in BWC = 2.0				
3) Tower to be designed for single Circuit strung condition				

### **Loading Trees and Loading Cases.**

Load tree shows the loading points of the tower. Calculated loads will be applied respective points on the tower. In each load case different loads will be applied, and tower strength is modified accordingly.



Following table shows different loading cases due to breakage of different wires of the tower.

Broken ( GSW and Top Conductor)				Broken ( OPGW and Top Conductor)			
Join Label	Vertical Load/(N)	Transverse Load /(N)	Longitudinal Load /(N)	Join Label	Vertical Load/(N)	Transverse Load /(N)	Longitudinal Load /(N)
PGR	4440.38	3191.91	23663.75	PGR	5286.75	5456.25	0.00
POL	5286.75	5456.25	0.00	POL	4440.38	4092.19	27025.00
TCR	12014.18	9761.06	46305.00	TCR	14996.72	12884.21	0.00
TCR	14996.72	12884.21	0.00	TCR	14996.72	12884.21	0.00
TCL	14996.72	12884.21	0.00	TCL	12014.18	9761.06	46305.00
TCL	14996.72	12884.21	0.00	TCL	14996.72	12884.21	0.00
MCR	14996.72	12884.21	0.00	MCR	14996.72	12884.21	0.00
MCR	14996.72	12884.21	0.00	MCR	14996.72	12884.21	0.00
MCL	14996.72	12884.21	0.00	MCL	14996.72	12884.21	0.00
MCL	14996.72	12884.21	0.00	MCL	14996.72	12884.21	0.00
BCR	14996.72	12884.21	0.00	BCR	14996.72	12884.21	0.00
BCR	14996.72	12884.21	0.00	BCR	14996.72	12884.21	0.00
BCL	14996.72	12884.21	0.00	BCL	14996.72	12884.21	0.00
BCL	14996.72	12884.21	0.00	BCL	14996.72	12884.21	0.00



University of Moratuwa, Sri Lanka

Electronic Theses & Dissertations

Broken ( GSW and Middle Conductor)				Broken ( OPGW and Middle Conductor)			
Join Label	Vertical Load/(N)	Transverse Load /(N)	Longitudinal Load /(N)	Join Label	Vertical Load/(N)	Transverse Load /(N)	Longitudinal Load /(N)
PGR	4440.38	3191.91	23663.75	PGR	5286.75	5456.25	0.00
POL	5286.75	5456.25	0.00	POL	4440.38	4092.19	27025.00
TCR	14996.72	12884.21	0.00	TCR	14996.72	12884.21	0.00
TCR	14996.72	12884.21	0.00	TCR	14996.72	12884.21	0.00
TCL	14996.72	12884.21	0.00	TCL	14996.72	12884.21	0.00
TCL	14996.72	12884.21	0.00	TCL	14996.72	12884.21	0.00
MCR	12014.18	9761.06	46305.00	MCR	14996.72	12884.21	0.00
MCR	14996.72	12884.21	0.00	MCR	14996.72	12884.21	0.00
MCL	14996.72	12884.21	0.00	MCL	12014.18	9761.06	46305.00
MCL	14996.72	12884.21	0.00	MCL	14996.72	12884.21	0.00
BCR	14996.72	12884.21	0.00	BCR	14996.72	12884.21	0.00
BCR	14996.72	12884.21	0.00	BCR	14996.72	12884.21	0.00
BCL	14996.72	12884.21	0.00	BCL	14996.72	12884.21	0.00
BCL	14996.72	12884.21	0.00	BCL	14996.72	12884.21	0.00

Broken ( GSW and Middle Conductor)				Broken ( OPGW and Middle Conductor)			
Join Label	Vertical Load/(N)	Transverse Load /(N)	Longitudinal Load /(N)	Join Label	Vertical Load/(N)	Transverse Load /(N)	Longitudinal Load /(N)
PGR	4440.38	3191.91	23663.75	PGR	5286.75	5456.25	0.00
POL	5286.75	5456.25	0.00	POL	4440.38	4092.19	27025.00
TCR	14996.72	12884.21	0.00	TCR	14996.72	12884.21	0.00
TCR	14996.72	12884.21	0.00	TCR	14996.72	12884.21	0.00
TCL	14996.72	12884.21	0.00	TCL	14996.72	12884.21	0.00
TCL	14996.72	12884.21	0.00	TCL	14996.72	12884.21	0.00
MCR	12014.18	9761.06	46305.00	MCR	14996.72	12884.21	0.00
MCR	14996.72	12884.21	0.00	MCR	14996.72	12884.21	0.00
MCL	14996.72	12884.21	0.00	MCL	12014.18	9761.06	46305.00
MCL	14996.72	12884.21	0.00	MCL	14996.72	12884.21	0.00
BCR	14996.72	12884.21	0.00	BCR	14996.72	12884.21	0.00
BCR	14996.72	12884.21	0.00	BCR	14996.72	12884.21	0.00
BCL	14996.72	12884.21	0.00	BCL	14996.72	12884.21	0.00
BCL	14996.72	12884.21	0.00	BCL	14996.72	12884.21	0.00

Broken ( GSW and Bottom Conductor)				Broken ( OPGW and Bottom Conductor)			
Join Label	Vertical Load/(N)	Transverse Load /(N)	Longitudinal Load /(N)	Join Label	Vertical Load/(N)	Transverse Load /(N)	Longitudinal Load /(N)
PGR	4440.38	3191.91	23663.75	PGR	5286.75	5456.25	0.00
POL	5286.75	5456.25	0.00	POL	4440.38	4092.19	27025.00
TCR	14996.72	12884.21	0.00	TCR	14996.72	12884.21	0.00
TCR	14996.72	12884.21	0.00	TCR	14996.72	12884.21	0.00
TCL	14996.72	12884.21	0.00	TCL	14996.72	12884.21	0.00
TCL	14996.72	12884.21	0.00	TCL	14996.72	12884.21	0.00
MCR	14996.72	12884.21	0.00	MCR	14996.72	12884.21	0.00
MCR	14996.72	12884.21	0.00	MCR	14996.72	12884.21	0.00
MCL	14996.72	12884.21	0.00	MCL	14996.72	12884.21	0.00
MCL	14996.72	12884.21	0.00	MCL	14996.72	12884.21	0.00
BCR	12014.18	9761.06	46305.00	BCR	14996.72	12884.21	0.00
BCR	14996.72	12884.21	0.00	BCR	14996.72	12884.21	0.00
BCL	14996.72	12884.21	0.00	BCL	12014.18	9761.06	46305
BCL	14996.72	12884.21	0.00	BCL	14996.72	12884.21	0.00

Broken (Top and Bottom Conductor)				Broken (Top and Bottom Conductor)			
Join Label	Vertical Load/(N)	Transverse Load /(N)	Longitudinal Load /(N)	Join Label	Vertical Load/(N)	Transverse Load /(N)	Longitudinal Load /(N)
PGR	5286.75	5456.25	0.00	PGR	5286.75	5456.25	0.00
POL	5286.75	5456.25	0.00	POL	5286.75	5456.25	0.00
TCR	12014.18	9761.06	46305	TCR	14996.72	12884.21	0.00
TCR	14996.72	12884.21	0.00	TCR	14996.72	12884.21	0.00
TCL	14996.72	12884.21	0.00	TCL	12014.18	9761.06	46305
TCL	14996.72	12884.21	0.00	TCL	14996.72	12884.21	0.00
MCR	12014.18	9761.06	46305	MCR	14996.72	12884.21	0.00
MCR	14996.72	12884.21	0.00	MCR	14996.72	12884.21	0.00
MCL	14996.72	12884.21	0.00	MCL	12014.18	9761.06	46305
MCL	14996.72	12884.21	0.00	MCL	14996.72	12884.21	0.00
BCR	14996.72	12884.21	0.00	BCR	14996.72	12884.21	0.00
BCR	14996.72	12884.21	0.00	BCR	14996.72	12884.21	0.00
BCL	14996.72	12884.21	0.00	BCL	14996.72	12884.21	0.00
BCL	14996.72	12884.21	0.00	BCL	14996.72	12884.21	0.00

Broken (Middle and Bottom Conductor)				Broken (Middle and Bottom Conductor)			
Join Label	Vertical Load/(N)	Transverse Load /(N)	Longitudinal Load /(N)	Join Label	Vertical Load/(N)	Transverse Load /(N)	Longitudinal Load /(N)
PGR	5286.75	5456.25	0.00	PGR	5286.75	5456.25	0.00
POL	5286.75	5456.25	0.00	POL	5286.75	5456.25	0.00
TCR	14996.72	12884.21	0.00	TCR	14996.72	12884.21	0.00
TCR	14996.72	12884.21	0.00	TCR	14996.72	12884.21	0.00
TCL	14996.72	12884.21	0.00	TCL	14996.72	12884.21	0.00
TCL	14996.72	12884.21	0.00	TCL	14996.72	12884.21	0.00
MCR	12014.18	9761.06	46305	MCR	14996.72	12884.21	0.00
MCR	14996.72	12884.21	0.00	MCR	14996.72	12884.21	0.00
MCL	14996.72	12884.21	0.00	MCL	12014.18	9761.06	46305
MCL	14996.72	12884.21	0.00	MCL	14996.72	12884.21	0.00
BCR	12014.18	9761.06	46305	BCR	14996.72	12884.21	0.00
BCR	14996.72	12884.21	0.00	BCR	14996.72	12884.21	0.00
BCL	14996.72	12884.21	0.00	BCL	12014.18	9761.06	46305
BCL	14996.72	12884.21	0.00	BCL	14996.72	12884.21	0.00

Broken ( Top and Bottom Conductor)				Broken ( Top and Bottom Conductor)			
Join Label	Vertical Load/(N)	Transverse Load /(N)	Longitudinal Load /(N)	Join Label	Vertical Load/(N)	Transverse Load /(N)	Longitudinal Load /(N)
PGR	5286.75	5456.25	0.00	PGR	5286.75	5456.25	0.00
POL	5286.75	5456.25	0.00	POL	5286.75	5456.25	0.00
TCR	12014.18	9761.06	46305	TCR	14996.72	12884.21	0.00
TCR	14996.72	12884.21	0.00	TCR	14996.72	12884.21	0.00
TCL	14996.72	12884.21	0.00	TCL	12014.18	9761.06	46305
TCL	14996.72	12884.21	0.00	TCL	14996.72	12884.21	0.00
MCR	14996.72	12884.21	0.00	MCR	14996.72	12884.21	0.00
MCR	14996.72	12884.21	0.00	MCR	14996.72	12884.21	0.00
MCL	14996.72	12884.21	0.00	MCL	14996.72	12884.21	0.00
MCL	14996.72	12884.21	0.00	MCL	14996.72	12884.21	0.00
BCR	12014.18	9761.06	46305	BCR	14996.72	12884.21	0.00
BCR	14996.72	12884.21	0.00	BCR	14996.72	12884.21	0.00
BCL	14996.72	12884.21	0.00	BCL	12014.18	9761.06	46305
BCL	14996.72	12884.21	0.00	BCL	14996.72	12884.21	0.00



University of Moratuwa, Sri Lanka.  
 Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

## APPENDIX V : Sample of Tower Simulation Report

Note: Only Three pages of 645pages simulation report are attached.

```
*****\par
*
* TOWER - Analysis and Design - Copyright Power Line Systems, Inc. 1986-2013 *\par
*
*****\par
\par
Project Name: MCs\par
Project Notes: Tower\par
Project File: H:\\ACSR ZEBRA\\TD1\\+6M TD1.tow\par
Date run      : 3:12:57 PM Thursday, March 10, 2016\par
by           : Tower Version 13.20\par
Licensed to: Ceylon Electricity Board - Transmission Design\par
\par
Successfully performed linear analysis\par
}\par
\par
Member check option: ASCE 10\par
Connection rupture check: ASCE 10\par
Crossing diagonal check: Fixed \par
Included angle check: None \par
Climbing load check: None\par
Redundant members checked with Actual Force\par
\par
University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk
\par
\b Joint      Symmetry X Coord. Y Coord. Z Coord. X Disp. Y Disp. Z Disp. X Rot. Y
Rot. Z Rot.\b0\par
\b Label      Code      (m)      (m)      (m)      Rest.      Rest.      Rest.      Rest.
Rest.      Rest.\b0\par
\b -----
-----\b0\par
1P XY-Symmetry    2.73    2.73      0   Free   Free   Free   Free   Free
Free \par
2P XY-Symmetry    1.19    1.19   10.19   Free   Free   Free   Free   Free
Free \par
3P XY-Symmetry    0.75    0.75   23.04   Free   Free   Free   Free   Free
Free \par
4P X-Symmetry      0     4.1    23.04   Free   Free   Free   Free   Free
Free \par
5P X-Symmetry      0     4.1    19.04   Free   Free   Free   Free   Free
Free \par
6P X-Symmetry      0     4.23   14.64   Free   Free   Free   Free   Free
Free \par
7P X-Symmetry      0     4.62   10.19   Free   Free   Free   Free   Free
```

```

Free \par
  1X      X-GenXY     2.73    -2.73       0   Free   Free   Free   Free   Free
Free \par
  7X      X-Gen       0     -4.62   10.19   Free   Free   Free   Free   Free
Free \par
\par
\b Secondary Joints:\b0\par
\par
\b      Joint      Symmetry Origin   End Fraction Elevation X Disp. Y Disp. Z Disp. X
Rot.  Y Rot.  Z Rot.\b0\par
\b      Label        Code  Joint Joint                   Rest.   Rest.   Rest.
Rest.  Rest.  Rest.\b0\par
\b                                         (m)                                         \b0
\par
\b -----
-----\b0\par
  30S XY-Symmetry   1P   2P       0       4   Free   Free   Free   Free
Free  Free \par
  31S XY-Symmetry   1P   2P       0       7.72  Free   Free   Free   Free
Free  Free \par
  32S XY-Symmetry   2P   3P       0      11.34  Free   Free   Free   Free
Free  Free \par
  33S XY-Symmetry   2P   3P       0      12.4   Free   Free   Free   Free
Free  Free \par
  34S XY-Symmetry   2P   3P       0      14.64  Free   Free   Free   Free
Free  Free \par
  35S XY-Symmetry   2P   3P       0      15.7   Free   Free   Free   Free
Free  Free \par
  36S XY-Symmetry   2P   3P       0      16.68  Free   Free   Free   Free
Free  Free \par
  37S XY-Symmetry   2P   3P       0      19.04  Free   Free   Free   Free
Free  Free \par
  41Y      Y-Gen     40S   40X      0.5       0   Free   Free   Free   Free
Free  Free \par
  42X      X-Gen     40S   40Y      0.5       0   Free   Free   Free   Free
Free  Free \par
  43Y      Y-Gen     38S   38X      0.5       0   Free   Free   Free   Free
Free  Free \par
  44X      X-Gen     38S   38Y      0.5       0   Free   Free   Free   Free
Free  Free \par
  45Y      Y-Gen     35S   35X      0.5       0   Free   Free   Free   Free
Free  Free \par
  46X      X-Gen     35S   35Y      0.5       0   Free   Free   Free   Free
Free  Free \par
  47Y      Y-Gen     32S   32X      0.5       0   Free   Free   Free   Free
Free  Free \par
  48X      X-Gen     32S   32Y      0.5       0   Free   Free   Free   Free
Free  Free \par

```



	49X	X-GenXY	1P	2P	0	-4.17	Free	Free	Free	Free
Free	Free	\par								
	49XY	XY-GenXY	1P	2P	0	-4.17	Free	Free	Free	Free
Free	Free	\par								
	49Y	Y-GenXY	1P	2P	0	-4.17	Free	Free	Free	Free
Free	Free	\par								
	50X	X-GenXY	1P	2P	0	-10.17	Fixed	Fixed	Fixed	Free
Fixed	Fixed	\par								
	50XY	XY-GenXY	1P	2P	0	-10.17	Fixed	Fixed	Fixed	Free
Fixed	Fixed	\par								

0i0.44E2X	X-Gen	30S	1Y	0.4377	0	Free	Free	Free	Free
-----------	-------	-----	----	--------	---	------	------	------	------

Free Free \par

\par

The model contains 20 primary and 100 secondary joints for a total of 120 joints.\par

\par

\b Steel Material Properties:\b0\par

\par

\b	Steel	Modulus	Yield	Ultimate	Member	Member	Member	Member
----	-------	---------	-------	----------	--------	--------	--------	--------

Member Member\b0\par

C-LG-3	g31X	-1.074	82.478	-19.620	79.007	-16.428	12.237	7.785\par
C-LG-3	g31XY	-0.779	-82.535	17.298	-79.571	13.996	-13.001	-9.014\par
C-LG-3	g31Y	-34.625	17.268	-82.550	13.955	-79.479	-8.904	-13.036\par
D-LG-4	g32B	21.752	14.689	67.094	21.931	61.341	6.802	10.380\par
D-LG-4	g32X	0.593	67.540	-14.150	64.876	11.503	10.837	7.375\par
D-LG-4	g32XY	0.811	-67.402	15.872	-64.460	13.330	-10.152	-6.454\par
D-LG-4	g32Y	26.672	16.887	66.395	14.355	-63.538	-5.574	-9.155\par
D-LG-4	g32BP	-28.189	7.544	-74.966	7.454	-61.455	-10.359	-22.780\par
D-LG-4	g32BX	-3.332	-75.859	6.644	-62.261	6.544	-23.660	-11.122\par

D

\par

\*\*\* Weight of structure (N)\par

Weight of Angles\*Section DLF: 50857.9\par

Weight of Suspensions: 16600.0\par

Total: 67457.9\par

\par

\par

\*\*\* End of Report\par

\par

## APPENDIX VI: Profile Design Summary Report

PLS-CADD Version 9.20 7:49:01 AM Sunday, March 27, 2016  
 Project Name: 'D:\Academic\MSC\2nd year\Profile Design\Flat\paddy\ACSR\flat  
 paddy.DON'

### Structure List Report

Struct.	Station	Line	Ahead	Height	Offset	Orient
Name/Description/Comments/Material	Number	Angle	Span	Adjust	Adjust	Angle
	(m)	(deg)	(m)	(m)	(m)	(deg)
<hr/>						
	1	0.00	0.00	361.35	0.00	0.00
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl+03m						
					TDL+03	
						embed len=0.30
	2	361.35	0.00	329.95	0.00	0.00
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl+09m						
					TDL+09	
						embed len=0.30
	3	691.30	0.00	322.21	0.00	0.00
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl+00m						
					TDL+00	
 University of Moratuwa, Sri Lanka. Electronic Theses & Dissertations www.lib.mrt.ac.lk	4	1013.51	0.00	336.63	0.00	0.00
					TDL+00	
						embed len=0.30
	5	1350.14	0.00	361.04	0.00	0.00
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl+09m						
					TDL+00	
						embed len=0.30
	6	1711.18	0.00	349.81	0.00	0.00
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl+03m						
					TDL+09	
						embed len=0.30
	7	2060.99	0.00	315.88	0.00	0.00
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl+03m						
					TDL+03	
						embed len=0.30
	8	2376.87	0.00	371.88	0.00	0.00
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl+03m						
					TDL+03	
						embed len=0.30
	9	2748.75	0.00	344.75	0.00	0.00
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl+00m						

							TDL+00
							embed len=0.30
10	3093.50	29.55	303.52	0.00	0.00	0.00	d:\academic\msc\2nd year\profile design\flat\paddy\acsr\td3\td3+03m
							TD3+03
							embed len=0.30
11	3397.02	0.00	268.59	0.00	0.00	0.00	d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl-03m
							TDL-03
							embed len=0.30
12	3665.61	-27.25	327.73	0.00	0.00	0.00	d:\academic\msc\2nd year\profile design\flat\paddy\acsr\td3\td3+06m
							TD3+06
							embed len=0.30
13	3993.34	0.00	322.99	0.00	0.00	0.00	d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl+00m
							TDL+00
							embed len=0.30
14	4316.33	0.00	323.79	0.00	0.00	0.00	d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl+06m
							TD3+06
							embed len=0.30
15	4640.12	0.00	316.40	0.00	0.00	0.00	d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl+00m
							TDL+06
							embed len=0.30
16	4956.52	0.00	331.77	0.00	0.00	0.00	d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl+03m
							TD1+00
							embed len=0.30
17	5288.29	0.00	318.24	0.00	0.00	0.00	d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl+00m
							TDL+03
							embed len=0.30
18	5606.53	0.00	338.76	0.00	0.00	0.00	d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl+03m
							TD3+03
							embed len=0.30
19	5945.29	0.00	295.82	0.00	0.00	0.00	d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl+00m
							TDL+00
							embed len=0.30
20	6241.11	0.00	0.00	0.00	0.00	0.00	d:\academic\msc\2nd year\profile design\flat\paddy\acsr\tdl\tdl-03m
							TD1-03
							embed len=0.30



## Structure Coordinates Report

Struct. Number	Station	Ahead	X	Y	Z Structure
			Span (m)	(m)	Name (m)
1	0.00	361.35	261408.32	256824.92	161.62 tdl+03m
2	361.35	329.95	261675.56	257068.13	152.21 tdl+09m
3	691.30	322.21	261919.59	257290.21	149.28 tdl+00m
4	1013.51	336.63	262157.88	257507.09	149.49 tdl+00m
5	1350.14	361.04	262406.85	257733.66	142.84 tdl+09m
6	1711.18	349.81	262673.86	257976.67	140.49 tdl+03m
7	2060.99	315.88	262932.57	258212.12	139.91 tdl+03m
8	2376.87	371.88	263166.19	258424.73	138.66 tdl+03m
9	2748.75	344.75	263441.22	258675.03	141.08 tdl+00m
10	3093.50	303.52	263696.19	258907.08	139.39 td3+03m
11	3397.02	268.59	263992.22	258974.08	134.02 tdl-03m
12	3665.61	327.73	264254.19	259033.37	132.45 td3+06m
13	3993.34	322.99	264505.25	259244.03	131.18 tdl+00m
14	4316.33	323.79	264752.68	259451.63	130.76 tdl+06m
15	4640.12	316.40	265000.72	259659.75	130.25 tdl+00m
16	4956.52	331.77	265243.10	259863.13	130.90 tdl+03m
17	5288.29	318.24	265497.26	260076.38	131.05 tdl+00m
18	5606.53	338.76	265741.05	260280.93	130.98 tdl+03m
19	5945.29	295.82	266000.56	260498.68	130.22 tdl+00m
20	6241.11	0.00	266227.18	260688.82	138.17 tdl+03m



Structure Attachment Coordinates [www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

Coordinates are for weather case 'MaxTemp-NoWind', Initial RS, wind from the left

```

Struct. Set PhaseStructure      Set -----Insulator----- | -----Wire-----
---- | -----Mid----- | -----Low----- | -----TIN Z below-----
|
Number No.   No.     Name   Label -----Attach----- | -----Attach-----
---- | -----Span----- | -----Point----- | Insulator Mid   Low
|
|                               -----Point----- | -----Point-----
---- | -----Point----- | | Attach   Span   Point
|
|                               x           y           z |           x           y
z |           x           y           z |           x           y           z | ---Point-----
|                               (m)----- | -----(m)----- | -----(m)-----
---- | -----(m)----- | -----(m)----- | -----(m)-----
|
-----
```

1	3	1	tdl+03m	P1-R	261412.17	256820.69	191.33	261414.97	256823.24
190.89		261547.02	256943.76	179.76	261558.57	256954.30	179.68	0.00	0.00
6.80	154.59	265874.28	260385.66	144.15	265888.51	260397.60	144.05	0.00	0.00
		3			265744.78	260276.49	150.89	265744.78	260276.49
148.79		265874.54	260385.35	138.35	265888.77	260397.29	138.25	0.00	0.00
19	3	1	tdl+00m	P1-R	266003.90	260494.69	158.68	266003.91	260494.68
156.58		266115.93	260588.34	152.68	266094.34	260570.29	152.44	0.00	0.00
		2			266004.03	260494.54	152.93	266004.04	260494.53
150.83		266116.07	260588.17	146.85	266095.13	260570.67	146.63	0.00	0.00
		3			266004.29	260494.23	147.13	266004.30	260494.21
145.03		266116.39	260587.79	140.95	266096.31	260571.03	140.75	0.00	0.00

#### Section Sagging Data

Sec.      Cable    From      To    Voltage    Ruling -----Sagging Data-----

Display

No.	File	Str.	Str.	Span	Condition	Temp.	Catenary	Horiz.
-----	------	------	------	------	-----------	-------	----------	--------

Catenary

Name	Constant	Tension
------	----------	---------

Constant

(m)	(kV)	(m)	(deg C)	(m)	(N)
-----	------	-----	---------	-----	-----

(m)

---

---	1	zebra.dat	10	132	344.9	Creep RS	32.0	1785.6	28554.9	
1488.3										
	2	zebra.dat	10	132	287.1	Creep RS	32.0	1785.6	28554.9	
1412.2										
	3	zebra.dat	12	20	132	322.8	Creep RS	32.0	1785.6	28554.9
1461.6										

---

#### Section Stringing Data

Section      CableStruct.      Set    Phasing Set

Number	Name	Number	Number	Label
--------	------	--------	--------	-------

---

1	zebra.dat	1	3	123 P1-R
		2	3	123 P1-R
		3	3	123 P1-R
		4	3	123 P1-R
		5	3	123 P1-R
		6	3	123 P1-R
		7	3	123 P1-R
		8	3	123 P1-R
		9	3	123 P1-R
		10	3	123 P1-R
2	zebra.dat	10	3	123 P1-R

---

	11	3	123 P1-R
	12	3	123 P1-R
3 zebra.dat	12	3	123 P1-R
	13	3	123 P1-R
	14	3	123 P1-R
	15	3	123 P1-R
	16	3	123 P1-R
	17	3	123 P1-R
	18	3	123 P1-R
	19	3	123 P1-R

#### Section Geometry Data

Notes: Lengths are arc lengths along the wire at 32 (deg C), Initial.

Lengths are adjusted for the number of phases, the number of conductors and the length of strain insulators..

Sec. No.	Cable File Name	From Str. Name	To Str. Number	Number of Phases	Wires Per Phase	Min. Span	Max. Span	Ruling Span	Total Cable Length (m)
<hr/>									
1 zebra.dat		1	10	3	1	315.9	371.9	344.9	9263.9
2 zebra.dat		10	12	3	1	270.2	301.7	287.1	1694.5
3 zebra.dat		12	20	3	1	255.8	301.8	288.8	7716.9

#### Structure Material List Report

Structure File Name

University of Moratuwa, Sri Lanka

Electronic Theses & Dissertations

www.lib.mrt.ac.lk

Count

d:\academic\msc\2nd year\profile design\flat\paddy\acsr\td1\td1+03m	1
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\td1\td1-03m	1
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\td3\td3+03m	1
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\td3\td3+06m	1
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\td1\td1+00m	7
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\td1\td1+03m	5
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\td1\td1+06m	1
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\td1\td1+09m	2
d:\academic\msc\2nd year\profile design\flat\paddy\acsr\td1\td1-03m	1
Total number of structures =	20

#### Cable Material List Report

Notes: Lengths are arc lengths along the wire at 32 (deg C), Initial.

Lengths are adjusted for the number of phases, the number of conductors and the length of strain insulators.

Cable	Number
Cable Length	

## APPENDIX VII : Material Schedules of Transmission Lines

### Non Populated Flat Terrain

	Description	Unit	ACSR	ACCC	ZTACIR /AW	ACSS/TW	ACCR	GTACSR	LL- ACSR/ AS	LL- TACSR/ AS
<b>Supply of Conductors including joints and jumper leads</b>										
	400 mm <sup>2</sup> Zebra 61/3.18 mm ACSR conductor (Including mid span joints) units	km	37.4	37.4	37.4	37.4	37.4	37.4	37.4	37.4
	7/3.25 MM Galvanized earth wire including mid span units	km	6.2	6.2	6.2	6.2	6.2	6.2	6.2	6.2
	OPGW Conductors and OPGW Accessories	km	6.2	6.2	6.2	6.2	6.2	6.2	6.2	6.2
<b>Supply of Damping System (Vibration dampers)</b>										
	Vibration dampers for 400 mm <sup>2</sup> Zebra (61/3.18 mm) conductor	Nos	450	450	462	462	450	450	450	450
	Vibration dampers for OPGW	Nos	76	76	76	76	76	76	76	76
	Vibration dampers for GSW	Nos	75	75	77	77	75	75	75	75
<b>Supply of Insulator sets</b>										
	Normal suspension insulator sets for 400 mm <sup>2</sup> ACSR conductor	Nos	96	96	96	96	96	96	96	96
	Normal tension insulator sets for 400 mm <sup>2</sup> ACSR conductor	Nos	48	48	48	48	48	48	48	48
	Jumper suspension insulator sets	Nos	0	0	0	0	0	0	0	0
	Light duty tension insulator sets for 400 mm <sup>2</sup> ACSR conductor	Nos	12	12	12	12	12	12	12	12
<b>Supply of self-supporting towers and extended towers of the suspension type complete with all fittings</b>										
	Type TDL towers with -3m extension	Nos	1	1	1	1	1	1	2	2
	Type TDL towers with ± 0m extension	Nos	7	5	6	5	7	7	6	6
	Type TDL towers with +3m extension	Nos	8	6	6	6	5	4	5	6
	Type TD1 towers with +6m extension	Nos	1	0	1	3	2	2	3	2
	Type TDL towers with +9m extension	Nos	2	0	2	2	1	1	0	0
	Type TDL towers with +12m extension	Nos	0	0	0	0	0	0	0	0
<b>Supply of self-supporting towers and extended towers of the Tension (TD1) type complete with all fittings</b>										
	Type TD1 towers with -3m extension	Nos	1	1	1	1	1	1	1	1
	Type TD1 towers with ± 0m extension	Nos	0	1	0	0	0	0	0	0
	Type TD1 towers with +3m extension	Nos	2	1	2	1	2	2	2	2
	Type TD1 towers with +6m extension	Nos	0	0	0	0	0	0	0	0
	Type TD1 towers with +9m extension	Nos	0	0	0	0	0	0	0	0
	Type TD1 towers with +12m extension	Nos	0	0	0	0	0	0	0	0
<b>Supply of self-supporting towers and extended towers of the Tension (TD3) type complete with all fittings</b>										
	Type TD3 towers with -3m extension	Nos	0	0	0	0	0	0	0	0
	Type TD3 towers with ± 0m extension	Nos	0	0	0	1	0	0	0	0
	Type TD3 towers with +3m extension	Nos	0	1	0	1	0	0	0	0
	Type TD3 towers with +6m extension	Nos	1	0	1	0	1	1	1	1
	Type TD3 towers with +9m extension	Nos	0	0	0	0	0	0	0	0
	Type TD3 towers with +12m extension	Nos	0	0	0	0	0	0	0	0
<b>CIVIL WORKS</b>										
<b>Foundation complete for TDL towers and all extensions</b>										
	Foundation type 3	Nos	16	16	16	16	16	16	16	16
	Foundation type 4A	Nos	0	0	0	0	0	0	0	0
<b>Foundation complete for TD1 towers and all extensions</b>										
	Foundation type 3	Nos	3	3	3	2	3	3	3	3
	Foundation type 4A	Nos	0	0	0	0	0	0	0	0
<b>Foundation complete for TD3 towers and all extensions</b>										
	Foundation type 3	Nos	1	1	1	2	1	1	1	1
	Foundation type 4A	Nos	0	0	0	0	0	0	0	0

Survey									
Preliminary Survey *	km	6.2	6.2	6.2	6.2	6.2	6.2	6.2	6.2
Profile Survey	km	6.2	6.2	6.2	6.2	6.2	6.2	6.2	6.2
<b>TOTAL</b>									
<b>INSTALLATIONS</b>									
<b>Erection of self-supporting towers and extended towers of the suspension type complete with all fittings &amp; including Earthing System</b>									
Type TDL towers with ± 0m extension	Nos	1	9	1	0	1	2	2	2
Type TDL towers with -3m extension	Nos	7	5	6	5	7	7	6	6
Type TDL towers with +3m extension	Nos	5	2	6	6	5	4	5	6
Type TDL towers with +6m extension	Nos	1	0	1	3	2	2	3	2
Type TDL towers with +9m extension	Nos	2	0	2	2	1	1	0	0
Type TDL towers with +12m extension	Nos	0	0	0	0	0	0	0	0
<b>Erection of self-supporting towers and extended towers of the Tension (TD1) type complete with all fittings including Earthing System</b>									
Type TD1 towers with ± 0m extension	Nos	1	1	1	1	1	1	1	1
Type TD1 towers with -3m extension	Nos	0	1	0	0	0	0	0	0
Type TD1 towers with +3m extension	Nos	2	1	2	1	2	2	2	2
Type TD1 towers with +6m extension	Nos	0	0	0	0	0	0	0	0
Type TD1 towers with +9m extension	Nos	0	0	0	0	0	0	0	0
Type TD1 towers with +12m extension	Nos	0	0	0	0	0	0	0	0
<b>Erection of self-supporting towers and extended towers of the Tension (TD3) type complete with all fittings including Earthing System</b>									
Type TD3 towers with ± 0m extension	Nos	0	0	0	0	0	0	0	0
Type TD3 towers with -3m extension	Nos	0	0	0	1	0	0	0	0
Type TD3 towers with +3m extension	Nos	0	1	0	1	0	0	0	0
Type TD3 towers with +6m extension	Nos	1	0	1	0	1	1	1	1
Type TD3 towers with +9m extension	Nos	0	0	0	0	0	0	0	0
Type TD3 towers with +12m extension	Nos	0	0	0	0	0	0	0	0
<b>Stringing</b>	University of Moratuwa, Sri Lanka								
	km	6.2	6.2	6.2	6.2	6.2	6.2	6.2	6.2



Description	Unit	ACSR	ACCC	ZTACIR /AW	ACSS/TW	ACCR	GTACSR	LL- ACSR/AS	LL- TACSR/AS
<b>Supply of Conductors including joints and jumper leads</b>									
400 mm <sup>2</sup> Zebra 61/3.18 mm ACSR conductor (Including mid span joints) units	km	34.6	34.6	34.6	34.6	34.6	34.6	34.6	34.6
7/3.25 MM Galvanized earth wire including mid span units	km	5.8	5.8	5.8	5.8	5.8	5.8	5.8	5.8
OPGW Conductors and OPGW Accessories	km	5.8	5.8	5.8	5.8	5.8	5.8	5.8	5.8
<b>Supply of Damping System (Vibration dampers)</b>									
Vibration dampers for 400 mm <sup>2</sup> Zebra (61/3.18 mm) conductor	No	342	342	318	318	378	342	342	342
Vibration dampers for OPGW	No	70	70	66	66	74	70	70	70
Vibration dampers for GSW	No	57	57	53	53	63	57	57	57
<b>e) Supply of Insulator sets</b>									
Normal suspension insulator sets for 400 mm <sup>2</sup> ACSR conductor	No	30	30	36	36	30	30	30	30
Normal tension insulator sets for 400 mm <sup>2</sup> ACSR conductor	No	180	180	168	168	180	180	180	180
Jumper suspension insulator sets	No	6	6	6	6	6	6	6	6
Light duty tension insulator sets for 400 mm <sup>2</sup> ACSR conductor	No	12	12	12	12	12	12	12	12

<b>Supply of self-supporting towers and extended towers of the suspension type complete with all fittings</b>									
Type TDL towers with -3m extension	No	0	2	2	2	0	1	1	1
Type TDL towers with $\pm 0$ m extension	No	2	2	0	1	2	0	0	0
Type TDL towers with +3m extension	No	1	1	1	0	1	3	2	2
Type TDL towers with +6m extension	No	2	0	2	1	2	0	2	2
Type TDL towers with +9m extension	No	0	0	0	1	0	1	0	0
Type TDL towers with +12m extension	No	0	0	1	1	0	0	0	0
<b>Supply of self-supporting towers and extended towers of the Tension (TD1) type complete with all fittings</b>									
Type TD1 towers with -3m extension	No	0	1	0	0	0	0	0	0
Type TD1 towers with $\pm 0$ m extension	No	1	4	0	0	1	1	1	1
Type TD1 towers with +3m extension	No	3	0	6	6	4	4	4	4
Type TD1 towers with +6m extension	No	0	1	0	0	0	0	0	0
Type TD1 towers with +9m extension	No	0	0	0	0	1	0	0	0
Type TD1 towers with +12m extension	No	1	0	0	0	0	1	1	1
<b>Supply of self-supporting towers and extended towers of the Tension (TD3) type complete with all fittings</b>									
Type TD3 towers with -3m extension	No	0	1	0	1	1	1	1	1
Type TD3 towers with $\pm 0$ m extension	No	3	4	3	2	3	3	3	4
Type TD3 towers with +3m extension	No	3	1	2	3	1	1	1	0
Type TD3 towers with +6m extension	No	1	0	1	1	1	1	1	1
Type TD3 towers with +9m extension	No	0	0	1	0	0	0	0	0
Type TD3 towers with +12m extension	No	1	0	0	0	1	1	1	1
<b>Supply of self-supporting towers and extended towers of the Tension (TD6) type complete with all fittings</b>									
Type TD6 towers with -3m extension	No	0	1	1	1	0	2	2	2
Type TD6 towers with $\pm 0$ m extension	No	2	1	1	0	2	0	0	0
Type TD6 towers with +3m extension	No	0	0	0	1	0	0	0	0
Type TD6 towers with +6m extension	No	0	0	0	0	0	0	0	0
Type TD6 towers with +9m extension	No	0	0	0	0	0	0	0	0
Type TD6 towers with +12m extension	No	0	0	0	0	0	0	0	0
<b>CIVIL WORKS</b>									
<b>Foundation complete for TD1 towers and all extensions</b>									
Foundation type 3	No	5	5	6	6	5	5	5	5
Foundation type 4A	No	9	8	8	8	0	0	0	0
<b>Foundation complete for TD1 towers and all extensions</b>									
Foundation type 3	No	5	6	6	6	6	6	6	6
Foundation type 4A	No	0	0	0	0	0	0	0	0
<b>Foundation complete for TD3 towers and all extensions</b>									
Foundation type 3	No	8	6	7	7	7	7	7	7
Foundation type 4A	No	0	0	0	0	0	0	0	0
<b>Foundation complete for TD6 towers and all extensions</b>									
Foundation type 3	No	2	2	2	2	2	2	2	2
Foundation type 4A	No	0	0	0	0	0	0	0	0
<b>Survey</b>									
Preliminary Survey *	km	6	6	6	6	6	6	6	6
Profile Survey	km	6	6	6	6	6	6	6	6
<b>TOTAL</b>									
<b>INSTALLATIONS</b>									
<b>Erection of self-supporting towers and extended towers of the suspension type complete with all fittings &amp; including Earthing System</b>									
Type TDL towers with $\pm 0$ m extension	No	0	2	2	2	0	1	1	1
Type TDL towers with -3m extension	No	2	2	0	1	2	0	0	0
Type TDL towers with +3m extension	No	1	1	1	0	1	3	2	2
Type TDL towers with +6m extension	No	2	0	2	1	2	0	2	2
Type TDL towers with +9m extension	No	0	0	0	1	0	1	0	0
Type TDL towers with +12m extension	No	0	0	1	1	0	0	0	0

<b>Erection of self-supporting towers and extended towers of the Tension (TD1) type complete with all fittings including Earthing System</b>									
Type TD1 towers with ± 0m extension	No	0	1	0	0	0	0	0	0
Type TD1 towers with -3m extension	No	1	4	0	0	1	1	1	1
Type TD1 towers with +3m extension	No	3	0	6	6	4	4	4	4
Type TD1 towers with +6m extension	No	0	1	0	0	0	0	0	0
Type TD1 towers with +9m extension	No	0	0	0	0	1	0	0	0
Type TD1 towers with +12m extension	No	1	0	0	0	0	1	1	1
<b>Erection of self-supporting towers and extended towers of the Tension (TD3) type complete with all fittings including Earthing System</b>									
Type TD3 towers with ± 0m extension	No	0	1	0	1	1	1	1	1
Type TD3 towers with -3m extension	No	3	4	3	2	3	3	3	4
Type TD3 towers with +3m extension	No	3	1	2	3	1	1	1	0
Type TD3 towers with +6m extension	No	1	0	1	1	1	1	1	1
Type TD3 towers with +9m extension	No	0	0	1	0	0	0	0	0
Type TD3 towers with +12m extension	No	1	0	0	0	1	1	1	1
<b>Erection of self-supporting towers and extended towers of the Tension (TD6) type complete with all fittings including Earthing System</b>									
Type TD6 towers with ± 0m extension	No	0	1	1	1	0	2	2	2
Type TD6 towers with -3m extension	No	2	1	1	0	2	0	0	0
Type TD6 towers with +3m extension	No	0	0	0	1	0	0	0	0
Type TD6 towers with +6m extension	No	0	0	0	0	0	0	0	0
Type TD6 towers with +9m extension	No	0	0	0	0	0	0	0	0
Type TD6 towers with +12m extension	No	0	0	0	0	0	0	0	0
<b>Stringing</b>									
	km	5.8	5.8	5.8	5.8	5.8	5.8	5.8	5.8

**Paddy Flat Terrain**  **University of Moratuwa, Sri Lanka.**

Description	Unit	ACSR	ACCC	ZTACUR /AW	ACSS/TW	ACCR	GTCSR	LL-ACSR/AS	LL-TACSR/AS
<b>Supply of Conductors including joints and jumper leads</b>									
400 mm <sup>2</sup> Zebra 61/3.18 mm ACSR conductor (Including mid span joints) units	km	36	36	36	36	36	36	36	36
7/3.25 MM Galvanized earth wire including mid span units	km	6	6	6	6	6	6	6	6
OPGW Conductors and OPGW Accessories	km	6	6	6	6	6	6	6	6
<b>Supply of Damping System (Vibration dampers)</b>									
Vibration dampers for 400 mm <sup>2</sup> Zebra (61/3.18 mm) conductor	No	450	450	462	462	450	450	450	450
Vibration dampers for OPGW	No	76	76	76	76	76	76	76	76
Vibration dampers for GSW	No	75	75	77	77	75	75	75	75
<b>Supply of Insulator sets</b>									
Normal suspension insulator sets for 400 mm <sup>2</sup> ACSR conductor	No s	96	96	96	96	96	96	96	96
Normal tension insulator sets for 400 mm <sup>2</sup> ACSR conductor	No	48	48	48	48	48	48	48	48
Jumper suspension insulator sets	No	0	0	0	0	0	0	0	0
Light duty tension insulator sets for 400 mm <sup>2</sup> ACSR conductor	No	12	12	12	12	12	12	12	12
<b>Supply of self-supporting towers and extended towers of the suspension type complete with all fittings</b>									
Type TDL towers with -3m extension	No	1	9	1	0	1	2	2	2
Type TDL towers with ± 0m extension	No	7	5	6	5	7	7	6	6
Type TDL towers with +3m extension	No	5	2	6	6	5	4	5	6
Type TDL towers with +6m extension	No	1	0	1	3	2	2	3	2

Type TDL towers with +9m extension	No	2	0	2	2	1	1	0	0
Type TDL towers with +12m extension	No	0	0	0	0	0	0	0	0
<b>Supply of self-supporting towers and extended towers of the Tension (TD1) type complete with all fittings</b>									
Type TD1 towers with -3m extension	No s	1	1	1	1	1	1	1	1
Type TD1 towers with ± 0m extension	No	0	1	0	0	0	0	0	0
Type TD1 towers with +3m extension	No	2	1	2	1	2	2	2	2
Type TD1 towers with +6m extension	No	0	0	0	0	0	0	0	0
Type TD1 towers with +9m extension	No	0	0	0	0	0	0	0	0
Type TD1 towers with +12m extension	No	0	0	0	0	0	0	0	0
<b>Supply of self-supporting towers and extended towers of the Tension (TD3) type complete with all fittings</b>									
Type TD3 towers with -3m extension	No	0	0	0	0	0	0	0	0
Type TD3 towers with ± 0m extension	No	0	0	0	1	0	0	0	0
Type TD3 towers with +3m extension	No	0	1	0	1	0	0	0	0
Type TD3 towers with +6m extension	No	1	0	1	0	1	1	1	1
Type TD3 towers with +9m extension	No	0	0	0	0	0	0	0	0
Type TD3 towers with +12m extension	No	0	0	0	0	0	0	0	0
<b>CIVIL WORKS</b>									
<b>Foundation complete for TDL towers and all extensions</b>									
Foundation type 3	No	0	0	0	0	0	0	0	0
Foundation type 4A	No	16	16	16	16	16	16	16	16
<b>Foundation complete for TD1 towers and all extensions</b>									
Foundation type 3	No	0	0	0	0	0	0	0	0
Foundation type 4A	No	3	3	3	2	3	3	3	3
<b>Foundation complete for TD3 towers and all extensions</b>									
Foundation type 3	No	0	0	0	0	0	0	0	0
Foundation type 4A	No	1	1	1	2	1	1	1	1
<b>Survey</b>									
Preliminary Survey *	km	6	6	6	6	6	6	6	6
Profile Survey	km	6	6	6	6	6	6	6	6
<b>TOTAL</b>									
<b>INSTALLATIONS</b>									
<b>University of Moratuwa, Sri Lanka.</b>									
<b>Electronic Theses &amp; Dissertations</b>									
<b>Erection of self-supporting towers and extended towers of the suspension type complete with all fittings &amp; including Earthing System</b>									
Type TDL towers with ± 0m extension	No	1	9	1	0	1	2	2	2
Type TDL towers with -3m extension	No	7	5	6	5	7	7	6	6
Type TDL towers with +3m extension	Ns	5	2	6	6	5	4	5	6
Type TDL towers with +6m extension	No	1	0	1	3	2	2	3	2
Type TDL towers with +9m extension	No	2	0	2	2	1	1	0	0
Type TDL towers with +12m extension	No	0	0	0	0	0	0	0	0
<b>Erection of self-supporting towers and extended towers of the Tension (TD1) type complete with all fittings including Earthing System</b>									
Type TD1 towers with ± 0m extension	No	1	1	1	1	1	1	1	1
Type TD1 towers with -3m extension	No	0	1	0	0	0	0	0	0
Type TD1 towers with +3m extension	No	2	1	2	1	2	2	2	2
Type TD1 towers with +6m extension	No	0	0	0	0	0	0	0	0
Type TD1 towers with +9m extension	No	0	0	0	0	0	0	0	0
Type TD1 towers with +12m extension	No	0	0	0	0	0	0	0	0
<b>Erection of self-supporting towers and extended towers of the Tension (TD3) type complete with all fittings including Earthing System</b>									
Type TD3 towers with ± 0m extension	No	0	0	0	0	0	0	0	0
Type TD3 towers with -3m extension	No	0	0	0	1	0	0	0	0
Type TD3 towers with +3m extension	No	0	1	0	1	0	0	0	0
Type TD3 towers with +6m extension	No	1	0	1	0	1	1	1	1
Type TD3 towers with +9m extension	No	0	0	0	0	0	0	0	0
Type TD3 towers with +12m extension	No	0	0	0	0	0	0	0	0
<b>Stringing</b>									
	km	6	6	6	6	6	6	6	6

## Non Populated Hilly Terrain

	Description	Unit	ACSR	ACCC	ZTACIR /AW	ACSS/TW	ACCR	GTACSR	LL- ACSR/ AS	LL- TACSR/ AS
<b>Supply of Conductors including joints and jumper leads</b>										
400 mm <sup>2</sup> Zebra 61/3.18 mm ACSR conductor (Including mid span joints) units	km	36.6	36.6	36.6	36.6	36.6	36.6	36.6	36.6	36.6
7/3.25 MM Galvanized earth wire including mid span units	km	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1
OPGW Conductors and OPGW Accessories	km	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1
<b>Supply of Damping System (Vibration dampers)</b>										
Vibration dampers for 400 mm <sup>2</sup> Zebra (61/3.18 mm) conductor	Nos	336	348	336	336	336	336	348	336	336
Vibration dampers for OPGW	Nos	64	64	64	66	64	64	64	64	64
Vibration dampers for GSW	Nos	56	58	56	56	56	56	58	56	56
<b>Supply of Insulator sets</b>										
Normal suspension insulator sets for 400 mm <sup>2</sup> ACSR conductor	Nos	12	12	12	12	12	12	12	12	6
Normal tension insulator sets for 400 mm <sup>2</sup> ACSR conductor	Nos	204	204	204	204	204	204	204	204	216
Jumper suspension insulator sets	Nos	6	6	6	6	6	6	6	6	6
Light duty tension insulator sets for 400 mm <sup>2</sup> ACSR conductor	Nos	12	12	12	12	12	12	12	12	12
<b>Supply of self-supporting towers and extended towers of the suspension type complete with all fittings</b>										
Type TDL towers with -3m extension	Nos	0	1	0	0	1	1	1	1	1
Type TDL towers with ± 0m extension	Nos	1	1	1	0	0	0	0	0	1
Type TDL towers with +3m extension	Nos	1	0	1	1	0	1	1	0	0
Type TDL towers with +6m extension	Nos	0	0	0	1	0	0	0	0	0
Type TDL towers with +9m extension	Nos	0	0	0	0	0	0	0	0	0
Type TDL towers with +12m extension	Nos	0	0	0	0	0	0	0	0	0
<b>Supply of self-supporting towers and extended towers of the Tension (TD1) type complete with all fittings</b>										
Type TD1 towers with -3m extension	Nos	1	3	1	0	0	1	0	0	1
Type TD1 towers with ± 0m extension	Nos	0	2	0	1	2	1	2	1	1
Type TD1 towers with +3m extension	Nos	3	0	3	1	1	3	1	3	3
Type TD1 towers with +6m extension	Nos	2	2	1	2	2	1	2	1	1
Type TD1 towers with +9m extension	Nos	1	1	1	0	2	2	2	2	2
Type TD1 towers with +12m extension	Nos	4	3	5	7	4	3	4	3	3
<b>Supply of self-supporting towers and extended towers of the Tension (TD3) type complete with all fittings</b>										
Type TD3 towers with -3m extension	Nos	1	2	1	0	1	1	1	1	1
Type TD3 towers with ± 0m extension	Nos	2	2	3	2	3	2	3	3	3
Type TD3 towers with +3m extension	Nos	1	0	0	1	0	1	0	0	0
Type TD3 towers with +6m extension	Nos	0	0	0	0	0	0	0	0	0
Type TD3 towers with +9m extension	Nos	0	0	0	1	0	0	0	0	0
Type TD3 towers with +12m extension	Nos	0	0	0	0	0	0	0	0	0
<b>Supply of self-supporting towers and extended towers of the Tension (TD6) type complete with all fittings</b>										
Type TD6 towers with -3m extension	Nos	1	1	0	0	1	1	1	1	1
Type TD6 towers with ± 0m extension	Nos	0	0	1	1	0	0	0	0	0
Type TD6 towers with +3m extension	Nos	0	1	1	0	1	1	1	1	0
Type TD6 towers with +6m extension	Nos	1	0	0	1	0	0	0	0	1
Type TD6 towers with +9m extension	Nos	0	0	0	0	0	0	0	0	0
Type TD6 towers with +12m extension	Nos	0	0	0	0	0	0	0	0	0
Type TDT towers with +12m extension(TDT + 12)	Nos	0	0	0	0	0	0	0	0	0

<b>CIVIL WORKS</b>									
<b>Foundation complete for TDL towers and all extensions</b>									
	Foundation type 3	Nos	2	2	2	2	2	2	2
	Foundation type 4A	Nos	0	0	0	0	0	0	0
<b>Foundation complete for TD1 towers and all extensions</b>									
	Foundation type 3	Nos	11	11	11	11	11	11	11
	Foundation type 4A	Nos	0	0	0	0	0	0	0
<b>Foundation complete for TD3 towers and all extensions</b>									
	Foundation type 3	Nos	4	4	4	4	4	4	4
	Foundation type 4A	Nos	0	0	0	0	0	0	0
<b>Foundation complete for TD6 towers and all extensions</b>									
	Foundation type 3	Nos	2	2	2	2	2	2	2
	Foundation type 4A	Nos	0	0	0	0	0	0	0
<b>Survey</b>									
	Preliminary Survey	km	6	6	6	6	6	6	6
	Profile Survey	km	6	6	6	6	6	6	6
<b>TOTAL</b>									
<b>INSTALLATIONS</b>									
<b>Erection of self-supporting towers and extended towers of the suspension type complete with all fittings &amp; including Earthing System</b>									
	Type TDL towers with $\pm 0$ m extension	Nos	0	1	0	0	1	1	1
	Type TDL towers with -3m extension	Nos	1	1	1	0	0	0	0
	Type TDL towers with +3m extension	Nos	1	0	1	1	0	1	0
	Type TDL towers with +6m extension	Nos	0	0	0	1	1	0	0
	Type TDL towers with +9m extension	Nos	0	0	0	0	0	0	0
	Type TDL towers with +12m extension	Nos	0	0	0	0	0	0	0
<b>Erection of self-supporting towers and extended towers of the Tension (TD1) type complete with all fittings including Earthing System</b>									
	Type TD1 towers with $\pm 0$ m extension	Nos	1	3	1	0	0	1	0
	Type TD1 towers with -3m extension	Nos	2	2	1	1	1	2	1
	Type TD1 towers with +3m extension	Nos	3	0	3	1	1	3	1
	Type TD1 towers with +6m extension	Nos	2	2	2	1	1	2	1
	Type TD1 towers with +9m extension	Nos	1	1	1	0	2	2	2
	Type TD1 towers with +12m extension	Nos	4	3	5	7	4	3	3
<b>Erection of self-supporting towers and extended towers of the Tension (TD3) type complete with all fittings including Earthing System</b>									
	Type TD3 towers with $\pm 0$ m extension	Nos	1	2	1	0	1	1	1
	Type TD3 towers with -3m extension	Nos	2	2	3	2	3	2	3
	Type TD3 towers with +3m extension	Nos	1	0	0	1	0	1	0
	Type TD3 towers with +6m extension	Nos	0	0	0	0	0	0	0
	Type TD3 towers with +9m extension	Nos	0	0	0	1	0	0	0
	Type TD3 towers with +12m extension	Nos	0	0	0	0	0	0	0
<b>Erection of self-supporting towers and extended towers of the Tension (TD6) type complete with all fittings including Earthing System</b>									
	Type TD6 towers with $\pm 0$ m extension	Nos	1	1	0	0	1	1	1
	Type TD6 towers with -3m extension	Nos	0	0	1	1	0	0	0
	Type TD6 towers with +3m extension	Nos	0	1	1	0	1	1	0
	Type TD6 towers with +6m extension	Nos	1	0	0	1	0	0	1
	Type TD6 towers with +9m extension	Nos	0	0	0	0	0	0	0
	Type TD6 towers with +12m extension	Nos	0	0	0	0	0	0	0
<b>Stringing</b>									
		km	6.1	6.1	6.1	6.1	6.1	6.1	6.1

## Hilly Populated Hilly Terrain


	Description	Unit	ACSR	ACCC	ZTACIR /AW	ACSS/TW	ACCR	GTACSR	LL- ACSR/ AS	LL- TACSR/ AS
<b>Supply of Conductors including joints and jumper leads</b>										
	400 mm <sup>2</sup> Zebra 61/3.18 mm ACSR conductor (Including mid span joints) units	km	34.6	34.6	34.6	34.6	34.6	34.6	34.6	34.6
	7/3.25 MM Galvanized earth wire including mid span units	km	5.8	5.8	5.8	5.8	5.8	5.8	5.8	5.8
	OPGW Conductors and OPGW Accessories	km	5.8	5.8	5.8	5.8	5.8	5.8	5.8	5.8
<b>Supply of Damping System (Vibration dampers)</b>										
	Vibration dampers for 400 mm <sup>2</sup> Zebra (61/3.18 mm) conductor	Nos	336	336	336	342	342	336	354	336
	Vibration dampers for OPGW	Nos	64	66	64	64	64	64	64	64
	Vibration dampers for GSW	Nos	56	56	56	57	57	56	59	56
<b>Supply of Insulator sets</b>										
	Normal suspension insulator sets for 400 mm <sup>2</sup> ACSR conductor	Nos	6	6	6	6	12	6	6	6
	Normal tension insulator sets for 400 mm <sup>2</sup> ACSR conductor	Nos	216	216	216	216	204	216	228	216
	Jumper suspension insulator sets	Nos	6	6	6	6	6	6	6	6
	Light duty tension insulator sets for 400 mm <sup>2</sup> ACSR conductor	Nos	12	12	12	12	12	12	12	12
<b>Supply of self-supporting towers and extended towers of the suspension type complete with all fittings</b>										
	Type TDL towers with -3m extension	Nos	0	0	0	0	1	0	0	1
	Type TDL towers with ± 0m extension	Nos	1	1	0	0	0	1	1	0
	Type TDL towers with +3m extension	Nos	0	0	0	1	0	0	0	0
	Type TDL towers with +6m extension	Nos	0	0	0	0	1	0	0	0
	Type TDL towers with +9m extension	Nos	0	0	0	0	0	0	0	0
	Type TDL towers with +12m extension	Nos	0	0	0	0	0	0	0	0
<b>Supply of self-supporting towers and extended towers of the Tension (TD1) type complete with all fittings</b>										
	Type TD1 towers with -3m extension	Nos	0	1	0	0	2	0	0	0
	Type TD1 towers with ± 0m extension	No	1	2	1	0	1	2	1	2
	Type TD1 towers with +3m extension	Nos	1	1	1	1	1	3	3	1
	Type TD1 towers with +6m extension	Nos	3	1	3	1	1	0	2	2
	Type TD1 towers with +9m extension	Nos	3	2	2	3	1	3	3	2
	Type TD1 towers with +12m extension	Nos	3	4	5	7	5	4	4	5
<b>Supply of self-supporting towers and extended towers of the Tension (TD3) type complete with all fittings</b>										
	Type TD3 towers with -3m extension	Nos	1	4	1	0	2	1	1	1
	Type TD3 towers with ± 0m extension	Nos	1	0	1	1	1	2	1	1
	Type TD3 towers with +3m extension	Nos	1	1	1	1	0	1	2	2
	Type TD3 towers with +6m extension	Nos	1	0	1	1	1	0	0	0
	Type TD3 towers with +9m extension	Nos	0	0	0	0	0	0	0	0
	Type TD3 towers with +12m extension	Nos	1	0	0	1	0	0	0	0
<b>Supply of self-supporting towers and extended towers of the Tension (TD6) type complete with all fittings</b>										
	Type TD6 towers with -3m extension	Nos	1	1	1	0	1	1	1	1
	Type TD6 towers with ± 0m extension	Nos	0	0	0	1	0	0	0	0
	Type TD6 towers with +3m extension	Nos	0	1	0	0	0	0	0	1
	Type TD6 towers with +6m extension	Nos	1	0	1	1	0	1	1	0
	Type TD6 towers with +9m extension	Nos	0	0	0	0	1	0	0	0
	Type TD6 towers with +12m extension	Nos	0	0	0	0	0	0	0	0
<b>CIVIL WORKS</b>										
<b>Foundation complete for TDL towers and all extensions</b>										
	Foundation type 3	Nos	1	1	1	1	2	1	1	1
	Foundation type 4A	Nos	0	0	0	0	0	0	0	0

<b>Foundation complete for TD1 towers and all extensions</b>									
Foundation type 3	Nos	11	11	12	12	11	12	13	12
Foundation type 4A	Nos	0	0	0	0	0	0	0	0
<b>Foundation complete for TD3 towers and all extensions</b>									
Foundation type 3	Nos	5	5	4	4	4	4	4	4
Foundation type 4A	Nos	0	0	0	0	0	0	0	0
<b>Foundation complete for TD6 towers and all extensions</b>									
Foundation type 3	Nos	2	2	2	2	2	2	2	2
Foundation type 4A	Nos	0	0	0	0	0	0	0	0
<b>Foundation complete for TDT towers and all extensions</b>									
Foundation type 3	Nos	0	0	0	0	0	0	0	0
Foundation type 4A	Nos	0	0	0	0	0	0	0	0
<b>Survey</b>									
Preliminary Survey *	km	5.8	5.8	5.8	5.8	5.8	5.8	5.8	5.8
Profile Survey	km	5.8	5.8	5.8	5.8	5.8	5.8	5.8	5.8
<b>TOTAL</b>									
<b>INSTALLATIONS</b>									
<b>Erection of self-supporting towers and extended towers of the suspension type complete with all fittings &amp; including Earthing System</b>									
Type TDL towers with ± 0m extension	Nos	0	0	0	0	1	0	0	1
Type TDL towers with -3m extension	Nos	1	1	0	0	0	1	1	0
Type TDL towers with +3m extension	Nos	0	0	1	1	0	0	0	0
Type TDL towers with +6m extension	Nos	0	0	0	0	1	0	0	0
Type TDL towers with +9m extension	Nos	0	0	0	0	0	0	0	0
Type TDL towers with +12m extension	Nos	0	0	0	0	0	0	0	0
<b>Erection of self-supporting towers and extended towers of the Tension (TD1) type complete with all fittings including Earthing System</b>									
Type TD1 towers with ± 0m extension	Nos	0	1	0	0	2	0	0	0
Type TD1 towers with -3m extension	Nos	1	2	1	0	1	2	1	2
Type TD1 towers with +3m extension	Nos	1	1	1	1	1	3	3	1
Type TD1 towers with +6m extension	Nos	3	3	3	1	0	2	2	2
Type TD1 towers with +9m extension	Nos	3	2	2	3	1	3	3	2
Type TD1 towers with +12m extension	Nos	3	4	5	7	5	4	4	5
<b>Erection of self-supporting towers and extended towers of the Tension (TD3) type complete with all fittings including Earthing System</b>									
Type TD3 towers with ± 0m extension	Nos	1	4	1	0	2	1	1	1
Type TD3 towers with -3m extension	Nos	1	0	1	1	1	2	1	1
Type TD3 towers with +3m extension	Nos	1	1	1	1	0	1	2	2
Type TD3 towers with +6m extension	Nos	1	0	1	1	1	0	0	0
Type TD3 towers with +9m extension	Nos	0	0	0	0	0	0	0	0
Type TD3 towers with +12m extension	Nos	1	0	0	1	0	0	0	0
<b>Erection of self-supporting towers and extended towers of the Tension (TD6) type complete with all fittings including Earthing System</b>									
Type TD6 towers with ± 0m extension	Nos	1	1	1	0	1	1	1	1
Type TD6 towers with -3m extension	Nos	0	0	0	1	0	0	0	0
Type TD6 towers with +3m extension	Nos	0	1	0	0	0	0	0	1
Type TD6 towers with +6m extension	Nos	1	0	1	1	0	1	1	0
Type TD6 towers with +9m extension	Nos	0	0	0	0	1	0	0	0
Type TD6 towers with +12m extension	Nos	0	0	0	0	0	0	0	0
<b>Stringing</b>									
	km	5.8	5.8	5.8	5.8	5.8	5.8	5.8	5.8

## Paddy Hilly Terrain

	Description	Unit	ACSR	ACCC	ZTACIR /AW	ACSS/TW	ACCR	GTACSR	LL- ACSR/ AS	LL- TACSR/ AS
<b>Supply of Conductors including joints and jumper leads</b>										
	400 mm <sup>2</sup> Zebra 61/3.18 mm ACSR conductor (Including mid span joints) units	km	28.5	28.5	28.5	28.5	28.5	28.5	28.5	28.5
	7/3.25 MM Galvanized earth wire including mid span units	km	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7
	OPGW Conductors and OPGW Accessories	km	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7
<b>Supply of Damping System (Vibration dampers)</b>										
	Vibration dampers for 400 mm <sup>2</sup> Zebra (61/3.18 mm) conductor	Nos	288	288	288	288	288	288	288	288
	Vibration dampers for OPGW	Nos	58	58	58	58	58	58	58	58
	Vibration dampers for GSW	Nos	48	48	48	48	48	48	48	48
<b>Supply of Insulator sets</b>										
	Normal suspension insulator sets for 400 mm <sup>2</sup> ACSR conductor	Nos	30	24	30	24	24	24	24	24
	Normal tension insulator sets for 400 mm <sup>2</sup> ACSR conductor	Nos	132	144	132	144	144	144	144	144
	Jumper suspension insulator sets	Nos	0	0	0	0	0	0	0	0
	Light duty tension insulator sets for 400 mm <sup>2</sup> ACSR conductor	Nos	12	12	12	12	12	12	12	12
<b>Supply of self-supporting towers and extended towers of the suspension type complete with all fittings</b>										
	Type TDL towers with -3m extension	Nos	0	0	0	0	0	0	0	0
	Type TDL towers with ± 0m extension	Nos	0	1	0	0	0	0	0	0
	Type TDL towers with +3m extension	Nos	0	1	1	1	0	1	1	1
	Type TDL towers with +6m extension	Nos	3	1	3	2	3	2	2	2
	Type TDL towers with +9m extension	Nos	0	0	0	0	0	0	0	0
	Type TDL towers with +12m extension	Nos	2	1	2	1	1	1	1	1
<b>Supply of self-supporting towers and extended towers of the Tension (TD1) type complete with all fittings</b>										
	Type TD1 towers with -3m extension	Nos	2	3	2	2	2	2	2	2
	Type TD1 towers with ± 0m extension	No	0	2	0	1	1	1	1	1
	Type TD1 towers with +3m extension	Nos	1	1	1	1	1	1	1	1
	Type TD1 towers with +6m extension	Nos	3	1	3	2	3	3	3	3
	Type TD1 towers with +9m extension	Nos	0	0	0	1	0	0	0	0
	Type TD1 towers with +12m extension	Nos	0	0	0	0	0	0	0	0
<b>Supply of self-supporting towers and extended towers of the Tension (TD3) type complete with all fittings</b>										
	Type TD3 towers with -3m extension	Nos	0	2	0	0	0	0	0	1
	Type TD3 towers with ± 0m extension	Nos	1	1	1	1	1	1	2	0
	Type TD3 towers with +3m extension	Nos	2	1	2	2	2	2	1	2
	Type TD3 towers with +6m extension	Nos	1	1	1	1	1	1	1	1
	Type TD3 towers with +9m extension	Nos	1	0	1	1	1	1	1	1
	Type TD3 towers with +12m extension	Nos	0	0	0	0	0	0	0	0
<b>CIVIL WORKS</b>										
<b>Foundation complete for TDL towers and all extensions</b>										
	Foundation type 3	Nos	0	0	0	0	0	0	0	0
	Foundation type 4A	Nos	5	4	5	4	4	4	4	4
<b>Foundation complete for TD1 towers and all extensions</b>										
	Foundation type 3	Nos	0	0	0	0	0	0	0	0
	Foundation type 4A	Nos	6	7	6	7	7	7	7	7
<b>Foundation complete for TD3 towers and all extensions</b>										
	Foundation type 3	Nos	0	0	0	0	0	0	0	0
	Foundation type 4A	Nos	5	5	5	5	5	5	5	5

<b>Survey</b>									
	Preliminary Survey *	km	4.7	4.7	4.7	4.7	4.7	4.7	4.7
	Profile Survey	km	4.7	4.7	4.7	4.7	4.7	4.7	4.7
<b>TOTAL</b>									
<b>INSTALLATIONS</b>									
<b>Erection of self-supporting towers and extended towers of the suspension type complete with all fittings &amp; including Earthing System</b>									
	Type TDL towers with ± 0m extension	Nos	0	0	0	0	0	0	0
	Type TDL towers with -3m extension	Nos	0	1	0	0	0	0	0
	Type TDL towers with +3m extension	Nos	0	1	0	1	0	1	1
	Type TDL towers with +6m extension	Nos	3	1	3	2	3	2	2
	Type TDL towers with +9m extension	Nos	0	0	0	0	0	0	0
	Type TDL towers with +12m extension	Nos	2	1	2	1	1	1	1
<b>Erection of self-supporting towers and extended towers of the Tension (TD1) type complete with all fittings including Earthing System</b>									
	Type TD1 towers with ± 0m extension	Nos	2	3	2	2	2	2	2
	Type TD1 towers with -3m extension	Nos	0	2	0	1	1	1	1
	Type TD1 towers with +3m extension	Nos	1	1	1	1	1	1	1
	Type TD1 towers with +6m extension	Nos	3	1	3	2	3	3	3
	Type TD1 towers with +9m extension	Nos	0	0	0	1	0	0	0
	Type TD1 towers with +12m extension	Nos	0	0	0	0	0	0	0
<b>Erection of self-supporting towers and extended towers of the Tension (TD3) type complete with all fittings including Earthing System</b>									
	Type TD3 towers with ± 0m extension	Nos	0	2	0	0	0	0	1
	Type TD3 towers with -3m extension	Nos	1	1	1	1	1	1	0
	Type TD3 towers with +3m extension	Nos	2	1	2	2	2	1	2
	Type TD3 towers with +6m extension	Nos	1	1	1	1	1	1	1
	Type TD3 towers with +9m extension	Nos	1	0	1	1	1	1	1
	Type TD3 towers with +12m extension	Nos	0	0	0	0	0	0	0



University of Moratuwa, Sri Lanka

Electronic Theses & Dissertations

[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

## APPENDIX VIII: Sample Price Schedule

<b>Description</b>	<b>Unit</b>	<b>Qty.</b>	<b>Unit Price</b>	<b>Total Price</b>
			<b>LKR</b>	<b>LKR</b>
<b>ACSR</b>				
<b>Supply of Conductors including joints and jumper leads</b>				
400 mm <sup>2</sup> Zebra 61/3.18 mm ACSR conductor (Including mid span joints) units	km	6.24	770,000.00	28,833,928.20
7/3.25 MM Galvanized earth wire including mid span units	km	6.24	243,000.00	1,516,589.73
OPGW, Conductors and OPGW Accessories	km	6.24	675,778.00	4,217,604.83
<b>Supply of Damping System (Vibration dampers)</b>				
Vibration dampers for 400 mm <sup>2</sup> Zebra (61/3.18 mm) conductor	Nos	450.00	5,198.62	2,339,379.00
Vibration dampers for OPGW	Nos	76.00	7,328.62	556,975.12
Vibration dampers for GSW	Nos	75.00	4,772.62	357,946.50
<b>Supply of Insulator sets</b>				
Normal suspension insulator sets for 400 mm <sup>2</sup> ACSR conductor	Nos	96.00	46,718.00	4,484,928.00
Normal tension insulator sets for 400 mm <sup>2</sup> ACSR conductor	Nos	48.00	63,190.00	3,033,120.00
Jumper suspension insulator sets	Nos	0.00	44,674.62	
Light duty tension insulator sets for 400 mm <sup>2</sup> ACSR conductor	Nos	12.00	104,740.62	1,256,887.44
<b>Supply of self-supporting towers and extended towers of the suspension type complete with all fittings</b>				
Type TDL towers with -3m extension	Nos	1.00	1,047,938.96	1,047,938.96
Type TDL towers with ± 0m extension	Nos	7.00	1,162,088.56	8,134,619.89
Type TDL towers with +3m extension	Nos	5.00	1,292,983.80	6,464,918.99
Type TDL towers with +6m extension	Nos	1.00	1,420,151.84	1,420,151.84
Type TDL towers with +9m extension	Nos	2.00	1,562,552.23	3,125,104.45
Type TDL towers with +12m extension	Nos	0.00	1,748,828.09	
<b>Supply of self-supporting towers and extended towers of the Tension (TD1) type complete with all fittings</b>				
Type TD1 towers with -3m extension	Nos	1.00	1,369,897.08	1,369,897.08
Type TD1 towers with ± 0m extension	No	0.00	1,462,065.63	
Type TD1 towers with +3m extension	Nos	2.00	1,627,929.79	3,255,859.57
Type TD1 towers with +6m extension	Nos	0.00	1,718,585.04	
Type TD1 towers with +9m extension	Nos	0.00	1,871,023.13	
Type TD1 towers with +12m extension	Nos	0.00	1,985,534.50	
<b>Supply of self-supporting towers and extended towers of the Tension (TD3) type complete with all fittings</b>				
Type TD3 towers with -3m extension	Nos	0.00	2,056,200.96	
Type TD3 towers with ± 0m extension	Nos	0.00	2,367,693.37	
Type TD3 towers with +3m extension	Nos	0.00	2,567,637.32	
Type TD3 towers with +6m extension	Nos	1.00	2,768,788.85	2,768,788.85
Type TD3 towers with +9m extension	Nos	0.00	3,020,926.32	
Type TD3 towers with +12m extension	Nos	0.00	3,224,775.81	
<b>Supply of self-supporting towers and extended towers of the Tension (TD6) type complete with all fittings</b>		0.00		
Type TD6 towers with -3m extension	Nos	0.00	2,439,113.93	
Type TD6 towers with ± 0m extension	Nos	0.00	2,730,981.86	
Type TD6 towers with +3m extension	Nos	0.00	3,184,089.98	
Type TD6 towers with +6m extension	Nos	0.00	3,565,410.68	
Type TD6 towers with +9m extension	Nos	0.00	3,987,399.37	
Type TD6 towers with +12m extension	Nos	0.00	4,377,555.28	
<b>ACSR Zebra Conductors and Earth Wires-7/3.25</b>				<b>30,350,517.93</b>
<b>OPGW Conductors and OPGW Accessories</b>				<b>4,774,579.95</b>
<b>Insulator sets, and Insulator h/w + conductor, GSW h/w</b>				<b>11,472,260.94</b>
<b>Towers</b>				<b>27,587,279.63</b>
<b>Other Supply (6% of Total Supply)</b>				<b>4,451,078.31</b>
<b>CIVIL WORKS</b>				

<b>Foundation complete for TDL towers and all extensions</b>				
	Foundation type 3	Nos	16	715,098.25
	Foundation type 4A	Nos		2,028,051.56
<b>Foundation complete for TD1 towers and all extensions</b>				
	Foundation type 3	Nos	3	1,094,929.11
	Foundation type 4A	Nos		2,805,487.45
<b>Foundation complete for TD3 towers and all extensions</b>				
	Foundation type 3	Nos	1	1,594,323.59
	Foundation type 4A	Nos		3,449,671.00
<b>Foundation complete for TD6 towers and all extensions</b>				
	Foundation type 3	Nos	0	4,051,615.75
	Foundation type 4A	Nos		8,113,809.00
<b>Survey</b>				
	Preliminary Survey	km	6.24	27,898.57
	Profile Survey	km	6.24	127,773.33
<b>INSTALLATIONS</b>				
<b>Erection of self-supporting towers and extended towers of the suspension type complete with all fittings &amp; including Earthing System</b>				
	Type TDL towers with ± 0m extension	Nos	1	181,111.31
	Type TDL towers with -3m extension	Nos	7	166,155.45
	Type TDL towers with +3m extension	Nos	5	206,778.53
	Type TDL towers with +6m extension	Nos	1	232,278.39
	Type TDL towers with +9m extension	Nos	2	261,929.04
	Type TDL towers with +12m extension	Nos	0	291,970.45
<b>Erection of self-supporting towers and extended towers of the Tension (TD1) type complete with all fittings including Earthing</b>				
	Type TD1 towers with ± 0m extension	Nos	1	265,284.96
	Type TD1 towers with -3m extension	Nos	0	337,872.79
	Type TD1 towers with +3m extension	Nos	2	297,830.76
	Type TD1 towers with +6m extension	Nos	0	335,666.26
	Type TD1 towers with +9m extension	Nos	0	386,379.99
	Type TD1 towers with +12m extension	Nos	0	416,938.05
<b>Erection of self-supporting towers and extended towers of the Tension (TD3) type complete with all fittings including Earthing</b>				
	Type TD3 towers with ± 0m extension	Nos	0	312,698.75
	Type TD3 towers with -3m extension	Nos	0	276,653.03
	Type TD3 towers with +3m extension	Nos	0	352,311.47
	Type TD3 towers with +6m extension	Nos	1	402,209.61
	Type TD3 towers with +9m extension	Nos	0	453,742.78
	Type TD3 towers with +12m extension	Nos	0	499,597.84
<b>Erection of self-supporting towers and extended towers of the Tension (TD6) type complete with all fittings including Earthing System</b>				
	Type TD6 towers with ± 0m extension	Nos	0	444,588.25
	Type TD6 towers with -3m extension	Nos	0	403,846.84
	Type TD6 towers with +3m extension	Nos	0	501,771.85
	Type TD6 towers with +6m extension	Nos	0	576,441.59
	Type TD6 towers with +9m extension	Nos	0	661,230.14
	Type TD6 towers with +12m extension	Nos	0	718,526.96
<b>Stringing</b>				
	Stringing	km	6.24	784,705.35
Summary Table				
	<b>Foundation and Surveying</b>			<b>17,292,248.41</b>
	<b>Tower Erection</b>			<b>4,397,384.68</b>
	<b>Stringing</b>			<b>4,897,432.43</b>
	<b>Other Works</b>			<b>2,658,706.55</b>

<b>Conductor Cost</b>	<b>30,350,517.93</b>
<b>Total Supply</b>	<b>48,285,198.83</b>
<b>Total Civil Works</b>	<b>29,245,772.07</b>
<b>Total Other Services</b>	<b>4,315,259.55</b>
<b>Total Cost</b>	<b>112,196,748.39</b>
<b>Per Km Cost</b>	<b>17,977,050.30</b>

<b>Conductor Cost Factor for same sized conductors; Source [6]</b>	
1.0	ACSR
2.5	ACCC
3.0	ZTACIR/AW
1.5	ACSS/TW
5.0	ACCR
1.5	GTACSR
1.4	LL ACSR
1.5	LL TACSR



University of Moratuwa, Sri Lanka.  
 Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

## APPENDIX IX : Total Cost Summary for Respective Terrain Models

### Non Populated Flat Terrain

Conductor Type		ACSR	ACCC	ZTACIR/AW	ACSS/TW	ACCR	GTACSR	LL-ACSR/AS	LL-TACSR/AS
Description		Rs.(Mn)							
<b>Total Supply</b>	<b>Conductor</b>	30.35	73.60	88.02	44.77	145.69	44.77	41.88	44.77
	<b>Other Supply</b>	48.29	48.69	53.56	55.27	55.61	52.36	50.42	53.05
<b>Total Civil Works</b>		29.25	29.19	30.08	32.03	29.48	31.19	30.02	31.26
<b>Total Other Services</b>		4.32	6.06	6.87	5.28	9.23	5.13	4.89	5.16
<b>Total Cost</b>		112.20	157.54	178.53	137.35	240.01	133.45	127.21	134.24
<b>Per km Cost</b>		17.98	25.24	28.61	22.01	38.46	21.38	20.38	21.51

### Populated Flat Terrain

Conductor Type		ACSR	ACCC	ZTACIR/AW	ACSS/TW	ACCR	GTACSR	LL-ACSR/AS	LL-TACSR/AS
Description		Rs.(Mn)							
<b>Total Supply</b>	<b>Conductor</b>	28.04	68.01	81.33	41.36	134.61	41.36	38.70	41.36
	<b>Other Supply</b>	67.20	65.52	73.99	72.28	75.66	73.58	69.91	73.63
<b>Total Civil Works</b>		45.63	46.33	49.16	49.43	47.36	51.25	48.56	50.92
<b>Total Other Services</b>		5.63	7.19	8.18	6.52	10.31	6.65	6.29	6.64
<b>Total Cost</b>		146.51	187.05	212.65	169.6	267.93	172.85	163.46	172.55
<b>Per km Cost</b>		25.41	32.44	36.88	29.41	46.46	29.97	28.35	29.92

### Paddy Flat Terrain

Conductor		ACSR	ACCC	ZTACIR/AW	ACSS/TW	ACCR	GTACSR	LL-ACSR/AS	LL-TACSR/AS
Description		Rs.(Mn)							
<b>Total Supply</b>	<b>Conductor</b>	30.35	73.60	88.02	44.77	145.69	44.77	41.88	44.77
	<b>Other Supply</b>	48.29	48.69	53.56	55.27	55.61	52.36	50.42	53.05
<b>Total Civil Works</b>		60.04	60.33	62.10	66.64	60.58	65.24	62.06	65.47
<b>Total Other Services</b>		5.55	7.30	8.15	6.67	10.48	6.49	6.17	5.36
<b>Total Cost</b>		144.22	189.92	211.83	173.34	272.35	168.86	160.54	139.39
<b>Per km Cost</b>		23.11	30.43	33.94	27.77	43.64	27.06	25.72	22.33

### Non Populated Hilly Terrain

Conductor		ACSR	ACCC	ZTACIR/ AW	ACSS/ TW	ACCR	GTACSR	LL-ACSR/ AS	LL- TACSR/ AS
Description		Rs.(Mn)							
Total Supply	Conductor	28.06	68.04	81.37	41.39	134.68	41.39	38.72	41.39
	Other Supply	63.89	65.92	68.40	71.36	70.40	68.68	65.66	69.43
<b>Total Civil Works</b>		57.77	61.67	59.59	62.07	58.91	63.74	60.22	63.25
<b>Total Other Services</b>		5.99	7.83	8.37	6.99	10.56	6.95	6.58	6.96
<b>Total Cost</b>		155.71	203.46	217.74	181.81	274.56	180.76	171.18	181.03
<b>Per km Cost</b>		26.99	35.26	37.74	31.51	47.59	31.33	29.67	31.38

### Populated Hilly Terrain

Conductor		ACSR	ACCC	ZTACIR/A W	ACSS/TW	ACCR	GTACSR	LL-ACSR/ AS	LL- TACSR/AS
Description		Rs.(Mn)							
Total Supply	Conductor	28.06	68.04	81.37	41.39	134.68	41.39	38.72	41.39
	Other Supply	69.47	72.53	76.59	77.16	76.59	76.92	76.83	77.20
<b>Total Civil Works</b>		61.40	67.32	65.31	66.27	63.71	69.33	67.77	69.09
<b>Total Other Services</b>		6.36	8.32	8.93	7.42	11.00	7.51	7.33	7.51
<b>Total Cost</b>		165.29	216.21	232.20	192.82	285.98	195.14	190.66	195.19
<b>Per km Cost</b>		28.65	37.47	40.24	33.42	49.57	33.82	33.04	33.83

### Paddy Hilly Terrain

Conductor		ACSR	ACCC	ZTACIR/ AW	ACSS/T W	ACCR	GTACSR	LL- ACSR/A S	LL- TACSR/ AS
Description		Rs.(Mn)							
Total Supply	Conductor	23.06	55.93	66.89	34.02	110.71	34.02	31.83	34.02
	Other Supply	51.13	52.98	56.99	55.52	58.81	57.49	54.40	57.14
<b>Total Civil Works</b>		79.74	86.93	85.51	86.86	84.90	91.80	86.72	91.87
<b>Total Other Services</b>		6.16	7.83	8.38	7.06	10.18	7.33	6.92	7.32
<b>Total Cost</b>		160.09	203.68	217.76	183.46	264.60	190.64	179.87	190.35
<b>Per km Cost</b>		33.75	42.94	45.91	38.68	55.79	40.20	37.92	40.13