

22

02

A PILOT PLANT STUDY OF

A PEBBLE BED FLOCCULATOR

BY

P. DHARMABALAN

M.Eng. in Civil Eng.

A Thesis Submitted to the University of Moratuwa

For the Degree of,

624 "84"
624 (043)

MASTE University of Moratuwa ING,

um Thesis



42413

42413

42413

SEPTEMBER 1984.

42413

This thesis submitted to the University of
Moratuwa for the degree of Masters in
Engineering has not been previously presented
in whole or in part, to any University or
Institution for a higher degree.

P. Dharmabalan

P. Dharmabalan

Chief Engineer

National Water Supply & Drainage Board

August 1984.

ABSTRACT.

In a small country like SRI LANKA where the Government is adopting various ways and means to improve the standard of living of the masses it has become a prime importance to provide safe drinking water. In the past, when the cost of construction and operation and maintenance was cheap when compared to the present day practices, conventional water treatment plants were constructed just as what was done for the developed countries. This has now been found to be unsatisfactory for use in local conditions in the way of its designs as well as on the operation and maintenance aspects. Under these circumstances, it has become an urgent need to carryout research and development on our own to produce safe drinking water at reasonable cost. Pebble bed flocculation type of treatment process is one such type of study which have proved to be useful to modify the existing plants in the island as well as for new installations in the future. The scope of this project studies is to understand the operation of Pebble bed flocculator under variable parameters such as the flow rate - turbidity , Pebble size etc. Inorder to assess the performance of the Pebble bed flocculation process plots of $\log Z/T - t/t_1$ were plotted and changes for varying parameters were observed and studied. From the comparison of the results it could be clearly seen that it is very promissing and could be used for medium scale plants. The turbidity of raw water that could be treated by this process range from 20 NTU to 100 NTU.

ACKNOWLEDGEMENT

The submission of this research and development report was made possible by the support given by number of institutions like the University of Moratuwa , the National Water Supply & Drainage Board, the Institute of Hydraulic Engineering, Delft, Netherlands, the World Health Organization etc.,

My sincere thanks to Dr(Mrs)T.R.Mampitiyarachchi who supervised my work at all stages of my project development and continuous encouragement given throughout the project work. Also I thank the staff of the University, Moratuwa, the National Water Supply and Drainage Board for continuous support.

Special mention must be made to the Managing Director, of Promoters Engineering Limited of Jaffna who took lot of chances in making this Model in Perspex for this project work.

To all these institutions and to friends and colleagues who critically examined my work, I wish to express my sincere appreciation.



TABLE OF CONTENTS.

Pages.

ABSTRACT

i

ACKNOWLEDGEMENTS

ii

TABLE OF CONTENTS

iii

LIST OF FIGURES

v

LIST OF TABLES

vi

NOTATIONS

vii

1.0 INTRODUCTION

1

2.0 ASPECTS OF COAGULATION AND FLOCCULATION

PROCESS

3

2.1 COAGULATION PROCESS

3

2.2 FLOCCULATION PROCESS

4

2.3 PEBBLE BED FLOCCULATOR

5

3.0 DEVELOPMENT OF A MODEL PEBBLE BED

FLOCCULATOR

7

3.1 METHOD OF APPROACH

7

3.2 LABORATORY EQUIPMENT

9

3.3 EXPERIMENTAL PROCEDURE

12

4.0 EXPERIMENTAL RESULTS AND DATA ANALYSIS

15

4.1 NAMING OF SAMPLES

15

4.2 DATA ANALYSIS

15

5.0 OBSERVATIONS

38

6.0 DISCUSSIONS AND CONCLUSIONS	39
7.0 RECOMMENDATIONS FOR ANY FUTURE WORK	41
APPENDIX A : SCHEMATIC DIAGRAM, SECTIONAL DIMENSIONS, FLOW RATE, CONSTANT HEAD DEVICE, RETENTION TIME	A 44
APPENDIX B : SIEVE ANALYSIS OF PEBBLES	B 50
APPENDIX C : SAMPLE MARKING	C 55
APPENDIX D : EXPERIMENTAL RESULTS	D 62
APPENDIX E : JAR TESTS AND TURBIDITY MEASUREMENTS	E 94
APPENDIX F : PHOTOGRAPHS	F 115
LIST OF REFERENCES	123

LIST OF FIGURES.

<u>Figure</u>		<u>Page</u>
4.1 to 4.12	Plot of $\log Z/T$ Vs t/t_1	31 to 34.
4.13	Turbidity Removal percentage with time	37
4.14	Calculation of Removal percentage	37 A.
7.1	Settling column	42
7.2	Sampling Tube	42
7.3	Pebble bed flocculator type treatment plant for use in water supply schemes.	43
A - 1	Schematic Diagram	A - 45
A - 2	Sectional Diagram	A - 46
A - 3	Flow Rate	A - 47
A - 4	Constant Head Device	A - 48
B - 1 & 6-2	Grading Curve	B -52, B-54.
E1 to E 14	PHOTOGRAPHS	F-116 to F-122.

LIST OF FIGURES.

<u>Figure</u>		<u>Page</u>
4.1 to 4.12	Plot of $\log Z/T$ Vs t/t_1	31 to 34.
4.13	Turbidity Removal percentage with time	37
4.14	Calculation of Removal percentage	37 A.
7.1	Settling column	42
7.2	Sampling Tube	42
7.3	Pebble bed flocculator type treatment plant for use in water supply schemes.	43
A - 1	Schematic Diagram	A - 45
A - 2	Sectional Diagram	A - 46
A - 3	Flow Rate	A - 47
A - 4	Constant Head Device	A - 48
B - 1 & 6-2	Grading Curve	B -52, B-54.
E1 to E 14	PHOTOGRAPHS	F-116 to F-122.

LIST OF TABLES.

<u>Table</u>		<u>Page</u>
3.1	Kaolin Clay and Turbidity g/l of Tap Water	14
4.1 to 4.12	Analysis of $\log Z/T$ Vs t/t_1	18 to 30.
4.13 & 4.15	Percent of Initial Turbidity with time	35 & 36.
4.14 & 4.16	Removal Percentage with time	35 & 36.
A- 1	Retention Time	A - 49
B-1 & 6-2	Sieve Analysis	B -51 & B-53
C-1 to C-6	Marking Procedure	C-56 to C-61
D-1 to D-30	Experimental Results	D-63 to D-93
E-1	Dosage of Lime	D-97
E-2	Dosage of Alum	D-100
E-3 to E-7	Jar Tests	E-105, to E-109

NOTATIONS

A	Sample taken after 15 mint of test run.
B	Sample taken after 30 mint of tset run,
C	Sample taken after 60 mint of test run.
D	Sample taken after 90 mint of test run.
E	Sample taken after 120 mint of test run.
$q_{1,2,3}$	Flow rate through the pebble bed in l/mint.
$R_{1,2,3}$	Removal percentage.
t	The turbidity of the sample at depth Z and at time T
t_1 to 6	The initial turbidity of sample.
T	The time after initiation of settling.
Z	Distance from the top of air water interface of settling column.

