

REFERENCES

- [1] T. Samad, E. Koch, P. Stluka, “Automated Demand Response for Smart Buildings and Microgrids: The State of the Practice and Research Challenges”, Proceedings of the IEEE, Vol: 104, Issue 4, April 2016
- [2] Federal Energy Regulatory Commission (FERC), “Assessment of demand response and advanced metering,” Dec. 2012. [Online]. Available: <http://www.ferc.gov/legal/staff-reports/12-20-12-demandresponse.pdf>.
- [3] S. Kiliccote, M. A. Piette, E. Koch, D. Hennage, “Utilizing Automated Demand Response in commercial buildings as non-spinning reserve product for ancillary services markets”, 50th IEEE Conference on Decision and Control and European Control Conference (CDC-ECC), 2011
- [4] B. Biegel, P. Andersen, J. Stoustrup, L. H. Hansen, A. Birke, “Sustainable Reserve Power from Demand Response and Fluctuating Production—Two Danish Demonstrations”, Proceedings of the IEEE, Vol. 104, Issue. 4, April 2016
- [5] A. Yassine, “Implementation Challenges of Automatic Demand Response for Households in Smart Grids”, 3rd International Conference on Renewable Energies for Developing Countries (REDEC), 2016
- [6] T. Samad, E. Koch, “Automated demand response for energy efficiency and emissions reduction”, Transmission and Distribution Conference and Exposition (T&D), 2012 IEEE PES
- [7] M. Behl, N. Shah, L. Vadakedathu, D. Wheeler, R. Mangharam, “Demo Abstract: EnergyLab - Building Energy Testbed for Demand-Response”, ACM/IEEE International Conference on Information Processing in Sensor Networks (IPSN), 2013
- [8] C. Ninagawa, K. Taga, A. Kiyota, T. Yamaguchi, “Emulation System on Smart Grid Fast Automated Demand Response of Widely-distributed Stochastically-operating Building Facilities” 2015 IEEE International Symposium on Systems Engineering (ISSE)

APPENDIX 01

Table 9.1: Participating Loads for the Pilot Project

Rated Watt value	Off time	Location	Priority
2350	7	Chairman	1
1970	5	H. Eng. Room	1
1100	9	Head of HR & Admin	1
1100	9	Chief FO	1
1100	8	GM	1
3670	5	Server room	1
1190	7	Head of Operations	1
1172	4	SDM	2
1910	1	SOM	2
860	9	CSM	2
1900	8	PM	2
1350	3	Conference Room	2
1340	8	RM	2
2367	1	DCC (middle)	2
2300	5	SOD	3
1100	9	Control Engineer	3
2000	8	Finance dept. common	3
6400	7	IT manager	3
5500	1	IT 3rd Floor	3
1550	6	SDD1	3
1150	3	SDD2 (3)	3
2340	1	Common area	3
1800	5	Control room	3
1300	3	Photocopy room	3
2600	6	Finance dept.	3
2700	6	Corporate office	3
6150	3	Reception	3
1970	8	Library	3
6150	3	Admin Office	3
3200	1	Auditorium 1 (right)	3
2840	9	SDD2 (middle)	3
2400	8	Library 2	3
1930	8	Corporate office assistant	3
1600	9	CSD	3
1010	1	Call center	3
825	6	SDD2 (left)	3
2350	7	SDD2 (right)	3
2480	7	Auditorium 1 (left)	3

1100	4	Accountant Treasury	3
1100	4	Financial Accountant	3
2500	6	Operations Division	3
1970	2	IT Development unit	3
3460	4	Supply Department	3
2200	1	Supply Department (right)	3
1700	3	Lunch Room 1	3
1900	1	DCC (corner)	3
1290	1	Chief Internal Auditor - IAD (right)	3
1650	3	Chief Internal Auditor - IAD (left)	3
3100	7	new admin office 1	3
2200	2	new admin office 2	3

APPENDIX 02

Table 9.2: Load Profile data for Day 1

Time	Solar Power Input /kW	Load Profile with solar input and ADR /kW	Load Profile with solar Input /kW
6:00 AM	0.00	13.2	13.2
6:01 AM	0.00	15.3	15.3
6:02 AM	0.00	16.0	16.0
6:03 AM	0.00	14.0	14.0
6:04 AM	0.00	14.1	14.1
6:05 AM	0.00	14.5	14.5
6:06 AM	0.00	16.0	16.0
6:07 AM	0.00	15.0	15.0
6:08 AM	0.00	15.8	15.8
6:09 AM	0.00	17.0	17.0
6:10 AM	0.00	17.0	17.0
6:11 AM	0.00	16.2	16.2
6:12 AM	0.00	16.2	16.2
6:13 AM	0.00	17.0	17.0
6:14 AM	0.04	18.0	18.0
6:15 AM	0.09	15.3	15.3
6:16 AM	0.04	15.6	15.6
6:17 AM	0.20	14.8	14.8
6:18 AM	0.24	16.4	16.4
6:19 AM	0.29	16.0	16.0
6:20 AM	0.35	16.1	16.1
6:21 AM	0.40	16.8	16.8
6:22 AM	0.44	16.3	16.3
6:23 AM	0.48	16.9	16.9
6:24 AM	0.56	15.3	15.3
6:25 AM	0.61	14.5	14.5
6:26 AM	0.56	15.5	15.5
6:27 AM	0.83	19.9	19.9
6:28 AM	0.87	20.4	20.4
6:29 AM	0.91	21.0	21.0
6:30 AM	0.99	19.2	19.2
6:31 AM	0.99	18.2	18.2
6:32 AM	1.01	17.6	17.6
6:33 AM	1.08	18.3	18.3
6:34 AM	1.16	19.9	19.9
6:35 AM	1.23	19.8	19.8
6:36 AM	1.09	19.9	19.9
6:37 AM	1.28	16.8	16.8
6:38 AM	1.32	15.5	15.5
6:39 AM	1.35	13.1	13.1
6:40 AM	1.35	13.7	13.7
6:41 AM	1.36	15.1	15.1
6:42 AM	1.37	15.7	15.7
6:43 AM	1.39	15.6	15.6
6:44 AM	1.44	11.6	11.6
6:45 AM	1.49	10.3	10.3
6:46 AM	1.45	10.3	10.3
6:47 AM	1.57	14.0	14.0
6:48 AM	1.71	14.9	14.9
6:49 AM	1.85	14.8	14.8
6:50 AM	1.92	10.6	10.6
6:51 AM	1.96	9.9	9.9
6:52 AM	2.01	11.4	11.4
6:53 AM	2.07	13.9	13.9
6:54 AM	2.13	15.2	15.2
6:55 AM	2.15	14.7	14.7
6:56 AM	2.18	14.6	14.6
6:57 AM	2.23	12.5	12.5
6:58 AM	2.28	12.8	12.8
6:59 AM	2.30	15.2	15.2
7:00 AM	2.30	15.7	15.7
7:01 AM	2.32	16.9	16.9
7:02 AM	2.35	18.8	18.8
7:03 AM	2.42	17.1	17.1
7:04 AM	2.46	17.1	17.1
7:05 AM	2.49	17.7	17.7
7:06 AM	2.50	21.2	21.2
7:07 AM	2.55	21.6	21.6
7:08 AM	2.56	20.6	20.6
7:09 AM	2.57	21.6	21.6
7:10 AM	2.59	20.0	20.0
7:11 AM	2.63	22.8	22.8
7:12 AM	2.67	21.2	21.2
7:13 AM	2.69	23.4	23.4
7:14 AM	2.71	22.6	22.6
7:15 AM	2.73	23.1	23.1
7:16 AM	2.76	21.8	21.8
7:17 AM	2.77	20.4	20.4
7:18 AM	2.78	20.9	20.9
7:19 AM	2.79	24.2	24.2
7:20 AM	2.80	25.0	25.0

7:21 AM	2.80	26.4	26.4
7:22 AM	2.83	26.8	26.8
7:23 AM	2.85	23.8	23.8
7:24 AM	2.89	24.1	24.1
7:25 AM	2.86	23.7	23.7
7:26 AM	2.85	26.2	26.2
7:27 AM	2.87	26.0	26.0
7:28 AM	2.89	26.0	26.0
7:29 AM	2.90	24.1	24.1
7:30 AM	2.92	24.4	24.4
7:31 AM	2.93	23.9	23.9
7:32 AM	2.99	25.8	25.8
7:33 AM	3.04	26.4	26.4
7:34 AM	3.08	25.6	25.6
7:35 AM	3.15	25.1	25.1
7:36 AM	3.18	24.7	24.7
7:37 AM	3.24	23.7	23.7
7:38 AM	3.31	25.2	25.2
7:39 AM	3.32	25.8	25.8
7:40 AM	3.38	26.9	26.9
7:41 AM	3.47	27.4	27.4
7:42 AM	3.51	26.1	26.1
7:43 AM	3.57	23.5	23.5
7:44 AM	3.58	23.3	23.3
7:45 AM	3.61	25.5	25.5
7:46 AM	3.71	26.4	26.4
7:47 AM	5.99	24.8	24.8
7:48 AM	6.90	23.3	23.3
7:49 AM	7.20	21.4	21.4
7:50 AM	7.31	20.9	20.9
7:51 AM	7.73	21.6	21.6
7:52 AM	8.52	25.1	25.1
7:53 AM	9.01	24.1	24.1
7:54 AM	9.74	25.8	25.8
7:55 AM	9.75	26.6	26.6
7:56 AM	9.89	26.1	26.1
7:57 AM	10.34	26.9	26.9
7:58 AM	10.89	27.7	27.7
7:59 AM	11.24	26.5	26.5
8:00 AM	11.11	27.7	27.7
8:01 AM	11.38	28.4	28.4
8:02 AM	11.94	32.6	32.6
8:03 AM	12.35	31.5	31.5
8:04 AM	13.37	31.0	31.0
8:05 AM	14.14	33.2	33.2
8:06 AM	14.36	34.6	34.6

8:07 AM	14.58	37.7	37.7
8:08 AM	14.82	37.7	37.7
8:09 AM	15.01	40.1	40.1
8:10 AM	15.10	39.0	39.0
8:11 AM	15.36	39.8	39.8
8:12 AM	15.43	40.6	40.6
8:13 AM	15.53	40.7	40.7
8:14 AM	15.55	43.6	43.6
8:15 AM	15.83	40.5	40.5
8:16 AM	15.88	40.7	40.7
8:17 AM	16.01	42.7	42.7
8:18 AM	16.21	44.9	44.9
8:19 AM	16.31	45.8	45.8
8:20 AM	16.64	45.9	45.9
8:21 AM	16.96	41.0	41.0
8:22 AM	16.76	42.0	42.0
8:23 AM	17.05	42.3	42.3
8:24 AM	16.89	43.8	43.8
8:25 AM	17.13	42.2	42.2
8:26 AM	17.32	45.2	45.2
8:27 AM	17.33	45.9	45.9
8:28 AM	17.39	49.3	49.3
8:29 AM	17.71	46.3	46.3
8:30 AM	17.75	50.2	50.2
8:31 AM	18.16	49.7	49.7
8:32 AM	18.42	50.5	50.5
8:33 AM	18.61	46.7	46.7
8:34 AM	18.83	46.8	46.8
8:35 AM	19.12	45.7	45.7
8:36 AM	19.25	49.7	49.7
8:37 AM	19.44	50.3	50.3
8:38 AM	19.68	47.7	47.7
8:39 AM	19.72	46.0	46.0
8:40 AM	19.79	43.6	43.6
8:41 AM	19.95	42.5	42.5
8:42 AM	20.31	42.6	42.6
8:43 AM	20.33	40.6	40.6
8:44 AM	20.26	41.2	41.2
8:45 AM	20.53	39.7	39.7
8:46 AM	20.65	38.9	38.9
8:47 AM	20.75	40.2	40.2
8:48 AM	20.81	42.7	42.7
8:49 AM	21.06	42.8	42.8
8:50 AM	21.31	44.7	44.7
8:51 AM	21.35	44.8	44.8
8:52 AM	21.53	43.4	43.4

8:53 AM	21.71	41.2	41.2
8:54 AM	21.82	42.5	42.5
8:55 AM	21.79	43.3	43.3
8:56 AM	21.98	45.9	45.9
8:57 AM	22.01	45.2	45.2
8:58 AM	22.43	42.4	42.4
8:59 AM	22.30	44.1	44.1
9:00 AM	22.70	42.9	42.9
9:01 AM	22.89	46.8	46.8
9:02 AM	22.91	47.8	47.8
9:03 AM	23.05	43.9	43.9
9:04 AM	23.35	42.0	42.0
9:05 AM	23.79	40.8	40.8
9:06 AM	23.64	40.0	40.0
9:07 AM	24.22	40.4	40.4
9:08 AM	24.31	44.1	44.1
9:09 AM	24.10	43.7	43.7
9:10 AM	24.14	43.5	43.5
9:11 AM	24.65	40.1	40.1
9:12 AM	24.77	37.9	37.9
9:13 AM	24.49	38.3	38.3
9:14 AM	24.69	43.2	43.2
9:15 AM	24.78	43.9	43.9
9:16 AM	25.02	47.0	47.0
9:17 AM	24.78	46.0	46.0
9:18 AM	24.86	44.9	44.9
9:19 AM	25.11	42.7	42.7
9:20 AM	25.39	45.5	45.5
9:21 AM	25.55	45.6	45.6
9:22 AM	25.44	44.2	44.2
9:23 AM	25.82	38.9	38.9
9:24 AM	25.80	37.5	37.5
9:25 AM	25.80	40.6	40.6
9:26 AM	25.92	41.4	41.4
9:27 AM	25.98	43.5	43.5
9:28 AM	26.07	41.8	41.8
9:29 AM	26.26	38.0	38.0
9:30 AM	26.31	37.3	37.3
9:31 AM	26.72	38.5	38.5
9:32 AM	26.93	41.7	41.7
9:33 AM	26.93	42.7	42.7
9:34 AM	27.05	40.3	40.3
9:35 AM	27.13	40.6	40.6
9:36 AM	26.93	38.8	38.7
9:37 AM	27.14	38.9	38.9
9:38 AM	27.23	38.8	38.8

9:39 AM	27.33	42.2	42.2
9:40 AM	27.25	43.0	43.0
9:41 AM	27.28	42.4	42.4
9:42 AM	27.21	42.6	42.6
9:43 AM	27.30	44.0	44.0
9:44 AM	27.36	46.0	46.0
9:45 AM	27.69	48.1	48.1
9:46 AM	26.88	42.4	42.4
9:47 AM	27.69	38.2	38.2
9:48 AM	27.73	36.3	36.3
9:49 AM	28.01	37.0	37.0
9:50 AM	28.28	38.9	38.9
9:51 AM	28.45	40.9	40.9
9:52 AM	28.73	38.8	38.8
9:53 AM	28.83	40.4	40.4
9:54 AM	28.82	42.3	42.3
9:55 AM	28.94	39.5	39.5
9:56 AM	27.89	36.9	36.9
9:57 AM	28.97	35.9	35.9
9:58 AM	29.22	36.7	36.7
9:59 AM	29.44	37.9	37.9
10:00 AM	29.62	40.6	40.6
10:01 AM	29.93	34.1	34.1
10:02 AM	29.60	32.7	32.7
10:03 AM	29.88	32.0	32.0
10:04 AM	30.03	34.4	34.4
10:05 AM	30.19	36.8	36.8
10:06 AM	28.68	37.3	37.3
10:07 AM	30.04	30.2	30.2
10:08 AM	30.16	31.8	31.8
10:09 AM	30.35	34.4	34.4
10:10 AM	29.95	41.7	41.7
10:11 AM	30.22	40.1	40.1
10:12 AM	29.49	38.3	38.3
10:13 AM	30.33	31.6	31.6
10:14 AM	30.15	30.0	30.0
10:15 AM	30.56	31.9	31.9

10:16 AM	30.59	37.2	37.2
10:17 AM	30.87	37.7	37.7
10:18 AM	30.69	34.7	34.7
10:19 AM	31.02	30.0	30.0
10:20 AM	31.14	29.4	29.4
10:21 AM	31.22	34.4	34.4
10:22 AM	31.16	36.6	36.6
10:23 AM	31.15	38.3	38.3
10:24 AM	31.00	33.3	33.3
10:25 AM	31.14	34.4	34.4
10:26 AM	31.53	33.3	33.3
10:27 AM	31.57	31.4	31.4
10:28 AM	31.52	34.4	34.4
10:29 AM	31.65	33.9	33.9
10:30 AM	31.58	34.8	34.8
10:31 AM	31.73	35.6	35.6
10:32 AM	31.69	34.3	34.3
10:33 AM	31.18	34.5	34.5
10:34 AM	31.09	33.8	33.8
10:35 AM	31.15	34.8	34.8
10:36 AM	31.56	37.3	37.3
10:37 AM	31.63	35.6	35.6
10:38 AM	31.80	33.8	33.8
10:39 AM	32.30	32.4	32.4
10:40 AM	32.46	30.0	30.0
10:41 AM	31.92	25.8	25.8
10:42 AM	31.94	26.2	26.2
10:43 AM	32.03	29.7	29.7
10:44 AM	32.58	31.5	31.5
10:45 AM	32.79	30.5	30.5

10:46 AM	32.81	27.8	27.8
10:47 AM	32.62	26.8	26.8
10:48 AM	32.89	29.5	29.5
10:49 AM	32.98	31.7	31.7
10:50 AM	33.50	33.2	33.2
10:51 AM	33.45	33.3	33.3
10:52 AM	33.85	32.1	32.1
10:53 AM	34.13	28.6	28.6
10:54 AM	34.05	26.7	26.7
10:55 AM	34.50	27.9	27.9
10:56 AM	34.49	29.0	29.0
10:57 AM	19.35	30.2	44.7
10:58 AM	25.90	28.2	36.3
10:59 AM	20.83	27.7	41.0
11:00 AM	23.83	30.8	40.9
11:01 AM	26.46	33.7	41.1
11:02 AM	35.38	34.9	34.9
11:03 AM	35.40	35.6	35.6
11:04 AM	35.70	31.5	31.5
11:05 AM	35.88	31.2	31.2
11:06 AM	35.74	30.8	30.8
11:07 AM	35.67	27.8	27.8
11:08 AM	35.83	25.6	25.6
11:09 AM	35.77	24.0	24.0
11:10 AM	35.57	23.7	23.7
11:11 AM	35.45	27.5	27.5
11:12 AM	35.10	31.7	31.7
11:13 AM	34.95	29.2	29.2
11:14 AM	35.50	29.8	29.8
11:15 AM	35.85	28.4	28.4

11:16 AM	35.99	31.6	31.6
11:17 AM	36.38	29.4	29.4
11:18 AM	36.55	29.4	29.4
11:19 AM	37.09	25.6	25.6
11:20 AM	37.82	25.0	25.0
11:21 AM	32.76	32.1	32.1
11:22 AM	22.14	29.4	43.3
11:23 AM	14.04	30.8	52.7
11:24 AM	12.03	32.0	55.4
11:25 AM	12.50	31.7	54.9
11:26 AM	13.60	27.4	49.5
11:27 AM	13.94	49.3	49.3
11:28 AM	15.15	47.0	47.0
11:29 AM	31.39	34.5	34.5
11:30 AM	37.66	26.7	26.7
11:31 AM	24.13	39.0	39.0
11:32 AM	14.04	49.8	49.8
11:33 AM	12.81	33.5	54.2
11:34 AM	14.01	29.7	50.3
11:35 AM	38.37	23.3	23.3
11:36 AM	20.07	20.2	36.2
11:37 AM	14.72	20.9	41.8
11:38 AM	10.09	23.8	48.7
11:39 AM	11.23	51.2	51.2
11:40 AM	39.36	24.2	24.2
11:41 AM	16.42	47.2	47.2
11:42 AM	42.68	22.6	22.6
11:43 AM	35.77	29.3	29.3
11:44 AM	13.70	28.0	51.0
11:45 AM	15.49	28.8	51.3

11:46 AM	31.43	33.3	33.3
11:47 AM	36.48	27.3	27.2
11:48 AM	28.89	26.1	35.1
11:49 AM	41.37	22.5	22.5
11:50 AM	24.86	27.0	40.5
11:51 AM	38.63	28.4	28.4
11:52 AM	38.42	25.8	25.8
11:53 AM	37.70	24.0	24.0
11:54 AM	37.22	22.1	22.1
11:55 AM	37.10	26.3	26.3
11:56 AM	36.27	27.8	27.8
11:57 AM	35.91	28.6	28.6
11:58 AM	35.58	28.1	28.1
11:59 AM	36.05	24.7	24.7
12:00 PM	35.79	27.6	27.6
12:01 PM	35.87	32.5	32.5
12:02 PM	35.75	32.2	32.2
12:03 PM	36.04	36.2	36.2
12:04 PM	36.11	34.9	34.9
12:05 PM	35.88	37.0	37.0
12:06 PM	35.71	32.7	32.7
12:07 PM	35.60	30.8	30.8
12:08 PM	35.85	29.8	29.8
12:09 PM	35.86	32.9	32.9
12:10 PM	35.82	36.9	36.9
12:11 PM	35.78	36.6	36.6
12:12 PM	35.79	35.0	35.0
12:13 PM	35.83	33.8	33.8
12:14 PM	35.77	31.1	31.1
12:15 PM	35.65	31.6	31.6

12:16 PM	35.62	34.2	34.2
12:17 PM	35.38	32.8	32.8
12:18 PM	35.41	30.5	30.5
12:19 PM	34.87	29.0	29.0
12:20 PM	34.57	30.3	30.3
12:21 PM	34.78	33.4	33.4
12:22 PM	35.11	33.3	33.3
12:23 PM	34.97	31.6	31.6
12:24 PM	35.92	28.7	28.7
12:25 PM	36.03	30.8	30.8
12:26 PM	35.99	29.8	29.8
12:27 PM	36.04	29.5	29.5
12:28 PM	35.67	30.4	30.4
12:29 PM	35.83	29.9	29.9
12:30 PM	35.95	28.1	28.1
12:31 PM	35.47	28.5	28.5
12:32 PM	35.58	27.3	27.3
12:33 PM	35.67	22.5	22.5
12:34 PM	36.35	18.5	18.5
12:35 PM	36.27	19.3	19.3
12:36 PM	36.00	23.1	23.1
12:37 PM	35.43	22.7	22.7
12:38 PM	35.24	24.1	24.1
12:39 PM	35.17	25.6	25.6
12:40 PM	34.98	23.6	23.6
12:41 PM	34.78	23.3	23.3
12:42 PM	34.83	24.2	24.2
12:43 PM	34.74	30.1	30.1
12:44 PM	34.76	28.9	28.9
12:45 PM	34.59	27.9	27.9

12:46 PM	34.27	27.3	27.3
12:47 PM	34.43	27.8	27.8
12:48 PM	34.47	27.9	27.9
12:49 PM	34.44	27.6	27.6
12:50 PM	34.61	27.2	27.2
12:51 PM	34.65	27.8	27.8
12:52 PM	34.67	28.2	28.2
12:53 PM	34.75	24.8	24.8
12:54 PM	34.91	22.4	22.4
12:55 PM	34.63	27.0	27.0
12:56 PM	34.64	28.3	28.3
12:57 PM	34.31	27.6	27.6
12:58 PM	34.06	26.3	26.3
12:59 PM	33.97	27.7	27.7
1:00 PM	34.27	28.1	28.1
1:01 PM	34.37	29.3	29.3
1:02 PM	34.37	30.9	30.9
1:03 PM	34.39	30.7	30.7
1:04 PM	34.38	31.4	31.4
1:05 PM	34.41	32.3	32.3
1:06 PM	34.37	31.1	31.1
1:07 PM	33.74	27.6	27.6
1:08 PM	34.61	25.5	25.5
1:09 PM	34.73	27.3	27.3
1:10 PM	34.60	31.9	31.9
1:11 PM	34.20	33.5	33.5
1:12 PM	34.37	33.0	33.0
1:13 PM	33.83	32.6	32.6
1:14 PM	34.14	32.3	32.3
1:15 PM	34.65	31.8	31.8
1:16 PM	34.04	32.4	32.4
1:17 PM	33.21	32.8	32.8
1:18 PM	34.61	29.4	29.4
1:19 PM	35.03	29.6	29.6
1:20 PM	34.95	31.8	31.8
1:21 PM	34.96	28.3	28.3
1:22 PM	34.96	25.6	25.6
1:23 PM	34.65	24.6	24.6
1:24 PM	34.44	26.1	26.1

1:25 PM	34.34	27.6	27.6
1:26 PM	32.99	28.0	28.0
1:27 PM	30.30	32.2	32.2
1:28 PM	33.60	27.7	27.7
1:29 PM	33.78	28.0	28.0
1:30 PM	33.84	28.5	28.5
1:31 PM	33.78	29.0	29.0
1:32 PM	33.70	30.3	30.3
1:33 PM	33.71	32.2	32.2
1:34 PM	33.75	30.0	30.0
1:35 PM	33.49	27.2	27.2
1:36 PM	33.29	25.1	25.1
1:37 PM	31.73	32.5	32.5
1:38 PM	33.31	30.1	30.1
1:39 PM	32.71	31.6	31.6
1:40 PM	32.72	32.1	32.1
1:41 PM	33.21	30.1	30.1
1:42 PM	33.51	27.8	27.8
1:43 PM	32.63	27.1	27.1
1:44 PM	31.39	31.6	31.6
1:45 PM	34.42	31.2	31.2
1:46 PM	34.80	31.8	31.8
1:47 PM	34.02	26.8	26.8
1:48 PM	33.48	23.6	23.6
1:49 PM	32.96	22.9	22.9
1:50 PM	32.76	25.7	25.7
1:51 PM	32.57	27.2	27.2
1:52 PM	31.39	28.3	28.3
1:53 PM	32.88	27.1	27.1
1:54 PM	32.31	28.8	28.8
1:55 PM	32.50	26.9	26.9
1:56 PM	32.02	26.5	26.5
1:57 PM	31.82	32.5	32.5
1:58 PM	31.83	34.3	34.3
1:59 PM	29.92	36.8	36.8
2:00 PM	31.21	33.5	33.5
2:01 PM	31.51	32.2	32.2
2:02 PM	31.53	31.5	31.5
2:03 PM	31.82	27.1	27.1
2:04 PM	31.72	24.4	24.4
2:05 PM	31.36	26.0	26.0
2:06 PM	30.91	29.1	29.1
2:07 PM	30.64	29.7	29.7
2:08 PM	31.29	28.1	28.1
2:09 PM	20.40	28.4	39.0
2:10 PM	20.01	25.1	36.0

2:11 PM	19.75	27.0	38.3
2:12 PM	20.01	29.6	40.2
2:13 PM	19.99	30.2	41.1
2:14 PM	19.84	29.9	41.1
2:15 PM	19.37	30.8	42.3
2:16 PM	20.06	31.2	41.8
2:17 PM	20.07	30.2	41.1
2:18 PM	20.81	39.5	39.5
2:19 PM	30.45	31.6	31.6
2:20 PM	30.27	32.0	32.0
2:21 PM	31.24	32.4	32.4
2:22 PM	31.91	32.5	32.5
2:23 PM	28.96	34.7	34.7
2:24 PM	31.54	32.0	32.0
2:25 PM	30.96	29.7	29.7
2:26 PM	30.37	32.7	32.7
2:27 PM	29.97	33.3	33.3
2:28 PM	29.70	31.8	31.8
2:29 PM	29.65	36.1	36.1
2:30 PM	29.42	38.5	38.5
2:31 PM	29.21	36.6	36.6
2:32 PM	29.14	34.4	34.4
2:33 PM	29.22	34.4	34.4
2:34 PM	28.60	36.9	36.9
2:35 PM	28.90	37.5	37.5
2:36 PM	28.85	39.1	39.1
2:37 PM	28.95	37.5	37.5
2:38 PM	29.16	34.6	34.6
2:39 PM	29.01	35.0	35.0
2:40 PM	27.39	36.1	36.1
2:41 PM	29.05	37.9	37.9
2:42 PM	26.18	47.5	47.5
2:43 PM	18.72	47.4	56.8
2:44 PM	27.65	45.0	45.0
2:45 PM	27.91	41.9	41.9
2:46 PM	26.82	42.5	42.5
2:47 PM	27.49	43.0	43.0
2:48 PM	27.04	44.0	44.0
2:49 PM	26.37	44.3	44.3
2:50 PM	26.49	43.0	43.0
2:51 PM	26.84	38.4	38.4
2:52 PM	27.06	36.3	36.3
2:53 PM	27.29	39.1	39.1
2:54 PM	27.12	40.0	40.0
2:55 PM	27.03	38.9	38.9
2:56 PM	22.51	39.1	43.3

2:57 PM	5.87	37.4	58.2
2:58 PM	7.18	35.5	55.4
2:59 PM	27.90	33.7	33.7
3:00 PM	7.46	35.4	55.0
3:01 PM	7.90	35.2	53.9
3:02 PM	27.19	34.4	34.4
3:03 PM	25.43	36.5	36.5
3:04 PM	26.66	38.1	38.1
3:05 PM	26.12	37.8	37.8
3:06 PM	24.61	36.5	36.5
3:07 PM	24.09	36.6	36.6
3:08 PM	24.23	40.5	40.5
3:09 PM	25.01	41.7	41.7
3:10 PM	24.51	41.9	41.9
3:11 PM	25.44	41.7	41.7
3:12 PM	15.93	41.4	50.0
3:13 PM	24.27	40.4	40.4
3:14 PM	24.49	41.9	41.9
3:15 PM	21.40	44.8	44.8
3:16 PM	7.51	41.9	58.4
3:17 PM	24.68	40.7	40.7
3:18 PM	24.33	41.0	41.0
3:19 PM	23.61	42.5	42.5
3:20 PM	23.64	41.7	41.7
3:21 PM	22.69	46.2	46.2
3:22 PM	22.27	44.7	44.7
3:23 PM	21.57	44.8	44.8
3:24 PM	21.44	44.5	44.5
3:25 PM	21.78	44.4	44.4
3:26 PM	21.07	45.5	45.5
3:27 PM	21.38	41.4	41.4
3:28 PM	19.76	42.4	42.4
3:29 PM	20.58	39.3	39.3
3:30 PM	20.43	41.8	41.8
3:31 PM	20.58	42.0	42.0
3:32 PM	20.10	44.4	44.4
3:33 PM	20.34	45.2	45.2
3:34 PM	18.86	46.2	46.2
3:35 PM	20.31	40.5	40.5
3:36 PM	20.22	41.4	41.4
3:37 PM	19.68	45.9	45.9
3:38 PM	19.13	47.5	47.5
3:39 PM	19.70	47.0	47.0
3:40 PM	19.43	47.1	47.1
3:41 PM	18.98	47.7	47.7
3:42 PM	19.06	48.4	48.4

3:43 PM	18.43	51.2	51.2
3:44 PM	18.23	47.7	47.7
3:45 PM	18.33	46.5	46.5
3:46 PM	18.44	48.8	48.8
3:47 PM	18.27	48.9	48.9
3:48 PM	18.38	49.1	49.1
3:49 PM	17.44	49.3	49.3
3:50 PM	17.69	46.1	46.1
3:51 PM	18.28	47.1	47.1
3:52 PM	18.15	46.4	46.4
3:53 PM	18.07	48.2	48.2
3:54 PM	17.96	47.0	47.0
3:55 PM	8.25	45.9	55.3
3:56 PM	9.99	48.1	56.0
3:57 PM	17.72	47.4	47.4
3:58 PM	17.74	46.9	46.9
3:59 PM	17.39	46.9	46.9
4:00 PM	17.84	49.3	49.3
4:01 PM	18.19	51.2	51.2
4:02 PM	17.82	52.2	52.2
4:03 PM	17.83	48.4	48.4
4:04 PM	17.63	46.8	46.8
4:05 PM	17.53	45.3	45.3
4:06 PM	17.45	42.5	42.5
4:07 PM	16.93	46.0	46.0
4:08 PM	16.80	48.7	48.7
4:09 PM	15.84	52.4	52.4
4:10 PM	16.42	53.9	53.9
4:11 PM	16.22	50.2	50.2
4:12 PM	16.46	47.1	47.1
4:13 PM	16.31	45.3	45.3
4:14 PM	16.21	46.7	46.7
4:15 PM	16.25	45.8	45.8
4:16 PM	15.77	47.8	47.8
4:17 PM	15.81	48.4	48.4
4:18 PM	15.38	51.4	51.4
4:19 PM	14.83	47.3	47.3
4:20 PM	14.71	45.5	45.5
4:21 PM	14.45	46.9	46.9
4:22 PM	14.18	48.1	48.1
4:23 PM	13.62	45.2	45.2
4:24 PM	13.55	46.4	46.4
4:25 PM	12.42	47.5	47.5
4:26 PM	11.81	47.6	47.6
4:27 PM	12.51	44.7	44.7
4:28 PM	12.04	46.2	46.2

4:29 PM	11.44	43.8	43.8
4:30 PM	11.50	45.1	45.1
4:31 PM	11.06	46.9	46.9
4:32 PM	9.29	54.8	54.8
4:33 PM	8.76	58.1	58.1
4:34 PM	9.04	58.8	58.8
4:35 PM	8.71	53.2	53.2
4:36 PM	8.55	50.6	50.6
4:37 PM	8.61	53.5	53.5
4:38 PM	8.72	56.6	56.6
4:39 PM	8.58	56.1	56.1
4:40 PM	8.26	55.8	55.8
4:41 PM	7.98	57.2	57.2
4:42 PM	7.83	57.8	57.8
4:43 PM	7.80	56.1	56.1
4:44 PM	6.84	55.2	55.2
4:45 PM	7.34	52.5	52.5
4:46 PM	7.77	52.7	52.7
4:47 PM	7.60	52.7	52.7
4:48 PM	7.90	53.5	53.5
4:49 PM	7.78	55.7	55.7
4:50 PM	6.97	58.4	58.4
4:51 PM	7.20	55.5	55.5
4:52 PM	6.48	51.3	51.3
4:53 PM	6.21	51.7	51.7
4:54 PM	6.17	53.5	53.5
4:55 PM	7.07	51.0	51.0
4:56 PM	7.11	47.5	47.5
4:57 PM	6.90	47.2	47.2
4:58 PM	6.94	45.9	45.9
4:59 PM	6.96	46.0	46.0
5:00 PM	6.72	47.9	47.9
5:01 PM	6.21	47.0	47.0
5:02 PM	5.13	46.3	46.3
5:03 PM	4.76	46.7	46.7
5:04 PM	4.56	49.2	49.2
5:05 PM	4.88	46.5	46.5
5:06 PM	4.86	43.2	43.2
5:07 PM	4.59	41.6	41.6
5:08 PM	4.10	41.5	41.5
5:09 PM	3.89	42.3	42.3
5:10 PM	3.78	42.5	42.5
5:11 PM	3.53	45.2	45.2
5:12 PM	3.47	42.4	42.4
5:13 PM	3.49	40.8	40.8
5:14 PM	3.41	39.3	39.3

5:15 PM	3.31	38.5	38.5
5:16 PM	3.18	39.0	39.0
5:17 PM	3.09	39.7	39.7
5:18 PM	3.11	39.5	39.5
5:19 PM	3.09	39.3	39.3
5:20 PM	3.10	41.4	41.4
5:21 PM	3.14	39.6	39.6
5:22 PM	3.17	38.0	38.0
5:23 PM	3.21	38.4	38.4
5:24 PM	3.04	38.3	38.3
5:25 PM	3.11	38.4	38.4
5:26 PM	3.06	36.0	36.0
5:27 PM	3.02	35.0	35.0
5:28 PM	2.91	35.1	35.1
5:29 PM	2.93	37.5	37.5
5:30 PM	3.01	37.5	37.5
5:31 PM	3.01	37.7	37.7
5:32 PM	3.11	39.9	39.9
5:33 PM	3.30	41.9	41.9
5:34 PM	3.47	41.1	41.1
5:35 PM	3.60	39.0	39.0
5:36 PM	3.65	35.4	35.4
5:37 PM	3.58	32.1	32.1
5:38 PM	3.49	31.8	31.8
5:39 PM	3.29	32.2	32.2
5:40 PM	3.05	35.4	35.4
5:41 PM	2.72	35.5	35.5
5:42 PM	2.48	35.5	35.5
5:43 PM	2.30	36.7	36.7
5:44 PM	2.16	37.2	37.2
5:45 PM	2.04	38.4	38.4
5:46 PM	1.92	38.4	38.4
5:47 PM	1.83	38.0	38.0
5:48 PM	1.78	38.9	38.9
5:49 PM	1.75	38.0	38.0
5:50 PM	1.72	38.1	38.1
5:51 PM	1.71	41.4	41.4
5:52 PM	1.73	42.0	42.0
5:53 PM	1.74	42.7	42.7
5:54 PM	1.72	42.9	42.9
5:55 PM	1.69	41.4	41.4
5:56 PM	1.62	40.7	40.7
5:57 PM	1.53	39.4	39.4
5:58 PM	1.46	37.8	37.8
5:59 PM	1.43	36.6	36.6
6:00 PM	1.42	36.5	36.5

Table 9.3: Event log for Day 1

ip Address	Rated Watt value	Off time	Location	Priority	Off count	event at: 6/15/20 18 10:57 AM	event at: 6/15/201 8 10:58 AM	event at: 6/15/201 8 10:59 AM	event at: 6/15/201 8 11:00 AM	event at: 6/15/201 8 11:01 AM	event at: 6/15/201 8 11:22 AM	event at: 6/15/201 8 11:23 AM	event at: 6/15/201 8 11:24 AM
192.168.8.168	2350	7	Chairman	1	4								
192.168.8.175	1970	5	H. Eng. Room	1	3								
192.168.8.176	1100	9	Head of HR & Admin	1	9								
192.168.8.179	1100	9	Chief FO	1	8								
192.168.8.180	1100	8	GM	1	7								
192.168.8.181	3670	5	Server room	1	1								
192.168.8.182	1190	7	Head of Operations	1	6								
192.168.8.154	1172	4	SDM	2	9								
192.168.8.157	1910	1	SOM	2	7								
192.168.8.167	860	9	CSM	2	11								
192.168.8.177	1900	8	PM	2	8								
192.168.8.188	1350	3	Conference Room	2	8								
192.168.8.189	1340	8	RM	2	8								
192.168.8.190	2367	1	DCC (middle)	2	5								
192.168.8.146	2300	5	SOD	3	14				1				1
192.168.8.147	1100	9	Control Engineer	3	15	1					1		
192.168.8.148	2000	8	Finance dept. common	3	15	1					1		
192.168.8.149	6400	7	IT manager	3	10					1			1
192.168.8.150	5500	1	IT 3rd Floor	3	7								
192.168.8.151	1550	6	SDD1	3	15	1					1		
192.168.8.152	1150	3	SDD2 (3)	3	14			1				1	
192.168.8.153	2340	1	Common area	3	9								
192.168.8.155	1800	5	Control room	3	15		1					1	
12.168.8.156	1300	3	Photocopy room	3	14			1				1	
192.168.8.158	2600	6	Finance dept.	3	13			1				1	

192.168.8.159	2700	6	Corporate office	3	13			1				1
192.168.8.160	6150	3	Reception	3	6							
192.168.8.161	1970	8	Library	3	15	1				1		
192.168.8.162	6150	3	Admin Office	3	6							
192.168.8.163	3200	1	Auditorium 1 (right)	3	9							
192.168.8.164	2840	9	SDD2 (middle)	3	15		1				1	
192.168.8.165	2400	8	Library 2	3	15	1						1
192.168.8.166	1930	8	Corporate office assistant	3	15	1					1	
192.168.8.169	1600	9	CSD	3	15	1					1	
192.168.8.170	1010	1	Call center	3	13					1		1
192.168.8.171	825	6	SDD2 (left)	3	15	1					1	
192.168.8.172	2350	7	SDD2 (right)	3	15		1					1
192.168.8.173	2480	7	Auditorium 1 (left)	3	14			1				1
192.168.8.174	1100	4	Accountant Treasury	3	15	1						1
192.168.8.178	1100	4	Financial Accountant	3	15		1					1
192.168.8.183	2500	6	Operations Division	3	13				1			1
192.168.8.184	1970	2	IT Development unit	3	12				1			1
192.168.8.185	3460	4	Supply Department	3	10							1
192.168.8.186	2200	1	Supply Department (right)	3	9							
192.168.8.187	1700	3	Lunch Room 1	3	13				1			1
192.168.8.191	1900	1	DCC (corner)	3	10							
192.168.8.192	1290	1	Chief Internal Auditor - IAD (right)	3	11							
192.168.8.193	1650	3	Chief Internal Auditor - IAD (left)	3	13				1			1
192.168.8.194	3100	7	new admin office 1	3	12			1				1
192.168.8.195	2200	2	new admin office 2	3	10							1

ip Address	Rated Watt value	Off time	Location	Priority	Off count	event at: 6/15/20 18 11:25 AM	event at: 6/15/20 18 11:26 AM	event at: 6/15/201 8 11:33 AM	event at: 6/15/201 8 11:34 AM	event at: 6/15/201 8 11:36 AM	event at: 6/15/201 8 11:37 AM	event at: 6/15/201 8 11:38 AM	event at: 6/15/201 8 11:44 AM
192.168.8.168	2350	7	Chairman	1	4		1						1
192.168.8.175	1970	5	H. Eng. Room	1	3			1					
192.168.8.176	1100	9	Head of HR & Admin	1	9		1						1
192.168.8.179	1100	9	Chief FO	1	8		1						1
192.168.8.180	1100	8	GM	1	7		1						1
192.168.8.181	3670	5	Server room	1	1			1					
192.168.8.182	1190	7	Head of Operations	1	6			1					1
192.168.8.154	1172	4	SDM	2	9		1					1	
192.168.8.157	1910	1	SOM	2	7		1					1	
192.168.8.167	860	9	CSM	2	11		1					1	
192.168.8.177	1900	8	PM	2	8		1					1	
192.168.8.188	1350	3	Conference Room	2	8		1					1	
192.168.8.189	1340	8	RM	2	8		1					1	
192.168.8.190	2367	1	DCC (middle)	2	5		1						1
192.168.8.146	2300	5	SOD	3	14					1			
192.168.8.147	1100	9	Control Engineer	3	15			1					1
192.168.8.148	2000	8	Finance dept. common	3	15			1					1
192.168.8.149	6400	7	IT manager	3	10					1			
192.168.8.150	5500	1	IT 3rd Floor	3	7		1					1	
192.168.8.151	1550	6	SDD1	3	15			1					1
192.168.8.152	1150	3	SDD2 (3)	3	14				1				
192.168.8.153	2340	1	Common area	3	9	1						1	
192.168.8.155	1800	5	Control room	3	15				1				
192.168.8.156	1300	3	Photocopy room	3	14					1			
192.168.8.158	2600	6	Finance dept.	3	13				1				
192.168.8.159	2700	6	Corporate office	3	13					1			
192.168.8.160	6150	3	Reception	3	6	1					1		

192.168.8.161	1970	8	Library	3	15			1					1
192.168.8.162	6150	3	Admin Office	3	6	1					1		
192.168.8.163	3200	1	Auditorium 1 (right)	3	9	1						1	
192.168.8.164	2840	9	SDD2 (middle)	3	15			1					1
192.168.8.165	2400	8	Library 2	3	15					1			
192.168.8.166	1930	8	Corporate office assistant	3	15			1					1
192.168.8.169	1600	9	CSD	3	15			1					1
192.168.8.170	1010	1	Call center	3	13						1		
192.168.8.171	825	6	SDD2 (left)	3	15			1					1
192.168.8.172	2350	7	SDD2 (right)	3	15					1			
192.168.8.173	2480	7	Auditorium 1 (left)	3	14					1			
192.168.8.174	1100	4	Accountant Treasury	3	15					1			
192.168.8.178	1100	4	Financial Accountant	3	15					1			
192.168.8.183	2500	6	Operations Division	3	13					1			
192.168.8.184	1970	2	IT Development unit	3	12						1		
192.168.8.185	3460	4	Supply Department	3	10						1		
192.168.8.186	2200	1	Supply Department (right)	3	9	1							1
192.168.8.187	1700	3	Lunch Room 1	3	13					1			
192.168.8.191	1900	1	DCC (corner)	3	10	1							1
192.168.8.192	1290	1	Chief Internal Auditor - IAD (right)	3	11	1							1
192.168.8.193	1650	3	Chief Internal Auditor - IAD (left)	3	13					1			
192.168.8.194	3100	7	new admin office 1	3	12					1			
192.168.8.195	2200	2	new admin office 2	3	10							1	

ip Address	Rated Watt value	Off time	Location	Priority	Off count	event at: 6/15/2018 11:45 AM	event at: 6/15/2018 11:48 AM	event at: 6/15/2018 11:50 AM	event at: 6/15/2018 2:09 PM	event at: 6/15/2018 2:10 PM	event at: 6/15/2018 2:11 PM	event at: 6/15/2018 2:12 PM	event at: 6/15/2018 2:13 PM
192.168.8.168	2350	7	Chairman	1	4								
192.168.8.175	1970	5	H. Eng. Room	1	3	1							
192.168.8.176	1100	9	Head of HR & Admin	1	9								
192.168.8.179	1100	9	Chief FO	1	8								
192.168.8.180	1100	8	GM	1	7								
192.168.8.181	3670	5	Server room	1	1								
192.168.8.182	1190	7	Head of Operations	1	6								
192.168.8.154	1172	4	SDM	2	9								
192.168.8.157	1910	1	SOM	2	7								
192.168.8.167	860	9	CSM	2	11								1
192.168.8.177	1900	8	PM	2	8								
192.168.8.188	1350	3	Conference Room	2	8								
192.168.8.189	1340	8	RM	2	8								
192.168.8.190	2367	1	DCC (middle)	2	5								
192.168.8.146	2300	5	SOD	3	14		1					1	
192.168.8.147	1100	9	Control Engineer	3	15				1				
192.168.8.148	2000	8	Finance dept. common	3	15				1				
192.168.8.149	6400	7	IT manager	3	10			1					1
192.168.8.150	5500	1	IT 3rd Floor	3	7								
192.168.8.151	1550	6	SDD1	3	15					1			
192.168.8.152	1150	3	SDD2 (3)	3	14	1					1		
192.168.8.153	2340	1	Common area	3	9								
192.168.8.155	1800	5	Control room	3	15	1				1			
192.168.8.156	1300	3	Photocopy room	3	14		1				1		
192.168.8.158	2600	6	Finance dept.	3	13	1					1		
192.168.8.159	2700	6	Corporate office	3	13		1				1		
192.168.8.160	6150	3	Reception	3	6								

192.168.8.161	1970	8	Library	3	15				1				
192.168.8.162	6150	3	Admin Office	3	6								
192.168.8.163	3200	1	Auditorium 1 (right)	3	9								
192.168.8.164	2840	9	SDD2 (middle)	3	15					1			
192.168.8.165	2400	8	Library 2	3	15	1					1		
192.168.8.166	1930	8	Corporate office assistant	3	15				1				
192.168.8.169	1600	9	CSD	3	15				1				
192.168.8.170	1010	1	Call center	3	13		1						1
192.168.8.171	825	6	SDD2 (left)	3	15				1				
192.168.8.172	2350	7	SDD2 (right)	3	15	1					1		
192.168.8.173	2480	7	Auditorium 1 (left)	3	14	1						1	
192.168.8.174	1100	4	Accountant Treasury	3	15	1			1				
192.168.8.178	1100	4	Financial Accountant	3	15	1						1	
192.168.8.183	2500	6	Operations Division	3	13	1							1
192.168.8.184	1970	2	IT Development unit	3	12				1				1
192.168.8.185	3460	4	Supply Department	3	10				1				
192.168.8.186	2200	1	Supply Department (right)	3	9								
192.168.8.187	1700	3	Lunch Room 1	3	13		1						1
192.168.8.191	1900	1	DCC (corner)	3	10								
192.168.8.192	1290	1	Chief Internal Auditor - IAD (right)	3	11								
192.168.8.193	1650	3	Chief Internal Auditor - IAD (left)	3	13				1				1
192.168.8.194	3100	7	new admin office 1	3	12	1							1
192.168.8.195	2200	2	new admin office 2	3	10								

ip Address	Rated Watt value	Off time	Location	Priority	Off count	event at: 6/15/2018 2:14 PM	event at: 6/15/2018 2:15 PM	event at: 6/15/2018 2:16 PM	event at: 6/15/2018 2:17 PM	event at: 6/15/2018 2:43 PM	event at: 6/15/2018 2:56 PM	event at: 6/15/2018 2:57 PM	event at: 6/15/2018 2:58 PM
192.168.8.168	2350	7	Chairman	1	4								
192.168.8.175	1970	5	H. Eng. Room	1	3								
192.168.8.176	1100	9	Head of HR & Admin	1	9				1				
192.168.8.179	1100	9	Chief FO	1	8				1				
192.168.8.180	1100	8	GM	1	7								
192.168.8.181	3670	5	Server room	1	1								
192.168.8.182	1190	7	Head of Operations	1	6								
192.168.8.154	1172	4	SDM	2	9			1					
192.168.8.157	1910	1	SOM	2	7				1				
192.168.8.167	860	9	CSM	2	11								1
192.168.8.177	1900	8	PM	2	8			1					
192.168.8.188	1350	3	Conference Room	2	8				1				
192.168.8.189	1340	8	RM	2	8			1					
192.168.8.190	2367	1	DCC (middle)	2	5								
192.168.8.146	2300	5	SOD	3	14								1
192.168.8.147	1100	9	Control Engineer	3	15					1	1		
192.168.8.148	2000	8	Finance dept. common	3	15					1		1	
192.168.8.149	6400	7	IT manager	3	10								
192.168.8.150	5500	1	IT 3rd Floor	3	7				1				
192.168.8.151	1550	6	SDD1	3	15						1		
192.168.8.152	1150	3	SDD2 (3)	3	14								1
192.168.8.153	2340	1	Common area	3	9	1							
192.168.8.155	1800	5	Control room	3	15							1	
192.168.8.156	1300	3	Photocopy room	3	14								1

ip Address	Rated Watt value	Off time	Location	Priority	Off count	event at: 6/15/2018 3:00 PM	event at: 6/15/2018 3:01 PM	event at: 6/15/2018 3:12 PM	event at: 6/15/2018 3:16 PM	event at: 6/15/2018 3:55 PM	event at: 6/15/2018 3:56 PM
192.168.8.168	2350	7	Chairman	1	4						
192.168.8.175	1970	5	H. Eng. Room	1	3						
192.168.8.176	1100	9	Head of HR & Admin	1	9						
192.168.8.179	1100	9	Chief FO	1	8						
192.168.8.180	1100	8	GM	1	7						
192.168.8.181	3670	5	Server room	1	1						
192.168.8.182	1190	7	Head of Operations	1	6						
192.168.8.154	1172	4	SDM	2	9						
192.168.8.157	1910	1	SOM	2	7						
192.168.8.167	860	9	CSM	2	11						
192.168.8.177	1900	8	PM	2	8						
192.168.8.188	1350	3	Conference Room	2	8						
192.168.8.189	1340	8	RM	2	8						
192.168.8.190	2367	1	DCC (middle)	2	5						
192.168.8.146	2300	5	SOD	3	14						
192.168.8.147	1100	9	Control Engineer	3	15			1		1	
192.168.8.148	2000	8	Finance dept. common	3	15			1		1	
192.168.8.149	6400	7	IT manager	3	10	1					
192.168.8.150	5500	1	IT 3rd Floor	3	7						
192.168.8.151	1550	6	SDD1	3	15				1		1
192.168.8.152	1150	3	SDD2 (3)	3	14						
192.168.8.153	2340	1	Common area	3	9	1					
192.168.8.155	1800	5	Control room	3	15				1		
192.168.8.156	1300	3	Photocopy room	3	14						
192.168.8.158	2600	6	Finance dept.	3	13						

192.168.8.159	2700	6	Corporate office	3	13						
192.168.8.160	6150	3	Reception	3	6		1				
192.168.8.161	1970	8	Library	3	15			1		1	
192.168.8.162	6150	3	Admin Office	3	6		1				
192.168.8.163	3200	1	Auditorium 1 (right)	3	9		1				
192.168.8.164	2840	9	SDD2 (middle)	3	15				1		1
192.168.8.165	2400	8	Library 2	3	15				1		1
192.168.8.166	1930	8	Corporate office assistant	3	15				1	1	
192.168.8.169	1600	9	CSD	3	15			1		1	
192.168.8.170	1010	1	Call center	3	13	1					
192.168.8.171	825	6	SDD2 (left)	3	15			1		1	
192.168.8.172	2350	7	SDD2 (right)	3	15				1		
192.168.8.173	2480	7	Auditorium 1 (left)	3	14				1		
192.168.8.174	1100	4	Accountant Treasury	3	15			1			1
192.168.8.178	1100	4	Financial Accountant	3	15				1		
192.168.8.183	2500	6	Operations Division	3	13						
192.168.8.184	1970	2	IT Development unit	3	12	1					
192.168.8.185	3460	4	Supply Department	3	10	1					
192.168.8.186	2200	1	Supply Department (right)	3	9	1					
192.168.8.187	1700	3	Lunch Room 1	3	13						
192.168.8.191	1900	1	DCC (corner)	3	10		1				
192.168.8.192	1290	1	Chief Internal Auditor - IAD (right)	3	11		1				
192.168.8.193	1650	3	Chief Internal Auditor - IAD (left)	3	13						
192.168.8.194	3100	7	new admin office 1	3	12						
192.168.8.195	2200	2	new admin office 2	3	10	1					